

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS) AP4

ACCESSION NBR: 8310120067 DOC. DATE: 83/10/06 NOTARIZED: NO DOCKET #
 FACIL: 50-388 Susquehanna Steam Electric Station, Unit 2, Pennsylvania 05000388
 AUTH. NAME AUTHOR AFFILIATION
 CURTIS, N.W. Pennsylvania Power & Light Co.
 RECIPIENT NAME RECIPIENT AFFILIATION
 SCHWENCER, A. Licensing Branch 2

SUBJECT: Forwards revised Section 7.6 to FSAR, clarifying pressure indicator monitoring, adding discussion of non-Class IE temp sensors & including average power range monitor upscale thermal trip. Revs will be incorporated into next FSAR rev.

DISTRIBUTION CODE: B001S COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 4
 TITLE: Licensing Submittal: PSAR/FSAR Amdts & Related Correspondence

NOTES: 1cy NMSS/FCAF/PM. LPDR 2cys.

05000388

	RECIPIENT		COPIES			RECIPIENT		COPIES	
	ID CODE/NAME		LTTR	ENCL		ID CODE/NAME		LTTR	ENCL
	NRR/DL/ADL		1	0	NRR LB2 BC		1	0	
	NRR LB2 LA		1	0	PERCH, R.	01	1	1	
INTERNAL:	ELD/HDS4		1	0	IE FILE		1	1	
	IE/DEPER/EPB	36	3	3	IE/DEPER/IRB	35	1	1	
	IE/DEQA/QAB	21	1	1	NRR/DE/AEAB		1	0	
	NRR/DE/CEB	11	1	1	NRR/DE/EHEB		1	1	
	NRR/DE/EOB	13	2	2	NRR/DE/GB	28	2	2	
	NRR/DE/MEB	18	1	1	NRR/DE/MTEB	17	1	1	
	NRR/DE/SAB	24	1	1	NRR/DE/SGEB	25	1	1	
	NRR/DHFS/HFEB40		1	1	NRR/DHFS/LQB	32	1	1	
	NRR/DHFS/PSRB		1	1	NRR/DL/SSPB		1	0	
	NRR/DSI/AEB	26	1	1	NRR/DSI/ASB		1	1	
	NRR/DSI/CPB	10	1	1	NRR/DSI/CSB	09	1	1	
	NRR/DSI/ICSB	16	1	1	NRR/DSI/METB	12	1	1	
	NRR/DSI/PSB	19	1	1	NRR/DSI/RAB	22	1	1	
	NRR/DSI/RSB	23	1	1	REG FILE	04	1	1	
	RGN1		3	3	RM/DDAMI/MIB		1	0	
EXTERNAL:	ACRS	41	6	6	BNL (AMDTS ONLY)		1	1	
	DMB/DSS (AMDTS)		1	1	FEMA-REP DIV	39	1	1	
	LPDR	03	2	2	NRC PDR	02	1	1	
	NSIC	05	1	1	NTIS		1	1	
NOTES:			3	3					

TOTAL NUMBER OF COPIES REQUIRED: LTR 57 ENCL 50

SECRET

CONFIDENTIAL

CONFIDENTIAL

CONFIDENTIAL

CONFIDENTIAL

DATE	TIME	LOCATION	STATUS	REMARKS
10/10/54	10:00
10/11/54	10:00
10/12/54	10:00
10/13/54	10:00
10/14/54	10:00
10/15/54	10:00
10/16/54	10:00
10/17/54	10:00
10/18/54	10:00
10/19/54	10:00
10/20/54	10:00
10/21/54	10:00
10/22/54	10:00
10/23/54	10:00
10/24/54	10:00
10/25/54	10:00
10/26/54	10:00
10/27/54	10:00
10/28/54	10:00
10/29/54	10:00
10/30/54	10:00
10/31/54	10:00



Pennsylvania Power & Light Company

Two North Ninth Street • Allentown, PA 18101 • 215 / 770-5151

Norman W. Curtis
Vice President-Engineering & Construction-Nuclear
215/770-7501

OCT 06 1983

Director of Nuclear Reactor Regulation
Attention: Mr. A. Schwencer, Chief
Licensing Branch No. 2
Division of Licensing
U. S. Nuclear Regulatory Commission
Washington, DC 20555

SUSQUEHANNA STEAM ELECTRIC STATION
FSAR SECTION 7.6
ER 100508 FILE 841-1
PLA-1836

Docket No. 50-388

Dear Mr. Schwencer:

In order to support obtaining an operating license for Susquehanna SES Unit 2, enclosed is a revised Section 7.6 of the Susquehanna SES FSAR. The revisions to this section are as follows:

- 7.6.1a.4.3.8.1 - This section has been revised to show a clarification that a pressure indicator monitors the pressure between the inner and outer head seal ring.
- 7.6.1b.1.2.4.1 - This section has been revised to add a discussion on the additional non-Class IE temperature sensors for Unit 2.
- Table 7.6-5 - This table has been revised to include the APRM Upscale Thermal Trip.

These revisions will be incorporated into the next amendment to the FSAR.


Very truly yours,

N. W. Curtis
Vice President-Engineering & Construction-Nuclear

Enclosure

cc: R. L. Perch NRC

1300/
1/1





2
3
4
5

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100

101

102
103
104
105
106
107
108
109
110
111
112
113
114
115
116
117
118
119
120
121
122
123
124
125
126
127
128
129
130
131
132
133
134
135
136
137
138
139
140
141
142
143
144
145
146
147
148
149
150
151
152
153
154
155
156
157
158
159
160
161
162
163
164
165
166
167
168
169
170
171
172
173
174
175
176
177
178
179
180
181
182
183
184
185
186
187
188
189
190
191
192
193
194
195
196
197
198
199
200

201
202
203
204
205
206
207
208
209
210
211
212
213
214
215
216
217
218
219
220
221
222
223
224
225
226
227
228
229
230
231
232
233
234
235
236
237
238
239
240
241
242
243
244
245
246
247
248
249
250
251
252
253
254
255
256
257
258
259
260
261
262
263
264
265
266
267
268
269
270
271
272
273
274
275
276
277
278
279
280
281
282
283
284
285
286
287
288
289
290
291
292
293
294
295
296
297
298
299
300

301
302
303
304
305
306
307
308
309
310
311
312
313
314
315
316
317
318
319
320
321
322
323
324
325
326
327
328
329
330
331
332
333
334
335
336
337
338
339
340
341
342
343
344
345
346
347
348
349
350
351
352
353
354
355
356
357
358
359
360
361
362
363
364
365
366
367
368
369
370
371
372
373
374
375
376
377
378
379
380
381
382
383
384
385
386
387
388
389
390
391
392
393
394
395
396
397
398
399
400

401
402
403
404
405
406
407
408
409
410
411
412
413
414
415
416
417
418
419
420
421
422
423
424
425
426
427
428
429
430
431
432
433
434
435
436
437
438
439
440
441
442
443
444
445
446
447
448
449
450
451
452
453
454
455
456
457
458
459
460
461
462
463
464
465
466
467
468
469
470
471
472
473
474
475
476
477
478
479
480
481
482
483
484
485
486
487
488
489
490
491
492
493
494
495
496
497
498
499
500

501
502
503
504
505
506
507
508
509
510
511
512
513
514
515
516
517
518
519
520
521
522
523
524
525
526
527
528
529
530
531
532
533
534
535
536
537
538
539
540
541
542
543
544
545
546
547
548
549
550
551
552
553
554
555
556
557
558
559
560
561
562
563
564
565
566
567
568
569
570
571
572
573
574
575
576
577
578
579
580
581
582
583
584
585
586
587
588
589
590
591
592
593
594
595
596
597
598
599
600

temperature sensing elements located in the service area of the fans. If high temperature is detected the electronic switches will initiate the low speed operation of the drywell cooling fans.

Electronic signal converters with full electrical input-output isolation are placed between safety related instrumentation and the input channels to the recorders.

Two redundant multipoint recorders for the primary containment pool temperature monitoring system provide a permanent history of all RTD measurements to the operator in the control room.

Each temperature sensing circuit is equipped with alarm switches and initiate one control room alarm per redundant channel.

One temperature indicator for the primary containment is located on the remote shutdown panel. Refer to Subsection 7.4.1:4 for system description. Instrument ranges are defined in Section 7.5.

Nine dual element RTDs per redundant system are located in the primary containment to sense the temperature in the Unit 2 drywell for a non-Class IE application. The signal from the RTD elements is received and recorded by two redundant multipoint recorders located on local panels.

7.6.1b.1.2.4.2 Equipment Design-Suppression Pool Temperature

The suppression pool temperature is monitored by two redundant systems, each of which performs as described below.

Eight RTD's per redundant system are located in the suppression pool approximately six inches below the minimum pool water level. These sensors are located around the pool in order to provide a good spatial distribution of pool temperature. Refer to Table 7.6-9 for the exact location of these sensors.

The signals from the sensors are processed by an electronic unit located on a main control room back panel. This electronic unit converts the RTD signals into degrees Fahrenheit and computes the average of the eight temperatures. If one of the RTD's fails, an error alarm is generated, and the failed RTD may be removed from the calculation of the average by operator action. The average value is displayed by digital indicators located both on the electronic unit, the main control board, and a vertical meter located on the RSP. A keyboard allows the operator to display any individual temperature input.

7.6.1a.4.3.7.2.2 Logic and Sequencing

No action is initiated by the safety/relief valve temperature monitoring circuit.

7.6.1a.4.3.7.2.3 Bypasses and Interlocks

There are no bypasses or interlocks associated with this subsystem.

7.6.1a.4.3.7.2.4 Redundancy and Diversity

No redundancy or diversity is required for this system.

7.6.1a.4.3.8 Reactor Vessel Head Leak Detection7.6.1a.4.3.8.1 Subsystem Identification

A pressure between the inner and outer head seal ring will be sensed by a pressure indicator. If the inner seal leaks, the pressure indicator will monitor the pressure.

The plant will continue to operate with the outer seal as a backup and the inner seal can be repaired at the next outage when the head is removed. If both the inner and outer head seals leak, the leak will be detected by an increase in drywell temperature and pressure.

7.6.1a.4.3.8.2 Head Seal Integrity Pressure Monitoring7.6.1a.4.3.8.2.1 Circuit Description

A pressure-indicating switch will monitor the pressure between the inner and outer head seals.

SSES-FSAR

TABLE 7.6-5

APRM SYSTEM TRIPS ⁽¹⁾

<u>TRIP FUNCTION</u>	<u>TRIP POINT RANGE</u>	<u>ACTION</u>
APRM downscale	2% to full scale	Rod block, annunciator white light display
APRM upscale (high)	Setpoint varied with flow, slope adjustable, intercepts separately adjustable	Rod block, annunciator amber light display
APRM upscale Thermal Trip ⁽²⁾	Variables flow versus LPRM average power compared, slopes separately adjustable, intercept defined	Scram, annunciator, red ⁽³⁾ light display
APRM upscale (high-high)	2% to full scale	Scram, annunciator, red ⁽³⁾ light display
APRM inoperative	Calibrate switch or too few inputs	Scram, rod block, annunciator red light display
APRM Bypass	Manual Switch	White light

(1) See plant Technical Specifications for setpoints.

(2) APRM signal passes through a 6 second time constant circuit to simulate heat flux prior to comparison.

(3) Same red light display.

