REGULATORY INFORMATION DISTRIBUTION STOTEM (RIDS)

ACCESSION NBR:8409240106 DOC.DATE: 84/09/19 NOTARIZED: NO . DOCKET! # FACIL:50-387 Susquehanna Steam Electric Station, Unit: 1, Pennsylva 05000387 50-388 Susquehanna Steam Electric Station, Unit 2, Pennsylva 05000388

AUTHOR AFFILIATION AUTH NAME

CURTIS, N.W.

Pennsylvania Power & Light Co.

RECIP.NAME RECIPIENT AFFILIATION SCHWENCER, A. Licensing Branch 2

SUBJECT: Forwards application for amend to License NPF-14, changing Tech Specs to remove motor operators from emergency svc water (ESW) pump discharge valves & add valves on ESW return lines from control structure chillers.

NOTES:1cy NMSS/FCAF/PM. LPDR 2cys Transcripts.

05000387

OL:07/17/82

1cy NMSS/FCAF/PM. LPDR 2cys Transcripts. OL:03/23/84

05000388

••	RECIPIENT ID CODE/NAME NRR LB2 BC 01.		COPIES LTTR ENCL 7 7		RECIPIENT: ID CODE/NAME		COPIES LTTR ENCL	
INTERNAL:	ADM/LFMB NRR/DE/MTEB NRR/DL/ORAB NRR/DSI/RAB RGN1		1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1	0 1 0 1	ELD/HDS4 NRR/DL.DIR NRR/DSI/METB REG FILE 04		1 0 1 1 1 1 1 1 1,	
EXTERNAL:	ACRS NRC PDR NTIS	09· 09·	6 1 1	6 1 1 .	LPDR NSIC	03* 05	2	2. ' 1.
- \				_				

NOTES:

Reeld wheek \$150== # 516760

METHOD TO THE RESTORD AND THE TOTAL PROPERTY OF THE TOTAL PROPERTY

Provided the second of the sec 4 4 14 14 14

consplyationer atamtem. AR THRATES HOUR MAN A . Malak The Committee of Albertania of the La Caralla Caralla


কি পাচ এই চুচ্চী ছিলেন্ত্ৰ কৈছে এই কেন্দ্ৰেল্য হৈছে এই জানা হয়। তাই এই পিনাৰে কেন্দ্ৰেল্য কি প্ৰতিষ্ঠান কৰি ক ইনিকাল কেন্দ্ৰেল্ড সংক্ৰমত প্ৰতিষ্ঠান প্ৰক্ৰমত এই কেন্দ্ৰেল্য কৰি জন্ত সংস্থায় কৰি বিশ্বস্থান কৰি কৰে। আনক্ৰিকাল ইয়ে চুচ্চী কৰে কৰে কৰি কিয়াৰ বাম প্ৰক্ৰমত ক্ষেত্ৰ বিশ্বস্থান কৰি কৰি এই এই এই এই The state of the s arage, fro control stoucture entities.

A A STATE THE THE THE STATE OF Alite: Mr - My - Ath Ale Gongon A - Actorio thing

and the content of the state of the theory and the

VIVI 11 X X . X A SUNGO Boy I was a series of the second second second second second 1 18 No to 5 1

	7 g 7 g >(7 g 7 g		A STATE OF S	J > -				
X N	, t t	· , *		, I	# # #	, ()	THE RESERVE	: #A # + \$ F - 8 -
4	f t	й , ,	92 में में •ुप ह ें	» Р Д) , ,	√ 1 3 2• ft	· 1 2 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1	2 # ½ ° o t = ₹ x · .
-	· · ·	* 16	4	est.	er 3			\$: ⁴ ∰



Two North Ninth Street • Allentown, PA 18101 • 215 / 770-5151

Norman W. Curtis Vice President-Engineering & Construction-Nuclear 215/770-7501

SEP 19 1984

Director of Nuclear Reactor Regulation Attention: Mr. A. Schwencer, Chief Licensing Branch No. 2 Division of Licensing U.S. Nuclear Regulatory Commission Washington, D.C. 20555

SUSQUEHANNA STEAM ELECTRIC STATION
PROPOSED AMENDMENTS 47 TO LICENSE NPF-14
AND 8 TO LICENSE NPF-22
ERT100450 FILE 841-8
PLA-2297

Docket Nos. 50-387 50-388

Reference: PLA-1812, N. W. Curtis to T. E. Murley, dated Sept. 22, 1983.

Dear Mr. Schwencer:

Via the referenced letter, PP&L submitted its final report on a deficiency involving water hammer in the Emergency Service Water (ESW) system. As part of the modifications needed to support the corrective action described in that report, the motor operators from the ESW pump discharge valves (HV-01101A,B,C,D) will be removed, and motor operated valves HV-08693A and B will be added on the ESW return lines from the control structure chillers.

The purpose of this letter is to propose changes to Table 3.8.4.2-1 in the Susquehanna SES Unit 1 and Unit 2 Technical Specifications in order to support the subject modifications, which will be performed during the first refueling outage of Unit 1. Attachment A provides a mark-up of the Unit 1 changes; note that it deletes the addition of the discharge valves which was previously proposed in Proposed Amendment 43 to License No. NPF-14. Attachment B provides a mark-up of the identical changes for Unit 2.

In order to support ESW operability requirements during the Unit 1 first refueling outage, PP&L requests that this change be approved prior to the start of the outage, and that it be conditioned to become effective prior to startup following the outage. This will allow the needed flexibility to perform the modifications anytime during the outage without causing conflicts with the Technical Specifications.

NO SIGNIFICANT HAZARDS CONSIDERATIONS

I. The proposed change does not involve a significant increase in the probability or consequences of an accident previously evaluated. The

8409240106 840919 PDR ADDCK 05000387 PDR PDR 1/1 HOD/

20 g g

May to the transport of the transport of

The gradient of the second of

The state of the s

the control of the second of the control of the con

The state of the s

The state of the s

The state of the s

the first of the f

SSES PLA-2297 ER 100450 File 841-8 Mr. A. Schwencer

removal of the motor operators (and installation of manual operators) on the ESW pump discharge valves poses no hazard. These valves will be locked open and are not required to change position in order for the ESW loop to function properly. The addition of the HV-08693A and B valves functionally replace two motor operated valves which will be converted to locked open, manually-operated valves. Hence, the loss of a new valve is no different than the loss of an existing valve.

- II. The proposed change does not create the possibility of a new or different kind of accident from any accident previously evaluated. The original design of the ESW pump discharge valves required manual operators; this change returns them to that design. The control structure chiller motor operated valves are a one-for-one replacement of existing valves.
- III. The proposed change does not involve a significant reduction in a margin of safety. The margin of safety will be improved due to the mitigation of water hammer in the ESW system. As stated in I. above, the proposed modifications do not affect the capability of ESW to function properly under normal or accident conditions.

Any questions on the proposed changes should be directed to Mr. R. Sgarro at (215) 770-7855. Pursuant to 10CFR170.22, the appropriate fees are enclosed.

Very truly yours,

N. W. Curtis

Vice President-Engineering & Construction-Nuclear

Attachments

cc: R. L. Perch - USNRC

T. M. Gerusky, Director Bureau of Radiation Protection Pennsylvania Dept. of Environmental Resources P.O. Box 2063 Harrisburg, PA 17120 , , ,

The second of th

A COMPANIE DE LA COMP EN LA COMPANIE DE LA COMPANIE DEL COMPANIE DE LA COMPANIE DEL COMPANIE DE LA COMPANIE DEL COMPANIE DE LA COMPANIE DEL COMPANIE DE LA COMPANIE DE LA COMPANIE DEL COM

and the second of the second o

and the second of the second o

The second secon

The factor will broke the first and the second of the seco

. . .