

REGULATOR INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8410260019 DOC. DATE: 84/10/19 NOTARIZED: NO DOCKET #
 FACIL: 50-387 Susquehanna Steam Electric Station, Unit 1, Pennsylvania 05000387
 AUTH. NAME AUTHOR AFFILIATION
 KENYON, B.D. Pennsylvania Power & Light Co.
 RECIP. NAME RECIPIENT AFFILIATION
 SCHWENCER, A. Licensing Branch 2

SUBJECT: Application to amend License NPF-14, changing Tech Spec
 4.1.3.1.4 re surveillance requirements for reactivity
 control sys to allow exemption from Spec 4.0.4 for entry
 into Operational Condition 2.

DISTRIBUTION CODE: A001D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 2+1
 TITLE: OR Submittal: General Distribution

NOTES: 1cy NMSS/FCAP/PM. LPDR 2cys Transcripts. 05000387
 OL: 07/17/82

	RECIPIENT ID CODE/NAME		COPIES LTTR ENCL		RECIPIENT ID CODE/NAME		COPIES LTTR ENCL
	NRR LB2 BC 01		7 7				
INTERNAL:	ADM/LFMB		1 0		ELD/HDS4		1 0
	NRR/DE/MTEB		1 1		NRR/DL DIR		1 1
	NRR/DL/ORAB		1 0		NRR/DSI/METB		1 1
	NRR/DSI/RAB		1 1		REG FILE 04		1 1
	RGN1		1 1				
EXTERNAL:	ACRS 09		6 6		LPDR 03		2 2
	NRC PDR 02		1 1		NSIC 05		1 1
	NTIS		1 1				
NOTES:			3 3				

THE UNIVERSITY OF CHICAGO
DEPARTMENT OF CHEMISTRY
530 SOUTH EAST ASIAN AVENUE
CHICAGO, ILLINOIS 60607
TEL: 773-936-3700

CONFIDENTIAL - INFORMATION CONTAINED
HEREIN IS UNCLASSIFIED EXCEPT WHERE
SHOWN OTHERWISE

CONFIDENTIAL - INFORMATION CONTAINED
HEREIN IS UNCLASSIFIED EXCEPT WHERE
SHOWN OTHERWISE

DATE	TIME	LOCATION	PERSONNEL	STATUS	REMARKS
10/15/77	14:00	LAB 101	J. D. WATSON	OK	WORKING
10/15/77	14:00	LAB 101	J. D. WATSON	OK	WORKING
10/15/77	14:00	LAB 101	J. D. WATSON	OK	WORKING
10/15/77	14:00	LAB 101	J. D. WATSON	OK	WORKING
10/15/77	14:00	LAB 101	J. D. WATSON	OK	WORKING
10/15/77	14:00	LAB 101	J. D. WATSON	OK	WORKING
10/15/77	14:00	LAB 101	J. D. WATSON	OK	WORKING
10/15/77	14:00	LAB 101	J. D. WATSON	OK	WORKING
10/15/77	14:00	LAB 101	J. D. WATSON	OK	WORKING
10/15/77	14:00	LAB 101	J. D. WATSON	OK	WORKING



Pennsylvania Power & Light Company

Two North Ninth Street • Allentown, PA 18101 • 215 / 770-5151

OCT 19 1984

Bruce D. Kenyon
Vice President-Nuclear Operations
215/770-7502

Director of Nuclear Reactor Regulation
Attention: Mr. A. Schwencer, Chief
Licensing Branch No. 2
Division of Licensing
U.S. Nuclear Regulatory Commission
Washington, DC 20555

SUSQUEHANNA STEAM ELECTRIC STATION
REQUEST FOR EMERGENCY CHANGE TO
TECHNICAL SPECIFICATION 4.1.3.1.4
ER 100450 FILE 841-8
PLA-2338

Docket No. 50-387

Dear Mr. Schwencer:

The purpose of this letter is to request that the portion of the change to Technical Specification 4.1.3.1.4 regarding the footnote which was submitted in proposed Amendment 43 to License No. NPF-14 on May 18, 1984 be processed as an emergency change in accordance with 10CFR50.91.

A marked-up copy of Technical Specification 4.1.3.1.4 showing the proposed change is attached.

This proposed change which requests an exemption from Specification 4.0.4 was provided so that OPERATIONAL CONDITION 2 could be entered to perform the required surveillance without requiring any interpretation. As such, this administrative change is an example of no significant hazards consideration as cited in column 3, paragraph (i) of 48FR14870. This proposed change has been included in the Susquehanna SES Unit 2 Technical Specifications and is consistent with recently issued BWR Technical Specifications.

The processing of this request to change the Technical Specifications in accordance with 10CFR50.91(5) is justified because in order to perform the required surveillance, the unit would have to enter Operational Condition 2, however the existing Technical Specification does not allow this. The unit would have to remain shutdown since it could not enter Operational Condition 2 to perform the necessary surveillance and thus declare the scram discharge volume operable.

This emergency situation could not have been avoided since it was not anticipated that the scram discharge volume drain and vent valves would not close within 30 seconds and that there was no way to retest them to declare them operable.

8410260019 841019
PDR ADOCK 05000387
P PDR

A-001
11

Faint, illegible text at the top of the page, possibly a header or introductory paragraph.

Second block of faint, illegible text, appearing as a separate paragraph.

Third block of faint, illegible text, continuing the document's content.

Fourth block of faint, illegible text, showing further details or a list.

Fifth block of faint, illegible text at the bottom of the page, possibly a conclusion or signature area.

OCT 19 1984

Page 2

SSES PLA-2238
ER 100450 File 841-8
Mr. A. Schwencer

As soon as the proposed Technical Specification change is approved, Susquehanna SES Unit 1 will be retested and restarted.

The Commonwealth of Pennsylvania has been notified as to our intention to change this Technical Specification via a letter (PLA-2208) dated May 18, 1984 and by copy of this letter.

We consider that this proposed change meets the criteria for an exclusion as defined in 10CFR51.22(C)(9) since:

1. This change is an example of a change which contains no significant hazards as cited in column 3, paragraph (1) of 48FR14870.
2. This change does not involve a significant change in the types or significant increase in the amounts of any effluents that may be released offsite because the change only involves only a clarification of when the surveillance is performed and not a change in the surveillance.
3. This change does not involve a significant increase in individual or cumulative occupational radiation exposure because the method of performing the surveillance does not change only the clarification of when the surveillance be performed.

If you have any questions, please contact us.

Very truly yours,



B. D. Kenyon
Vice President-Nuclear Operations

Attachments

cc: R. L. Perch USNRC
R. H. Jacobs USNRC

Thomas M. Gerusky, Director
Bureau of Radiation Protection
Pennsylvania Dept. of Environmental Resources
P. O. Box 2063
Harrisburg, PA 17120



Handwritten marks and characters in the top right corner.

Main body of the document containing faint, illegible text and scattered black specks.