

TABLE 3.3.2-1 (Continued)

ISOLATION ACTUATION INSTRUMENTATION

<u>TRIP FUNCTION</u>	<u>ISOLATION SIGNAL(S) (a)</u>	<u>MINIMUM OPERABLE CHANNELS PER TRIP SYSTEM (b)</u>	<u>APPLICABLE OPERATIONAL CONDITION</u>	<u>ACTION</u>
3. <u>MAIN STEAM LINE ISOLATION</u>				
a. Reactor Vessel Water Level - (Low, Low, Low, Level 1)	⊗ X	2	1, 2, 3	21
b. Main Steam Line Radiation - High	C	2	1, 2, 3	21
c. Main Steam Line Pressure - Low	P	2	1	22
d. Main Steam Line Flow - High	D	2/line	1, 2, 3	20
e. Condenser Vacuum - Low	UA	2	1, 2, 3	21
f. Main Steam Line Tunnel Temperature - High	E	2/line	1, 2, 3	21
g. Main Steam Line Tunnel Δ Temperature - High	E	2	1, 2, 3	21
h. Manual Initiation	NA	1	1, 2, 3	24
4. <u>REACTOR WATER CLEANUP SYSTEM ISOLATION</u>				
a. RWCS Δ Flow - High	J	1	1, 2, 3	23
b. RWCS Area Temperature - High	W	3	1, 2, 3	23
c. RWCS Area Ventilation Δ Temp. - High	W	3	1, 2, 3	23
d. SLCS Initiation	(d)	NA	1, 2, 3	23
e. Reactor Vessel Water Level - Low Low, Level 2	B	2	1, 2, 3	23
f. RWCS Δ Pressure - High	J	1	1, 2, 3	23
g. Manual Initiation	NA	1	1, 2, 3	24

8411120367-841031
PDR ADOCK 05000387
P PDR

TABLE 3.3.2-2

ISOLATION ACTUATION INSTRUMENTATION SETPOINTS

<u>TRIP FUNCTION</u>	<u>TRIP SETPOINT</u>	<u>ALLOWABLE VALUE</u>
1. PRIMARY CONTAINMENT ISOLATION		
a. Reactor Vessel Water Level		
1) Low, Level 3	> 13.0 inches*	> 11.5 inches
2) Low Low, Level 2	> -38.0 inches*	> -45.0 inches
3) Low Low Low, Level 1	> -129 inches*	> -136 inches
b. Drywell Pressure - High	< 1.72 psig	< 1.88 psig
c. Manual Initiation	NA	NA
2. SECONDARY CONTAINMENT ISOLATION		
a. Reactor Vessel Water Level - Low Low, Level 2	≥ -38.0 inches*	≥ -45.0 inches
b. Drywell Pressure - High	≤ 1.72 psig	≤ 1.88 psig
c. Refuel Floor High Exhaust Duct Radiation - High	≤ 2.5 mR/hr.**	≤ 4.0 mR/hr.**
d. Railroad Access Shaft Exhaust Duct Radiation - High	≤ 2.5 mR/hr.**	≤ 4.0 mR/hr.**
e. Refuel Floor Wall Exhaust Duct Radiation - High	< 2.5 R/hr.**	< 4.0 mR/hr.**
f. Manual Initiation	NA	NA
3. MAIN STEAM LINE ISOLATION		
a. Reactor Vessel Water Level - Low Low, Level 2	≥ -129 inches*	≥ -136 inches
b. Main Steam Line Radiation - High	< 3 X full power background	< 3.6 X full power background
c. Main Steam Line Pressure - Low	≥ 861 psig	≥ 841 psig
d. Main Steam Line Flow - High	≤ 107 psid	≤ 110 psid

SUSUNJEHANNA - UNIT 1

3/4 3-17

Amendment No. 4

TABLE 3.3.2-3

ISOLATION SYSTEM INSTRUMENTATION RESPONSE TIME



<u>TRIP FUNCTION</u>	<u>RESPONSE TIME (Seconds)#</u>
1. PRIMARY CONTAINMENT ISOLATION	
a. Reactor Vessel Water Level	
1) Low, Level 3	<10(a)
2) Low Low, Level 2	<1.0*/<10(a)**
3) Low Low Low, Level 1	<10(2)
b. Drywell Pressure - High	<10(a)
c. Manual Initiation	NA
2. SECONDARY CONTAINMENT ISOLATION	
a. Reactor Vessel Water Level-Low Low, Level 2	<10(a)
b. Drywell Pressure - High	<10(a)
c. Refuel Floor High Exhaust Duct Radiation - High (b)	<10(a)
d. Railroad Access Shaft Exhaust Duct Radiation - High (b)	<10(a)
e. Refuel Floor Wall Exhaust Duct Radiation -High (b)	<10(a)
f. Manual Initiation	NA
3. MAIN STEAM LINE ISOLATION	
a. Reactor Vessel Water Level- Low, Low, Level 1	<10(a)
b. Main Steam Line Radiation - High (a)(b)	<1.0*/<10(a)**
c. Main Steam Line Pressure - Low	<1.0*/<10(a)**
d. Main Steam Line Flow-High	<0.5*/<10(a)**
e. Condenser Vacuum - Low	NA
f. Main Steam Line Tunnel Temperature - High	NA
g. Main Steam Line Tunnel Δ Temperature - High	NA
h. Manual Initiation	NA
4. REACTOR WATER CLEANUP SYSTEM ISOLATION	
a. RWCS Δ Flow - High	<10(a)##
b. RWCS Area Temperature - High	NA
c. RWCS Area Ventilation Temperature ΔT - High	NA
d. SLCS Initiation	NA
e. Reactor Vessel Water Level - Low Low, Level 2	<10(a)
f. RWCS Δ Pressure - High	NA
g. Manual Initiation	NA
5. REACTOR CORE ISOLATION COOLING SYSTEM ISOLATION	
a. RCIC Steam Line Δ Pressure - High	<10(a)###
b. RCIC Steam Supply Pressure - Low	<10(a)
c. RCIC Turbine Exhaust Diaphragm Pressure - High	NA
d. RCIC Equipment Room Temperature - High	NA
e. RCIC Equipment Room Δ Temperature - High	NA
f. RCIC Pipe Routing Area Temperature - High	NA
g. RCIC Pipe Routing Area Δ Temperature - High	NA
h. RCIC Emergency Area Cooler Temperature - High	NA
i. Manual Initiation	NA


TABLE 4.3.2.1-1 (Continued)
ISOLATION ACTUATION INSTRUMENTATION SURVEILLANCE REQUIREMENTS

<u>TRIP FUNCTION</u>	<u>CHANNEL CHECK</u>	<u>CHANNEL FUNCTIONAL TEST</u>	<u>CHANNEL CALIBRATION</u>	<u>OPERATIONAL CONDITIONS FOR WHICH SURVEILLANCE REQUIRED</u>
3. <u>MAIN STEAM LINE ISOLATION</u>				
a. Reactor Vessel Water Level - (Low, Low Low, Level 1)	S	M	R	1, 2, 3
b. Main Steam Line Radiation - High	S	M	R	1, 2, 3
c. Main Steam Line Pressure - Low	NA	M	Q	1
d. Main Steam Line Flow - High	S	M	R	1, 2, 3
e. Condenser Vacuum - Low	NA	M	Q	1, 2**, 3**
f. Main Steam Line Tunnel Temperature - High	NA	M	Q	1, 2, 3
g. Main Steam Line Tunnel Δ Temperature - High	NA	M	Q	1, 2, 3
h. Manual Initiation	NA	R	NA	1, 2, 3
4. <u>REACTOR WATER CLEANUP SYSTEM ISOLATION</u>				
a. RWCS Δ Flow - High	S	M	R	1, 2, 3
b. RWCS Area Temperature - High	NA	M	Q	1, 2, 3
c. RWCS Area Ventilation Δ Temperature - High	NA	M	Q	1, 2, 3
d. SLCS Initiation	NA	R	NA	1, 2, 3
e. Reactor Vessel Water Level - Low Low, Level 2	S	M	R	1, 2, 3
f. RWCS Δ Pressure - High	S	M	R	1, 2, 3
g. Manual Initiation	NA	R	NA	1, 2, 3

TABLE 3.6.3-1

PRIMARY CONTAINMENT ISOLATION VALVES

<u>VALVE FUNCTION AND NUMBER</u>	<u>MAXIMUM ISOLATION TIME (Seconds)</u>	<u>ISOLATION SIGNAL(s)^(a)</u>
<u>a. Automatic Isolation Valves^(b)</u>		
<u>MSIV</u>		
HV-141F022 A,B,C,D	5	 C,D,E,P,UA C,D,E,P,UA
HV-141F028 A,B,C,D	5	
<u>MSL Drain</u>		
HV-141F016	10	 C,D,E,P,UA C,D,E,P,UA
HV-141F019	10	
<u>RCIC Steam Supply</u>		
HV-149F007 ^(c)	20	K
HV-149F008 ^(c)	20	K
HV-149F088	3	K
<u>HPCI Steam Supply</u>		
HV-155F002 ^(c)	50	L
HV-155F003 ^(c)	50	L
HV-155F100	3	L
<u>RHR - Shutdown Cooling Suction^(d)</u>		
HV-151F008	52	M,UB
HV-151F009	52	M,UB
<u>RWCU Suction^(e)</u>		
HV-144F001	30	B,J,W
HV-144F004	30	B,J,W
<u>RHR - Reactor Vessel Head Spray</u>		
HV-151F022	30	M,UB,Z
HV-151F023	20	M,UB,Z



Bases Figure B 3/4 3-1
 REACTOR VESSEL WATER LEVEL