

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8412260263 DOC. DATE: 84/12/21 NOTARIZED: YES DOCKET #  
 FACIL: 50-387 Susquehanna Steam Electric Station, Unit 1, Pennsylv 05000387  
 50-388 Susquehanna Steam Electric Station, Unit 2, Pennsylv 05000388  
 AUTH. NAME AUTHOR AFFILIATION  
 CURTIS, N.W. Pennsylvania Power & Light Co.  
 RECIP. NAME RECIPIENT AFFILIATION  
 SCHWENCER, A. Licensing Branch 2

SUBJECT: Application for amends to Licenses NPF-14 & NPF-22. Amends change Tech Specs re diesel generator testing w/one generator out of svc & circuitry & pumps associated w/ out-of-svc generators. Fee paid.

DISTRIBUTION CODE: A001D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 10+10  
 TITLE: OR Submittal: General Distribution

NOTES: 1cy NMSS/FCAF/PM. LPDR 2cys Transcripts. 05000387  
 OL: 07/17/82  
 1cy NMSS/FCAF/PM. LPDR 2cys Transcripts. 05000388  
 OL: 03/23/84

	RECIPIENT ID CODE/NAME		COPIES		RECIPIENT ID CODE/NAME	COPIES	
			LTR	ENCL		LTR	ENCL
	NRR LB2 BC	01	7	7			
INTERNAL:	ACRS	09	6	6	ADM/LFMB	1	0
	ELD/HDS4		1	0	NRR/DE/MTEB	1	1
	NRR/DL DIR		1	1	NRR/DL/ORAB	1	0
	NRR/DSI/METB		1	1	NRR/DSI/RAB	1	1
	<del>RPS FILE</del>	04	1	1	RGN1	1	1
EXTERNAL:	LPDR	03	2	2	NRC PDR	02	1
	NSIC	05	1	1	NTIS		1
NOTES:			3	3			

*W/ check for \$150.00  
 #542008*





**Pennsylvania Power & Light Company**

Two North Ninth Street • Allentown, PA 18101 • 215 / 770-5151

Norman W. Curtis  
Vice President-Engineering & Construction-Nuclear  
215/770-7501

DEC 21 1984

Director of Nuclear Reactor Regulation  
Attention: Mr. A. Schwencer, Chief  
Licensing Branch No. 2  
Division of Licensing  
U.S. Nuclear Regulatory Commission  
Washington, DC 20555

SUSQUEHANNA STEAM ELECTRIC STATION  
PROPOSED AMENDMENT NO. 58 TO NPF-14  
AND PROPOSED AMENDMENT NO. 13 TO NPF-22  
ER 100450 FILE 841-8  
PLA-2346

Docket Nos. 50-387  
50-388

Dear Mr. Schwencer:

The purpose of this letter is to request a one time exemption to Technical Specifications 3.8.1.1 and 3.7.1.2 to allow Pennsylvania Power & Light Co. to remove the diesel generators one at a time from service for an accumulated time of 60 days. This exception is required in order to perform work on the connection of the control and power circuits to the new fifth diesel at Susquehanna SES. Attachment A shows the proposed wording for this exemption.

The following is a description of the proposed changes to Technical Specification 3.8.1.1:

o ACTION a

1. The reference to the loss and restoration of one offsite circuit has been deleted since in order to be in the proposed action it is assumed that one diesel generator is already out of service and therefore a loss of one offsite circuit would be covered in ACTION b.
2. The testing requirements for the remaining diesel generators have been modified to allow the diesel generators to first be tested within 24 hours and then every 72 hours. The increased testing time between tests provides assurance that the diesel generators will be OPERABLE without degrading the performance of the diesels, since this time is equivalent to the testing requirements for diesels with 4 or more failures per last 100 valid tests. This testing frequency is consistent with the testing frequency as stated in Generic Letter 84-15.

*A001 w/ check 00  
1/1 \$150  
#542008*

8412260263 841221  
PDR ADDCK 05000387  
P PDR

The following information was obtained from the records of the  
 Department of the Interior, Bureau of Land Management, on the  
 subject of the above-captioned land. The land is situated in  
 the County of [County Name], State of [State Name]. The land  
 is described as follows: [Description of land, including acreage,  
 location, and any other relevant details]. The land is owned  
 by [Owner Name], who is the [Relationship] of [Parent Name].  
 The land was acquired by [Owner Name] on [Date]. The land is  
 currently being used for [Use of land]. The land is subject to  
 the following conditions: [List of conditions]. The land is  
 being offered for sale at a price of [Price]. The land is  
 being offered for sale on the following terms: [List of terms].  
 The land is being offered for sale by [Seller Name], who is the  
 authorized agent of the [Owner Name]. The land is being offered  
 for sale to the highest bidder. The land is being offered for  
 sale on the following date: [Date]. The land is being offered  
 for sale at the following location: [Location]. The land is being  
 offered for sale at the following time: [Time]. The land is being  
 offered for sale at the following price: [Price]. The land is  
 being offered for sale on the following terms: [List of terms].  
 The land is being offered for sale by [Seller Name], who is the  
 authorized agent of the [Owner Name]. The land is being offered  
 for sale to the highest bidder. The land is being offered for  
 sale on the following date: [Date]. The land is being offered  
 for sale at the following location: [Location]. The land is being  
 offered for sale at the following time: [Time]. The land is being  
 offered for sale at the following price: [Price]. The land is  
 being offered for sale on the following terms: [List of terms].

DEC 21 1984

Page 2

SSES PLA-2346  
ER 100450 File 841-8  
Mr. A. Schwencer

3. The time one diesel generator can be out of service was revised to an accumulated 60 days for all four diesel generators. This accumulated 60 days is only used for the diesel generators when they are taken out of service in order to do the necessary interconnections associated with the new fifth diesel generator project.
  4. The exemption to the requirements of Specification 3.0.4 has been added to allow restart of the units if they should happen to have to shutdown.
- o ACTION b
1. The testing requirements for the remaining diesel generators have been modified to allow the diesel generators to first be tested within 24 hours and then every 72 hours. Testing on a frequency of 72 hours is consistent with the maximum testing frequency required for diesels with 4 or more failures per last 100 valid tests.
  2. This action has been rewritten to clarify that when the two offsite circuits have been restored, a diesel generator may remain out of service provided it is out of service for work connected with fifth diesel project.
- o ACTION c
1. The words "except as noted in Specification 3.7.1.2" have been added to alert the operators that the ESW pump associated with the inoperable diesel generator will not automatically start upon demand.
- o ACTION d
1. This action statement has been revised to allow only three diesel generators to be OPERABLE instead of four.
  2. The time to restore both offsite circuits has been revised to be consistent with proposed ACTION b.
  3. This action has been rewritten to clarify that when the two offsite circuits have been restore, a diesel generator may remain inoperable provided it is inoperable for work connected with fifth diesel project.
- o ACTION e
1. This action has been rewritten to clarify that when the three diesel generators have been restored, a diesel generator may remain inoperable provided it is inoperable for work connected with fifth diesel project.



[The text in this section is extremely faint and illegible. It appears to be a multi-paragraph document with several lines of text per paragraph. Some characters are barely visible, but no words or sentences can be accurately transcribed.]

Technical Specification 3.7.1.2, ACTION a.1 has been revised to clarify that an ESW pump may remain inoperable until its associated diesel generator is restored to OPERABILITY.

This proposed extension to the Limiting Condition of Operation (LCO) is justified because of the following reasons:

- (1) The design of our offsite AC circuits as described in Section 8.2 of the Final Safety Analysis Report.
- (2) The results of our probabilistic evaluation on extending the diesel generator LCO.

Current Technical Specifications allow continued dual unit operation for up to three days with a diesel generator inoperable. The associated action statement requires demonstration of operability of the remaining diesel generators and the offsite AC sources. This assures the capability of affecting a safe shutdown and mitigating the effects of a design basis accident. This is maintained with (1) the onsite AC power system (3 diesel generators) or (2) the two offsite AC power sources.

Since the electrical AC power sources are degraded below the Technical Specification LCO, a time limit on continued operation is specified. This limits the exposure time in the degraded condition which in turn minimizes the risk associated with this level of degradation. The LCO in the case of one diesel generator is not too severe due to the redundancy of AC power sources which remain.

We have probabilistically evaluated the impact of temporarily extending the diesel generator Limiting Condition of Operation (LCO) from 3 days per diesel to 60 days total for all four diesels one at a time. It is estimated that as many as 15 days per diesel could be required to complete the tie-in. Thus without this temporary extension a dual unit shutdown is required. A recent draft report prepared by Battelle Columbus Laboratories for NRC entitled, "Determination of Allowed Outage Times (AOTs) from a Risk and Reliability Standpoint" (July 1984) states that AOT extensions are only justifiable if there is insufficient time to perform a task and there is no significant increase in total risk. The results of our analysis (discussed later) show no significant risk increase.

Several tasks were performed to examine the impact this extension has on the unavailability of system required to insure adequate core cooling (the assumed indicator of risk). These steps are outlined below:

1. identify loss of offsite power (LOOP) sequences which when coupled with a diesel in an LCO would result in inadequate core cooling,
2. estimate the LOOP frequency and the safety function unavailabilities,



[The text in this section is extremely faint and illegible due to low contrast and scan quality. It appears to be a multi-paragraph document.]



3. estimate the frequency of inadequate core cooling with and without the temporary technical specification change.

Sequences leading to inadequate core cooling are identified using the event tree illustrated in Figure 1. The LOOP frequency and system unavailabilities associated with the event tree heading are derived from data available in open literature. The LOOP frequency and system unavailabilities were combined using the event tree logic to obtain the yearly frequency of inadequate core cooling. This yearly frequency was calculated for two conditions: with all four diesel generators in standby, and with three in standby and one in a LCO. The frequency of inadequate core cooling (per year) is then calculated by summing these frequencies weighted by the yearly fraction of time in each condition. The equation for the frequency of inadequate core cooling is as follows:

$$\text{Frequency of Inadequate Core Cooling} = \frac{365.25 - \text{days in LCO}}{365.25} F_2 + \frac{\text{days in LCO}}{365.25} F_3$$

$F_2$  = The frequency of inadequate core cooling with all diesels in standby.

$F_3$  = The frequency of inadequate core cooling with either diesel A or B in an LCO.

For the LOOP frequency and system unavailabilities associated with the event tree headings, the following references were used:

- o Loss of Offsite Power at U.S. Nuclear Power Plant - All Years Through 1983, NSAC-80, July 1984, H. Wychaft
- o Precursors to Potential Severe Core Damage Accidents: 1980-1981, A Status Report, W. B. Cottrell, etal. ONRL/NSIC-217/V1 & 217/V2.
- o Precursors to Potential Severe Core Damage Accidents: 1969-1979, A Status Report, J. W. Minerick, C. A. Kukielka, ORNL/NSIC-182/V1 and 182/V2.
- o Reactor Safety Study, Wash-1400, Appendix II, 1975.
- o NSAC HPCI/RCIC failure data.

The increased risk associated with continued operation of both units with a diesel generator inoperable for 3 days is acceptable. Arguments supporting this statement are found in the applicable Technical Specification Bases section and Regulatory Guide 1.93. In this evaluation risk is defined as the probability of inadequate core cooling during a LOOP. The proposed temporary change in the diesel generator LCO increases the frequency of LOOP sequences leading to inadequate core cooling from  $5.0 \times 10^{-6}$ /yr. to no more than  $6.4 \times 10^{-6}$ /yr. This represents a minimal impact when considering the uncertainties in the data.



[The text in this section is extremely faint and illegible due to low contrast and noise. It appears to be a multi-paragraph document.]

DEC 21 1984

Page 5

SSES PLA-2346  
ER 100450 File 841-8  
Mr. A. Schwencer

The temporary LCO extension has no impact on the probability of inadequate core cooling when offsite power is available. The design of the onsite AC power supplies is such that only three diesel generators are required to fulfill the electric power requirements for the ECCS equipment assuming a loss of offsite power, a LOCA in one unit and the shutdown of the other unit. As was shown in the evaluation the increased frequency of inadequate core cooling during the LCO extension is small and therefore the one time LCO extension is acceptable.

In order to assure thoroughness and incorporation of recent ideas on Technical Specification changes, the draft Program Plan for Procedure Evaluating Technical Specifications (prepared for NRC by Brookhaven National Laboratory, October 1984) was reviewed. This report identifies 23 issues which should be addressed in the evaluation of Allowed Outage Times (AOTs). Many of these were determined to be irrelevant to this request. However the following are relevant: analysis level (e.g. system, function, core-damage, etc.), risk importance of the diesel generators, common cause failure, uncertainty, operating accident risk, the length of repair time, and system reconfiguration. Common cause failures, uncertainties, operating accident risk, and system reconfiguration were explicitly addressed in the probabilistic analysis. The length of repair was previously mentioned as the reason for the one-time extension request. The remaining issues are discussed below.

The impact of the extended AOT on operating accident risk was evaluated with respect to inadequate core cooling (as a measure of core damage). This level of analysis was selected since it did not require reference to a full plant probabilistic risk assessment (PRA) and is a level at which the results can be viewed with a meaningful perspective. The availability of diesel generators only affects accident sequences which include a loss of offsite power (LOOP). These are typically low contributors to core damage frequency and public risk as illustrated through the risk achievement worth. Findings of the NRC Accident Sequence Precursor Program show the risk achievement worth is only  $9.8 \times 10^{-6}$  for emergency power as compared to  $3.5 \times 10^{-1}$  for long term core cooling. This means the diesel generators would have a relatively low risk importance. The results of our analysis show a negligible increase in the frequency of LOOP sequences which can lead to inadequate core cooling. Therefore, the overall impact on operating accident risk during the AOT is negligible. This negligible increase should be more than offset by the additional capability of the extra diesel generator over the plant lifetime. This diesel is expected to significantly reduce the number of shutdowns and startups of one unit primarily due to the performance of required maintenance (which takes more than three days) during refueling of the other units.

While a diesel generator is removed from service for the modifications, it will not be able to respond to automatic or manual start signals. Therefore, there is no need to consider failures induced during the AOT. The analysis was performed with the assumption that the modifications would be completed in a manner that would not induce a common cause failure of other diesel generators or equipment. A review of the modifications and installation

Very faint header text, possibly including a date or reference number.

First paragraph of faint text, starting with a capital letter.

Second paragraph of faint text, continuing the narrative or report.

Third paragraph of faint text, providing further details.

Fourth paragraph of faint text, concluding the page's content.

DEC 21 1984

Page 6

SSES PLA-2346  
ER 100450 File 841-8  
Mr. A. Schwencer

details will insure that a common cause failure will not be induced during the modification work.

The proposed change does not:

- (1) involve a significant increase in the probability or consequences of an accident previously evaluated,
- (2) create the possibility of a new or different kind of accident from any accident previously evaluated, or
- (3) involve a significant reduction in a margin of safety.

The determination is based on the probabilistic evaluation, as described above, and therefore is an example as provided in 48FR14780, Column 3, paragraph (vi).

Pursuant to 10CFR170.22, the appropriate fee is enclosed.

We would request that this one time Technical Specification change be made effective on July 1, 1985.

Very truly yours,



N. W. Curtis  
Vice President-Engineering & Construction-Nuclear

Enclosures

cc: M. J. Campagnone USNRC  
R. H. Jacobs USNRC

T. M. Gerusky, Director  
Bureau of Radiation Protection  
Pennsylvania Dept. of Environmental Resources  
P. O. Box 2063  
Harrisburg, PA 17120

1950  
1951  
1952

1953  
1954  
1955

1956  
1957  
1958

1959  
1960  
1961

1962  
1963  
1964

1965  
1966  
1967

1968  
1969  
1970

1971  
1972  
1973

1974  
1975  
1976

1977  
1978  
1979

1980  
1981  
1982

1983  
1984  
1985

1986  
1987  
1988

BEFORE THE  
UNITED STATES NUCLEAR REGULATORY COMMISSION

---

In the Matter of :  
PENNSYLVANIA POWER & : Docket No. 50-387  
LIGHT COMPANY

---


PROPOSED AMENDMENT NO. 58  
FACILITY OPERATING LICENSE NO. NPF-14  
SUSQUEHANNA STEAM ELECTRIC STATION  
UNIT NO. 1

---

Licensee, Pennsylvania Power & Light Company, hereby files proposed Amendment No. 58 to its Facility Operating License No. NPF-14 dated July 17, 1982.

This amendment contains a revision to the Susquehanna SES Unit 1 Technical Specifications.

PENNSYLVANIA POWER & LIGHT COMPANY  
BY:



N. W. Curtis  
Vice President - Engineering &  
Construction - Nuclear

Sworn to and subscribed before me  
this 20<sup>th</sup> of November, 1984.

  
Notary Public

MARTHA C. BARTO, Notary Public  
Allentown, Lehigh County, Pa.  
My Commission Expires Jan. 13, 1986

THE UNIVERSITY OF CHICAGO  
DIVISION OF THE PHYSICAL SCIENCES  
DEPARTMENT OF CHEMISTRY

REPORT OF THE COMMITTEE ON THE  
PROGRESS OF THE WORK OF THE  
DEPARTMENT OF CHEMISTRY

FOR THE YEAR 1954-1955  
CHICAGO, ILLINOIS  
1955

CHICAGO, ILLINOIS  
1955

CHICAGO, ILLINOIS

CHICAGO, ILLINOIS





BEFORE THE  
UNITED STATES NUCLEAR REGULATORY COMMISSION

---

In the Matter of :  
PENNSYLVANIA POWER & : Docket No. 50-388  
LIGHT COMPANY :

---


PROPOSED AMENDMENT NO. 13  
FACILITY OPERATING LICENSE NO. NPF-22  
SUSQUEHANNA STEAM ELECTRIC STATION  
UNIT NO. 2

---


Licensee, Pennsylvania Power & Light Company, hereby files proposed Amendment No. 13 to its Facility Operating License No. NPF-22 dated March 23, 1984.

This amendment contains a revision to the Susquehanna SES Unit 2 Technical Specifications.

PENNSYLVANIA POWER & LIGHT COMPANY  
BY:

  
\_\_\_\_\_  
N. W. Curtis  
Vice President - Engineering &  
Construction - Nuclear

Sworn to and subscribed before me  
this 20<sup>th</sup> of December, 1984.

  
\_\_\_\_\_  
Notary Public  
MARTHA C. BARTO, Notary Public  
Allentown, Lehigh County, Pa.  
My Commission Expires Jan. 13, 1986



THE UNIVERSITY OF CHICAGO

PHYSICS DEPARTMENT

530 SOUTH EAST ASIAN AVENUE

CHICAGO, ILLINOIS 60607

TEL: 773-936-3700

FAX: 773-936-3700

WWW.PHYSICS.UCHICAGO.EDU

PHYSICS 309: QUANTUM MECHANICS

LECTURE 1: THE SCHRÖDINGER EQUATION


PROFESSOR JOHN W. NEGELE

WINTER 2004

LECTURE 1



LOOP $f_1$	ESS buses Energized $P_1$	High Pressure Makeup $P_2$	Low Pressure Makeup $P_3$	Long Term Heat Removal $P_4$
---------------	------------------------------------	-------------------------------------	------------------------------------	------------------------------------



Adequate Core Cooling	Yearly Frequency of Inadequate Core Cooling	
	Normal $f_2$	LCO $f_3$
yes	-	-
no	$3.9 \times 10^{-6}$	$3.7 \times 10^{-6}$
yes	-	-
no	$8.6 \times 10^{-9}$	$8.2 \times 10^{-9}$
no	$4.4 \times 10^{-9}$	$4.4 \times 10^{-9}$
yes	-	-
no	$3.6 \times 10^{-7}$	$4.7 \times 10^{-6}$
no	$4.8 \times 10^{-7}$	$6 \times 10^{-6}$
Total	$4.8 \times 10^{-6}/\text{year}$	$1.5 \times 10^{-5}/\text{year}$

Figure 1: Event Tree for Loss of Offsite Power at SSES

EVENT TREE LEGEND

<u>Symbol</u>	<u>Definition</u>
$F_1$	Yearly frequency of a Loss Of Offsite Power
$P_1$	Probability that ESS buses 1A201 and 1A202 are not energized
$P_2$	Probability that high pressure makeup fails
$P_3$	Probability that low pressure makeup fails
$P_4$	Probability that long term heat removal is unavailable
$f_2$	Yearly frequency of inadequate core cooling with all buses not energized
$f_3$	Yearly frequency of inadequate core cooling with one bus in LCO