

Docket Nos. 50-387
50-388

JAN 10 1985

License Nos. NPF-14
NPF-22

Pennsylvania Power & Light Company
ATTN: Mr. Bruce D. Kenyon
Vice President
Nuclear Operations
2 North Ninth Street
Allentown, Pennsylvania 18101

IE FILE COPY

Gentlemen:

Subject: Enforcement Conference for Inspection 50-387/84-35

This letter refers to the enforcement conference held on November 30, 1984, in the Region I office to discuss the findings of Susquehanna Special Inspection 50-387/84-35, related to the control rod array which exceeded a scram insertion time Technical Specification limit during a Unit 1 trip on June 13, 1984.

At this meeting, we also discussed the status of your actions associated with Confirmatory Action Letter 84-18, addressing problems with T-ASCO scram pilot solenoid valves, the results of which were outlined in your letters to Region I dated November 19, 1984.

Conference details are described in the report enclosed with this letter. Also enclosed is a copy of your presentation which was distributed at this meeting. Based on our discussions at this meeting, and the results of your evaluation of the failure mechanism of the scram pilot solenoids, we feel that the increased frequency of rod surveillance testing should be continued as committed to in CAL 84-18 and your November 19, 1984 letter, until your final evaluation and a written application for relief to the NRC have been completed.

You will be notified of our evaluation of appropriate enforcement action by separate letter. Your cooperation with us in this matter is appreciated.

Sincerely,

Original Signed By:

Richard W. Starostecki, Director
Division of Project and Resident
Programs

Enclosures:

1. Enforcement Conference Report
2. PP&L Presentation

OFFICIAL RECORD COPY

ENFCONFSUSQ12/10/84 - 0001.0.0
12/13/84

8501240465 850110
PDR ADDCK 05000387
Q PDR

#10
IE01

12

12

12

cc w/encls:

Norman W. Curtis, Vice President, Engineering and Construction - Nuclear
A. R. Sabol, Manager, Nuclear Quality Assurance
W. E. Barberich, Licensing Engineer
H. W. Keiser, Superintendent of Plant
William Matson
Public Document Room (PDR)
Local Public Document Room (LPDR)
Nuclear Safety Information Center (NSIC)
NRC Resident Inspector
Commonwealth of Pennsylvania

bcc w/encls:

Region I Docket Room (with concurrences)
Senior Operations Officer (w/o encls)
T. Murley
D. Holody
T. Martin
J. Durr
M. Campognone, NRR
J. T. Beard, NRR
G. Holahan, NRR

RI:DPRP
Strosnider/gcb
12/20/84
1/3/85

RI:DPRP
Kister
1/9/85

RI:DPRP
Starostecki
1/10/85

OFFICIAL RECORD COPY

ENFCONFSUSQ12/10/84 - 0002.0.0
01/03/85