

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8502050565 DOC. DATE: 85/02/01 NOTARIZED: NO DOCKET #  
 FACIL: 50-387 Susquehanna Steam Electric Station, Unit 1, Pennsylv 05000387  
 50-388 Susquehanna Steam Electric Station, Unit 2, Pennsylv 05000388  
 AUTH. NAME: CURTIS, N.W. AUTHOR AFFILIATION: Pennsylvania Power & Light Co.  
 RECIP. NAME: SCHWENCER, A. RECIPIENT AFFILIATION: Licensing Branch 2

SUBJECT: Responds to plant-specific concerns re NRC position on NUREG-0803. Leak rates, loading conditions & matl properties for SDV piping sys bounded by limiting values identified by BWR Owners Group.

DISTRIBUTION CODE: A0010 COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 3  
 TITLE: OR Submittal: General Distribution

NOTES: 1cy NMSS/FCAF/PM. LPDR 2cys Transcripts. 05000387  
 OL: 07/17/82  
 1cy NMSS/FCAF/PM. LPDR 2cys Transcripts. 05000388  
 OL: 03/23/84

	RECIPIENT ID CODE/NAME	COPIES LTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTR ENCL
	NRR LB2 BC 01	7		
INTERNAL:	ACRS 09	6	ADM/LFMB	1
	ELD/HDS4	1	NRR/DE/MTEB	1
	NRR/DL DIR	1	NRR/DL/ORAB	1
	NRR/DL/TSRG	1	NRR/DSI/METB	1
	NRR/DSI/RAB	1	REG FILE 04	1
	RGN1	1		
EXTERNAL:	LPDR 03	2	NRC PDR 02	1
	NSIC 05	1		
NOTES:		3		

TOTAL NUMBER OF COPIES REQUIRED: LTR 30 ENCL 9





**Pennsylvania Power & Light Company**

Two North Ninth Street • Allentown, PA 18101 • 215 / 770-5151

Norman W. Curtis  
Vice President-Engineering & Construction-Nuclear  
215/770-7501

FEB 1 1985

Director of Nuclear Reactor Regulation  
Attention: Mr. A. Schwencer, Chief  
Licensing Branch No. 2  
Division of Licensing  
U.S. Nuclear Regulatory Commission  
Washington, DC 20555

SUSQUEHANNA STEAM ELECTRIC STATION  
NUREG 0803  
ER 100450/100508                      FILE 206  
PLA-2402

Docket Nos. 50-387  
50-388

Dear Mr. Schwencer:

The purpose of this letter is to respond to plant specific concerns for Susquehanna SES as they relate to the NRC's position on NUREG-0803.

Concern No. 1

PP&L is requested to provide written verification that the leak rates, loading conditions and material properties for the SDV piping systems at Susquehanna Units 1 and 2 are bounded by the limiting values for these parameters identified by the BWROG.

Response

The leak rates, loading conditions and material properties for the SDV piping systems at Susquehanna Units 1 and 2 are bounded by the limiting values for these properties identified by the BWROG.

Concern No. 2

PP&L is requested to provide written verification that the Susquehanna Units 1 and 2 comply with the BWROG recommendations for leak detection capability.

Response

The following has been stated in our letter, PLA-2253 dated July 20, 1984:

"The following provides Pennsylvania Power & Light Company's formal endorsement of the BWR Owner's Group Letter to the NRC, number BWROG-8420, entitled "Transmittal of Additional Information on Scram Discharge Pipe Breaks Requested by NRC Staff at February 23, 1984 Meeting with BWR Owners' Group

8502050565 850201  
PDR ADDCK 05000387  
PDR

Accl  
/10

Faint, illegible text at the top of the page, possibly a header or introductory paragraph.

Section of text, possibly a list or a specific paragraph, located in the upper right quadrant.

Section of text on the left side of the page, possibly a sub-header or a specific point.

Section of text in the middle right area, possibly a continuation of a list or paragraph.

Section of text in the lower middle area, possibly a paragraph or a list item.

Section of text on the right side, possibly a sub-section or a specific note.

Section of text in the lower left area, possibly a paragraph or a list item.

Section of text in the lower middle area, possibly a paragraph or a list item.

Section of text on the right side, possibly a sub-section or a specific note.

Section of text in the lower middle area, possibly a paragraph or a list item.

Section of text in the lower middle area, possibly a paragraph or a list item.

Section of text at the bottom of the page, possibly a concluding paragraph or a list item.

FEB 1 1985

Page 2

SSES PLA-2402  
ER 100450 File 206  
Mr. A. Schwencer

(BWROG)." As part of the endorsement of the BWROG position, the participating utilities are required to implement a generic program to perform a visual observation of the SDV piping to check for leaks at least once per refueling cycle. It was indicated to the BWROG, by the NRC staff, that if the utilities implemented this program it would not be necessary to satisfy the equipment qualification requirements of NUREG-0803.

PP&L presently performs a walkdown of the SDV in the post-scrum condition on an 18-month frequency, as required by FSAR Section 18.1.69 (Integrity of Systems Outside Containment Likely to Contain Radioactive Material) and Technical Specification 6.8.4a (Primary Coolant Sources Outside Containment). This walkdown is of sufficient detail to detect appreciable leakage and it is our position that it meets intent of the program proposed by the NRC staff and the BWROG.

Based on the BWROG response with regard to leakage from the SDV and the above program for detection of such leakage, PP&L continues to maintain that equipment qualification for NUREG-0803 is not required."

Concern No. 3

PP&L is requested to provide written verification that Susquehanna Units 1 and 2 comply with the applicable generic secondary containment EPGs.

Response

At the present time, PP&L is in the process of revising our emergency operating procedures (EOPs) to reflect Revision 3 to the BWROG EPGs. Our existing EOPs are based upon an earlier revision of the BWROG EPGs.

Concern No. 4

PP&L is requested to provide written verification that the expected radiation fields and contact exposure levels at the SDV piping systems in Susquehanna Units 1 and 2 will not impair the performance of routine tests, inspections and post-scrum reset walkdowns.

Response

The following has been stated in our letter, PLA-2010 dated January 27, 1984:

"The following provides Pennsylvania Power & Light Company's formal endorsement of the BWR Owner's Group "Response to NRC Request for Additional Information on Scrum Discharge Piping." As noted in the BWR Owner's Group cover letter, the participating utilities are required to provide a discussion regarding the expected radiation field and contact exposure level at the scrum system piping as it may affect routine tests and inspection.

Based on the limited operating experience which Susquehanna Unit 1 has to date, PP&L expects to see the following average dose levels for the SDV over the life of the plant:

1954  
1955  
1956  
1957  
1958  
1959  
1960  
1961  
1962  
1963  
1964  
1965  
1966  
1967  
1968  
1969  
1970  
1971  
1972  
1973  
1974  
1975  
1976  
1977  
1978  
1979  
1980  
1981  
1982  
1983  
1984  
1985  
1986  
1987  
1988  
1989  
1990  
1991  
1992  
1993  
1994  
1995  
1996  
1997  
1998  
1999  
2000  
2001  
2002  
2003  
2004  
2005  
2006  
2007  
2008  
2009  
2010  
2011  
2012  
2013  
2014  
2015  
2016  
2017  
2018  
2019  
2020  
2021  
2022  
2023  
2024  
2025

FEB 1 1985

Page 3

SSES PLA-2402  
ER 100450 File 206  
Mr. A. Schwencer

- Average contact dose: 50-80 MR/HR
- Maximum contact dose: 300 MR/HR
- Average radiation field: 5 MR/HR"

Since Susquehanna SES Unit 1 and Unit 2 meet the Staff's position on equipment qualification as it relates to NUREG-0803, PP&L does not have to perform equipment qualification pursuant to Section 5.3 of NUREG-0803. Therefore License Condition 2.C.(18)(e) of Operating License NPF-14 has been met and should be closed.

If you have any questions, please contact us.

Very truly yours,



N. W. Curtis  
Vice President-Engineering & Construction-Nuclear

cc: M. J. Campagnone NRC  
R. H. Jacobs NRC

1. Introduction

2. Methodology

3. Results and Discussion

4. Conclusion

5. References

6. Appendix