

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8502070258 DOC. DATE: 85/01/31 NOTARIZED: YES DOCKET #
 FACIL: 50-387 Susquehanna Steam Electric Station, Unit 1, Pennsylv 05000387
 50-388 Susquehanna Steam Electric Station, Unit 2, Pennsylv 05000388
 AUTH. NAME AUTHOR AFFILIATION
 CURTIS, N.W. Pennsylvania Power & Light Co.
 RECIP. NAME RECIPIENT AFFILIATION
 SCHWENCER, A. Licensing Branch 2

SUBJECT: Forwards application for amends 61 & 15 to Licenses NPF-14 & NPF-22, respectively, changing Tech Specs to support installation of NRC-approved automatic depressurization sys logic mods.

DISTRIBUTION CODE: A001D COPIES RECEIVED: LTR 3 ENCL 39 SIZE: 5+23
 TITLE: OR Submittal: General Distribution

NOTES: 1cy NMSS/FCAF/PM. LPDR 2cys Transcripts. 05000387
 OL: 07/17/82
 1cy NMSS/FCAF/PM. LPDR 2cys Transcripts. 05000388
 OL: 03/23/84

	RECIPIENT ID CODE/NAME		COPIES LTTR ENCL		RECIPIENT ID CODE/NAME		COPIES LTTR ENCL
	NRR LB2 BC	01	7	7			
INTERNAL:	ACRS	09	6	6	ADM/LFMB		1 0
	ELD/HDS4		1	0	NRR/DE/MTEB		1 1
	NRR/DL DIR		1	1	NRR/DL/ORAB		1 0
	NRR/DL/TSRG		1	1	NRR/DSI/METB		1 1
	NRR/DSI/RAB		1	1	<u>REG FILE</u>	04	1 1
	RGN1		1	1			
EXTERNAL:	LPDR	03	2	2	NRC PDR	02	1 1
	NSIC	05	1	1			
NOTES:			3	3			

Rec'd w/ check \$150.00

THE UNIVERSITY OF CHICAGO
DEPARTMENT OF CHEMISTRY
530 SOUTH EAST ASIAN AVENUE
CHICAGO, ILLINOIS 60607
TEL: 773-936-3700
FAX: 773-936-3701
WWW: WWW.CHEM.UCHICAGO.EDU

NAME	ADDRESS	CITY	STATE	ZIP
ALBERT A. FREUD	1000 N. LAUREL AVE	CHICAGO	ILL	60642
ALBERT A. FREUD	1000 N. LAUREL AVE	CHICAGO	ILL	60642
ALBERT A. FREUD	1000 N. LAUREL AVE	CHICAGO	ILL	60642
ALBERT A. FREUD	1000 N. LAUREL AVE	CHICAGO	ILL	60642
ALBERT A. FREUD	1000 N. LAUREL AVE	CHICAGO	ILL	60642
ALBERT A. FREUD	1000 N. LAUREL AVE	CHICAGO	ILL	60642
ALBERT A. FREUD	1000 N. LAUREL AVE	CHICAGO	ILL	60642
ALBERT A. FREUD	1000 N. LAUREL AVE	CHICAGO	ILL	60642
ALBERT A. FREUD	1000 N. LAUREL AVE	CHICAGO	ILL	60642
ALBERT A. FREUD	1000 N. LAUREL AVE	CHICAGO	ILL	60642

ALBERT A. FREUD
1000 N. LAUREL AVE
CHICAGO, ILLINOIS 60642
TEL: 773-936-3700
FAX: 773-936-3701
WWW: WWW.CHEM.UCHICAGO.EDU



Pennsylvania Power & Light Company

Two North Ninth Street • Allentown, PA 18101 • 215 / 770-5151

Norman W. Curtis
Vice President-Engineering & Construction-Nuclear
215/770-7501

JAN 31 1985

Director of Nuclear Reactor Regulation
Attention: Mr. A. Schwencer, Chief
Licensing Branch No. 2
Division of Licensing
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

SUSQUEHANNA STEAM ELECTRIC STATION
PROPOSED AMENDMENTS 61 to NPF-14 AND
15 TO NPF-22
ER 100450 FILE 841-8
PLA-2401

Docket Nos. 50-387
50-388

Dear Mr. Schwencer:

The purpose of this letter is to propose changes to the Susquehanna SES Unit 1 and Unit 2 Technical Specifications in order to support the installation of NRC-Approved ADS logic modifications. Our review of the affected specifications indicated the need for several other changes as well, and these are explained in detail below.

Proposed Technical Specification Changes: A mark-up of the changes needed to support this proposal is attached. In the justification below, each page listed covers both the Unit 1 and Unit 2 specifications.

- o page 3/4 3-28: The circled changes (Unit 1 only) are from previously proposed Amendment 43. They are provided for information only. The only change on this page removes footnote (a) from applying to every entry. Footnote (a) states:

"A channel may be placed in an inoperable status for up to 2 hours for required surveillance without placing the trip system in the tripped condition provided at least one OPERABLE channel in the same trip system is monitoring that parameter."


This footnote no longer applies to the manual initiation functions for each ECCS System, since there is only one manual initiation channel per trip system. The manual initiation function is tested once per 18 months and can be done without rendering a required system inoperable, so the footnote is not necessary.

This footnote has also been removed from the Level 8 HPCI trip, since placing a channel in an inoperable status in this two-out-of-two series logic would render HPCI unavailable.

8502070258 850131
PDR ADDCK 05000387
P PDR

Rec'd w/checked 1/30/85

A001
3/39



JAN 31 1985

Page 2

SSES PLA-2401
ER 100450 File 841-8
Mr. A. Schwencer

With respect to the following, see FSAR Figure 7.3-5 sheet 3, attached.

- o page 3/4 3-29: The addition of the ADS Drywell Pressure Bypass Timer and Manual Inhibit Switch in the Unit 1 Specification and the Manual Inhibit Switch alone in the Unit 2 Specification (the Timer is already included) is being performed consistent with our commitments to the NRC on NUREG-0737 Item II.K.3.18 and the related license conditions (Unit 1: 2.C(28)(e); Unit 2: 2.C.(12)(f)).

In the Minimum Operable Channels Per Trip System column, footnote (a) has been replaced with footnote (f). This is because under (a) surveillances could not be performed without entering an LCO, since another OPERABLE channel in the same trip system was not available. Unlike the other ECCS, however, either ADS trip system alone can actuate ADS. Therefore the same level of availability can be achieved by requiring that the redundant trip system in the other division be OPERABLE.

Footnotes (d) and (e) have been provided to take advantage of inherent conservatisms due to redundant logics which accomplish the same objective. Footnote (e) allows that only one of the available RHR "pumps running" permissives will fulfill the OPERABILITY requirements of Trip Function 4d, since either one (A or C in Div. I; B or D in Div. II) will complete that logic segment. Similarly, footnote (d) allows that either Trip Function 4d or 4e must be satisfied, since the logic is in parallel and either will support ADS trip system availability. Footnote (d) also requires the pump permissives being used to meet the new minimum requirement to be associated with OPERABLE pumps; this ensures that ADS availability is not compromised.

ACTION 37 has been provided to replace ACTIONS 30 and 31 as they apply to ADS trip functions. Both of the former ACTIONS resulted in declaring the associated ECCS inoperable. This results in an overly restrictive shutdown ACTION when a perfectly functioning ADS trip system still exists. In order to alleviate this problem, ACTION 37 was developed to parallel the existing ADS valve inoperability requirements of 3.5.1.d:

"3.5.1.d. For the ADS:

1. With one of the above required ADS valves inoperable, provided the HPCI system, the CSS and LPCI system are OPERABLE, restore the inoperable ADS valve to OPERABLE status within 14 days or be in at least HOT SHUTDOWN within the next 12 hours and reduce reactor steam dome pressure to ≤ 100 psig within the next 24 hours."

The first part of the document discusses the importance of maintaining accurate records of all transactions. It emphasizes that every entry should be supported by a valid receipt or invoice. This ensures transparency and allows for easy verification of the data.

In the second section, the author details the various methods used to collect and analyze the data. This includes both manual and automated processes. The goal is to ensure that the information is both reliable and up-to-date.

The third part of the report focuses on the results of the analysis. It shows a clear trend of growth over the period studied. This is supported by several key indicators that have all shown positive movement.

Finally, the document concludes with a series of recommendations for future actions. These are based on the findings of the analysis and are designed to help the organization continue to improve its performance.

JAN 31 1985

Page 3

SSES PLA-2401
ER 100450 File 841-8
Mr. A. Schwencer

2. With two or more of the above required ADS valves inoperable, be in at least HOT SHUTDOWN within 12 hours and reduce reactor steam dome pressure to ≤ 100 psig within the next 24 hours."

Part a of ACTION 37 parallels 3.5.1.d.1 above. In each case, a single failure has occurred which results in decreased reliability but is within the bounds presented in the accident analysis. See FSAR Table 6.3-2, attached. One of the LOCA analysis input parameters is that 5 of the 6 ADS valves are assumed to operate. Since all 6 ADS valves will actuate on a signal from either trip system, losing one channel is bounded by this assumption.

Part b of ACTION 37 was written to parallel 3.5.1.d.2 above. In each case, more valves than have been assumed to fail in the analysis have been affected. Therefore, shutdown is required, as well as getting reactor pressure below the pressure for which ADS is required to be OPERABLE.

Based on the above, ACTION 37 is much less rigorous than the current Technical Specification requirements. However, when assessed based on the ADS requirement in the ECCS analysis in FSAR Section 6.3, the instrumentation ACTIONS were shown to be overly conservative, and the existing ADS system (valve) requirements were used as a model to develop requirements within those previously set by the NRC for the ADS instrumentation.

- o page 3/4 3-32: The setpoints provided are consistent with the NRC approved analysis supporting the required ADS logic modifications. They are consistent with the Susquehanna SES Unit 2 Technical Specifications.
- o page 3/4 3-33: The response time listings are listed (although they present no new requirements) for the sake of providing consistency and complete information.
- o page 3/4 3-35: The surveillance frequencies were chosen consistent with the existing ADS timer and the manual initiation function for the new timer and inhibit switch, respectively.

NO SIGNIFICANT HAZARDS CONSIDERATIONS

The proposed changes do not:

- (1) involve a significant increase in the probability or consequences of an accident previously evaluated,
- (2) Create the possibility of a new or different kind of accident from any accident previously evaluated, or

The first part of the document discusses the importance of maintaining accurate records of all transactions. It emphasizes that every entry should be supported by a valid receipt or invoice. This ensures transparency and allows for easy verification of the data.

In the second section, the author outlines the various methods used to collect and analyze the data. This includes both manual data entry and the use of specialized software tools. The goal is to ensure that the data is both accurate and easy to interpret.

The third part of the document provides a detailed breakdown of the results. It shows that there is a significant correlation between the variables being studied. This finding is supported by statistical analysis and is consistent with previous research in the field.

Finally, the document concludes with a series of recommendations for future research. It suggests that further studies should be conducted to explore the underlying causes of the observed trends. This will help to refine the current model and provide a more comprehensive understanding of the phenomenon.

JAN 31 1985

Page 4

SSES PLA-2401
ER 100450 File 841-8
Mr. A. Schwencer

- (3) involve a significant reduction in a margin of safety.

The basis for this determination is provided below (the examples referenced are examples of amendments not likely to involve significant hazards considerations).

- o page 3/4 3-28: Editorial changes were made to this page affecting the application of footnote (a). For the reasons provided earlier, these changes are examples as provided in 48FR14870, paragraph (i).
- o page 3/4 3-29: As discussed, the addition of instrumentation consistent with the resolution of NUREG-0737 Item II.K.3.18 is required by the Unit 1 and Unit 2 Licenses. This is an example as provided in 48FR14870, paragraph (vii).

The changes to the Minimum Operable Channels per Trip System requirements, although they reduce the margin of safety currently provided in the Technical Specifications, clearly maintain the level of safety required to meet the existing safety analysis. Therefore, these changes are examples as provided in 48FR14870, paragraph (vi).

- o page 3/4 3-32: These setpoints support required modifications. Therefore these changes are examples as provided in 48FR14870, paragraph (vi).
- o page 3/4 3-33: As discussed earlier, these changes are for consistency and clarity. They are therefore examples as provided in 48FR14870, paragraph (i).
- o page 3/4 3-35: These surveillance requirements support required modifications. Therefore these changes are examples as provided in 48FR14870, paragraph (vi).

IMPLEMENTATION SCHEDULE:

- o Unit 1: To support the referenced license condition, please condition your approval to become effective prior to startup following the first refueling outage.
- o Unit 2: For all proposed changes except those applicable to the manual inhibit switch, we request that the change approvals be conditioned to become effective 30 days after approval to allow procedural updates to be developed and approved. For the manual inhibit switch changes, we request that maximum flexibility be provided within the September 1, 1985 timeframe referenced in the license condition. This is because we plan to do the work at the first forced shutdown of sufficient duration after receipt of NRC approval, but no later than September 1, 1985. Therefore we request that your approval be conditioned to become effective upon completion of the modifications and associated performance testing, but no later than September 1, 1985.

JAN 31 1985

Page 5

SSES PLA-2401
ER 100450 File 841-8
Mr. A. Schwencer

Any questions on this proposal should be directed to Mr. R. Sgarro,
(215) 770-7855. Pursuant to 10CFR170.22, the appropriate fee is enclosed.

Very truly yours,



N. W. Curtis
Vice President-Engineering & Construction-Nuclear

Attachment

cc: M. J. Campagnone - USNRC
R. H. Jacobs - USNRC

T. M. Gerusky, Director
Bureau of Radiation Protection
Pa. Dept. of Environmental Resources
P.O. Box 2063
Harrisburg, PA 17120

1944
1945
1946

1947

1948

1949
1950
1951
1952
1953
1954
1955
1956
1957
1958
1959
1960
1961
1962
1963
1964
1965
1966
1967
1968
1969
1970
1971
1972
1973
1974
1975
1976
1977
1978
1979
1980
1981
1982
1983
1984
1985
1986
1987
1988
1989
1990
1991
1992
1993
1994
1995
1996
1997
1998
1999
2000
2001
2002
2003
2004
2005
2006
2007
2008
2009
2010
2011
2012
2013
2014
2015
2016
2017
2018
2019
2020
2021
2022
2023
2024
2025

2026
2027
2028
2029
2030
2031
2032
2033
2034
2035
2036
2037
2038
2039
2040
2041
2042
2043
2044
2045
2046
2047
2048
2049
2050
2051
2052
2053
2054
2055
2056
2057
2058
2059
2060
2061
2062
2063
2064
2065
2066
2067
2068
2069
2070
2071
2072
2073
2074
2075
2076
2077
2078
2079
2080
2081
2082
2083
2084
2085
2086
2087
2088
2089
2090
2091
2092
2093
2094
2095
2096
2097
2098
2099
2100

2101
2102
2103
2104
2105
2106
2107
2108
2109
2110
2111
2112
2113
2114
2115
2116
2117
2118
2119
2120
2121
2122
2123
2124
2125
2126
2127
2128
2129
2130
2131
2132
2133
2134
2135
2136
2137
2138
2139
2140
2141
2142
2143
2144
2145
2146
2147
2148
2149
2150
2151
2152
2153
2154
2155
2156
2157
2158
2159
2160
2161
2162
2163
2164
2165
2166
2167
2168
2169
2170
2171
2172
2173
2174
2175
2176
2177
2178
2179
2180
2181
2182
2183
2184
2185
2186
2187
2188
2189
2190
2191
2192
2193
2194
2195
2196
2197
2198
2199
2200

2201
2202
2203
2204
2205
2206
2207
2208
2209
2210
2211
2212
2213
2214
2215
2216
2217
2218
2219
2220
2221
2222
2223
2224
2225
2226
2227
2228
2229
2230
2231
2232
2233
2234
2235
2236
2237
2238
2239
2240
2241
2242
2243
2244
2245
2246
2247
2248
2249
2250
2251
2252
2253
2254
2255
2256
2257
2258
2259
2260
2261
2262
2263
2264
2265
2266
2267
2268
2269
2270
2271
2272
2273
2274
2275
2276
2277
2278
2279
2280
2281
2282
2283
2284
2285
2286
2287
2288
2289
2290
2291
2292
2293
2294
2295
2296
2297
2298
2299
2300

2301
2302
2303
2304
2305
2306
2307
2308
2309
2310
2311
2312
2313
2314
2315
2316
2317
2318
2319
2320
2321
2322
2323
2324
2325
2326
2327
2328
2329
2330
2331
2332
2333
2334
2335
2336
2337
2338
2339
2340
2341
2342
2343
2344
2345
2346
2347
2348
2349
2350
2351
2352
2353
2354
2355
2356
2357
2358
2359
2360
2361
2362
2363
2364
2365
2366
2367
2368
2369
2370
2371
2372
2373
2374
2375
2376
2377
2378
2379
2380
2381
2382
2383
2384
2385
2386
2387
2388
2389
2390
2391
2392
2393
2394
2395
2396
2397
2398
2399
2400

2401
2402
2403
2404
2405
2406
2407
2408
2409
2410
2411
2412
2413
2414
2415
2416
2417
2418
2419
2420
2421
2422
2423
2424
2425
2426
2427
2428
2429
2430
2431
2432
2433
2434
2435
2436
2437
2438
2439
2440
2441
2442
2443
2444
2445
2446
2447
2448
2449
2450
2451
2452
2453
2454
2455
2456
2457
2458
2459
2460
2461
2462
2463
2464
2465
2466
2467
2468
2469
2470
2471
2472
2473
2474
2475
2476
2477
2478
2479
2480
2481
2482
2483
2484
2485
2486
2487
2488
2489
2490
2491
2492
2493
2494
2495
2496
2497
2498
2499
2500