



Pennsylvania Power & Light Company

Two North Ninth Street • Allentown, PA 18101 • 215/770-5151

February 15, 1985

Mr. Paul Koval
Chief, Operations Section
Bureau of Water Quality Management
Pennsylvania Department of Environmental Resources
P.O. Box 659
90 East Union Street, Second Floor
Wilkes-Barre, PA 18702

SUSQUEHANNA STEAM ELECTRIC STATION
DISCHARGE MONITORING REPORT CORRECTION
NPDES PERMIT NO. PA 0027448
CCN 741326 FILE 012-4
PLE-6752

Dear Mr. Koval:

As stated in my Discharge Monitoring Report (DMR) transmittal letter of January 25, 1985 (PLE-6646), sample results from the period December 23, 1984 to December 29, 1984 were missing at the time of DMR submittal. This data has since been recovered and used to recalculate data on flow, pH, and residual chlorine presented on the December 1984 DMR.

The minimum and maximum values reported previously for these parameters remained unchanged. However, recalculated monthly averages are as follows:

		<u>Monthly Average</u>	
Flow	Measured:	0.022	MGD
	Limit:	0.045	
pH	Measured:	7.21	Std. Units
	Limit:	NA	
Residual Chlorine	Measured:	0.85	mg/l
	Limit:	NA	

Values for all other parameters reported remain unchanged.

If you have any questions, please contact me at (215) 770-7889.

Respectfully yours,

Jerome S. Fields
Sr. Environmental Scientist-Nuclear

DAS:mp

dasltb002238a

cc: EPA, Region III

(A. Schwencer)

(NRC)

8502270184 850215
PDR ADDCK 05000387
R PDR

LE25
1/0