

JUL 3 0 1985

Docket Nos. 50-387
50-388

Pennsylvania Power & Light Company
ATTN: Mr. H. W. Keiser
Vice President
Nuclear Operations
2 North Ninth Street
Allentown, Pennsylvania 18101

Gentlemen:

Subject: Resident Inspection Reports Nos. 50-387/85-18; 50-388/85-16
(05/06/85-06/23/85)

This routine inspection of the Susquehanna Steam Electric Station covered plant operations, surveillance, maintenance, Unit 1 refueling outage, allegation followup, open items, licensee events and closeout of Unit 1 license conditions. This inspection found that the modifications required by your operating license NPF-14 were completed as required during the Unit 1 first refueling outage. Additionally, review of the overpressurization potential for Emergency Core Cooling Systems found the system design, surveillance and maintenance activities for high/low pressure interface devices adequate.

An allegation was received by Region I in April 1985 concerning drywell average air temperature. Review of the allegation during this inspection found it partially substantiated, but no significant safety concern was identified. Several surveillance procedure deficiencies were noted, however. A series of anonymous allegations has been received recently by Region I which involve items of ongoing discussions between the plant staff and the corporate office. It appears that the safety concerns of certain individuals were not satisfied during these discussions, and prompted them to submit their allegation. This may be indicative of an internal communications problem.

Your cooperation with us is appreciated.

Sincerely,

Original Signed By:

Harry B. Kister, Chief
Projects Branch No. 1
Division of Reactor Projects

Enclosure:
Combined NRC Inspection Report Nos. 50-387/85-18; 50-388/85-16

8508050178 850730
PDR ADOCK 05000387
Q PDR

OFFICIAL RECORD COPY

CIR SUS 85-18/16 - 0001.0.0
07/19/85


IE'd
11

cc w/encl:


Norman W. Curtis, Vice President, Engineering and Construction - Nuclear
A. R. Sabol, Manager, Nuclear Quality Assurance
W. E. Barberich, Licensing Engineer
T. M. Crimmins, Superintendent of Plant
A. J. Pietrofitta, General Manager, Power Production Engineering and Construction
Atlantic Electric
R. J. Benich, Services Project Manager, General Electric Company
William Matson
Public Document Room (PDR)
Local Public Document Room (LPDR)
Nuclear Safety Information Center (NSIC)
NRC Resident Inspector
Commonwealth of Pennsylvania

bcc w/encl:

Region I Docket Room (with concurrences)
Senior Operations Officer (w/o encl)
DRP Section Chief
J. Grant, DRP
E. Kelly, Limerick

 RI:DRS
Strosnider
07/23/85

 RI:DRS
Kister
07/25/85

 RI:DRS
Starostecki
07/17/85

