

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8508050447      DOC. DATE: 85/07/31      NOTARIZED: NO      DOCKET #  
 FACIL: 50-387 Susquehanna Steam Electric Station, Unit 1, Pennsylv      05000387  
 50-388 Susquehanna Steam Electric Station, Unit 2, Pennsylv      05000388  
 AUTH. NAME      AUTHOR AFFILIATION  
 CURTIS, N.W.      Florida Power & Light Co.  
 RECIP. NAME      RECIPIENT AFFILIATION  
 BUTLER, W.R.      Licensing Branch 2

SUBJECT: Responds to request for justification for not including containment radiation monitor in procedure for estimating core damage. Correlation of monitors to amount of core damage impractical. Justification provided.

DISTRIBUTION CODE: A001D      COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 2  
 TITLE: OR Submittal; General Distribution

NOTES: 1cy NMSS/FCAF/PM.      LPDR 2cys Transcripts.      05000387  
 OL: 07/17/82  
 1cy NMSS/FCAF/PM.      LPDR 2cys Transcripts.      05000388  
 OL: 03/23/84

	RECIPIENT ID CODE/NAME:		COPIES LTTR ENCL		RECIPIENT ID CODE/NAME		COPIES LTTR ENCL
	NRR LB2 BC	01	7				
INTERNAL:	ACRS	09	6	6	ADM/LFMB		1
	ELD/HDS4		1	0	NRR/DE/MTEB		1
	NRR/DL DIR		1	1	NRR/DL/ORAB		1
	NRR/DL/TSRG		1	1	NRR/DSI/METB		1
	NRR/DSI/RAB		1	1	<u>REG FILE</u>	04	1
	RGN1		1				
EXTERNAL:	24X		1		EG&G BRUSKE, S		1
	LPDR	03	2	2	NRC PDR	02	1
	NSIC	05	1				
NOTES:			3	3			



Faint, illegible text at the top of the page, possibly a header or title.

First main line of faint, illegible text in the upper section.

Second main line of faint, illegible text in the upper section.

Third main line of faint, illegible text in the upper section.

Fourth main line of faint, illegible text in the upper section.

Fifth main line of faint, illegible text in the upper section.

Sixth main line of faint, illegible text in the upper section.



**Pennsylvania Power & Light Company**

Two North Ninth Street • Allentown, PA 18101 • 215 / 770-5151

Norman W. Curtis  
Vice President-Engineering & Construction-Nuclear  
215/770-7501

**JUL 31 1985**

Director of Nuclear Reactor Regulation  
Attention: Mr. W. R. Butler, Chief  
Licensing Branch No. 2  
Division of Licensing  
U.S. Nuclear Regulatory Commission  
Washington, DC 20555

SUSQUEHANNA STEAM ELECTRIC STATION  
ADDITIONAL INFORMATION ON ESTIMATING  
CORE DAMAGE PROCEDURE  
ER 100450 FILE 841-2  
PLA-2502

Docket Nos. 50-387  
50-388

Dear Mr. Butler:

This letter is in response to a request by your Staff for the justification for not including the containment radiation monitors in our procedure for estimating core damage.

The use of information from the containment radiation monitors is not included in the procedure for estimating core damage since it is impractical to correlate this information to the amount of core damage. Assumptions concerning the chemical form of the source and its ultimate location, the location and response characteristics of the detector, and the shield material between the detector and the emitting source would have to be made when developing a correlation.

Specifically the following items will have dramatic impact on the radiation levels in the vicinity of the containment high radiation monitors, and were used in the evaluation of not including the containment monitors in our procedure for estimating core damage.

1. The sequence of events that leads to core damage determines the form and location of the radiation source. Fission products from a transient induced core melt will be transported to the suppression pool through the vessel internals and the SRV tails pipes. Much of the less volatile fission products will condense on the cooler vessel and internal surfaces or be scrubbed in the pool. The noble gases will also be discharged into a subcooled pool where their evolution will be diffusion limited.

A LOCA induced core melt, however, will discharge directly to the drywell. The noble gases will remain airborne in the drywell, but the soluble fission products such as the halogens, cesium, tellurium and others, will

8508050447	850731
PDR	ADOCK 05000387
P	PDR

*A001*  
*1/0*

1942

... ..  
... ..  
... ..  
... ..

... ..  
... ..  
... ..  
... ..

... ..  
... ..

...

... ..  
... ..

... ..  
... ..  
... ..  
... ..  
... ..

... ..  
... ..  
... ..

... ..  
... ..  
... ..  
... ..  
... ..

... ..  
... ..  
... ..

JUL 31 1985

Page 2

SSES

PLA-2502

ER 100450

File 841-2

Mr. W. R. Butler

be swept into the suppression pool. A pool of fission product contaminated water will form on the diaphragm floor that will represent a disk source.

2. The dose at the detector is a function of the shielding between the source and the detector. There are two types of shield material in the drywell: the structural components and the gas.

The drywell is densely populated with pumps, pipes and structural supports. These components are made of stainless steel and will provide shielding between the emitting source and the detector.


The stopping power of the drywell gas is, to the first order, directly proportional to the gas density. The containment pressurization during an accident is largely due to the increased water vapor in the air, which implies an increase in the gas density. This phenomenon can increase the drywell density by a factor of 6, which implies an equivalent decrease in the detector dose.

3. The detector response function is a function of gamma ray energy. Proper calibration of these detectors to the possible spectrum of fission products would require exposing the detector to an equivalent source which is impractical.

The purpose of intergrating other plant parameters such as, water level, containment hydrogen concentration, containment radiation levels and less volatile fission products was to corroborate and refine estimates based on PASS samples of iodine, cesium and noble gas. As discussed above the containment radiation monitors do not perform this function, and may even have a deleterious effect on the ability to estimate core damage. The use of the containment radiation monitors have therefore not been included in the PP&L procedure.

If you have any additional questions, please contact us.

Very truly yours,



N. W. Curtis

Vice President-Engineering & Construction-Nuclear

cc: M. J. Campagnone

USNRC

R. H. Jacobs

USNRC

10-11-52

Dear Mr. [Name]:

I have your letter of [Date] regarding [Subject].

The information you provided is being reviewed.

We will contact you again once a decision is reached.

Thank you for your patience and understanding.

Sincerely,  
[Name]

[Additional text or signature block]

[Additional text]

[Final text or signature]