

Nitrogen Makeup

SV-15737	N/A	B,Y,R
SV-15738	N/A	B,Y,R
SV-15767	N/A	B,Y,R
SV-15789	N/A	B,Y,R

ADD THIS CHANGE

TABLE 3.6.3-1. (Continued)

PRIMARY CONTAINMENT ISOLATION VALVES

<u>VALVE FUNCTION AND NUMBER</u>	<u>MAXIMUM ISOLATION TIME (Seconds)</u>	<u>ISOLATION SIGNAL(s)<sup>(a)</sup></u>
----------------------------------	---	--

Automatic Isolation Valves (Continued)

DELETE THIS CHANGE

Containment Atmosphere Sample

SV-15734	A,B	N/A	B,Y
SV-15736	A	N/A	B,Y
SV-15736	B	N/A	B,Y,R
<del>SV-15737</del>	<del>A</del>	<del>N/A</del>	<del>B,Y,R</del>
SV-15740	A,B	N/A	B,Y
SV-15742	A,B	N/A	B,Y
SV-15750	A,B	N/A	B,Y
SV-15752	A,B	N/A	B,Y
<del>SV-15767</del>	<del>A</del>	<del>N/A</del>	<del>B,Y,R</del>
SV-15774	A,B	N/A	B,Y
SV-15776	A	N/A	B,Y
SV-15776	B	N/A	B,Y,R
SV-15780	A,B	N/A	B,Y
SV-15782	A,B	N/A	B,Y

Reactor Coolant Sample

HV-143F019	2	B,C
HV-143F020	2	B,C

Liquid Radwaste

HV-16108	A1,A2	15	B,Z
HV-16116	A1,A2	15	B,Z

RHR - Suppression Pool

Cooling/Spray<sup>(c)</sup>

HV-151F011	A,B	23	X,Z	23
HV-151F028	A,B	90	X,Z	

CS Test<sup>(b)(c)</sup>

HV-152F015	A,B	60	X,Z
------------	-----	----	-----

HPCI Suction<sup>(b)(c)</sup>

HV-155F042		90	L, LB
------------	--	----	-------

8508120443 850806  
PDR ADDCK 05000387  
PDR



100-100000-100000