

## PLANT SYSTEMS

### EMERGENCY SERVICE WATER SYSTEM

#### LIMITING CONDITION FOR OPERATION

3.7.1.2 Two independent emergency service water system loops shall be OPERABLE with each loop comprised of:

- a. Two OPERABLE emergency service water pumps, and
- b. An OPERABLE flow path capable of taking suction from the spray pond and transferring the water to the associated safety related equipment.

APPLICABILITY: OPERATIONAL CONDITIONS 1, 2, 3, 4, 5 and \*.

#### ACTION:

- a. In OPERATIONAL CONDITION 1, 2, or 3:
  1. <sup>#</sup> With one emergency service water pump inoperable, restore the inoperable pump to OPERABLE status within 7 days or be in at least HOT SHUTDOWN within the next 12 hours and in COLD SHUTDOWN within the following 24 hours.
  2. With two emergency service water pumps inoperable, restore at least one inoperable pump to OPERABLE status within 72 hours or be in at least HOT SHUTDOWN within the next 12 hours and in COLD SHUTDOWN within the following 24 hours.
  3. With one emergency service water system loop inoperable, restore the inoperable loop to OPERABLE status with at least one OPERABLE pump within 72 hours or be in at least HOT SHUTDOWN within the next 12 hours and in COLD SHUTDOWN within the following 24 hours.
- b. With only one emergency service water pump and its associated flowpath OPERABLE, restore at least two pumps and their associated flowpaths to OPERABLE status within 72 hours or:
  1. In OPERATIONAL CONDITION 4 or 5, declare the associated safety related equipment inoperable and take the ACTION required by Specifications 3.5.2 and 3.8.1.2.
  2. In Operational Condition \*, declare the associated diesel generator(s) inoperable and take the ACTION required by Specification 3.8.1.2. The provisions of Specification 3.0.3 are not applicable.

#### SURVEILLANCE REQUIREMENTS

- 3.7.1.2 The emergency service water system shall be demonstrated OPERABLE:
- a. At least once per 31 days by verifying that each valve, manual, power operated or automatic, servicing safety related equipment that is not locked, sealed or otherwise secured in position, is in its correct position.
  - b. At least once per 18 months during shutdown, by verifying that each pump starts automatically when its associated diesel generator starts.

When handling irradiated fuel in the secondary containment.

Footnote to Specification 3.7.1.2

# When any diesel generator is removed from service in order to do work associated with tying in the additional diesel generator and its associated emergency service water pump is inoperable, Action a.1 shall read as follows:

- a.1 With one emergency service water pump inoperable, restore the inoperable pump to OPERABLE status when its associated diesel generator is restored to OPERABLE status per Specification 3.8.1.1.

## 3/4.8 ELECTRICAL POWER SYSTEMS

### 3/4.8.1 A.C. SOURCES

#### A.C. SOURCES - OPERATING

#### LIMITING CONDITION FOR OPERATION

---

3.8.1.1 As a minimum, the following A.C. electrical power sources shall be OPERABLE:


- a. Two physically independent circuits between the offsite transmission network and the onsite Class 1E distribution system, and
- b. Four separate and independent diesel generators\*, each with:
  1. Separate engine mounted day fuel tanks containing a minimum of 325 gallons of fuel,
  2. A separate fuel storage system containing a minimum of 47,570 gallons of fuel, and
  3. A separate fuel transfer pump.

APPLICABILITY: OPERATIONAL CONDITIONS 1, 2, and 3.

#### ACTION:<sup>#</sup>

- a. With either one offsite circuit or one diesel generator of the above required A.C. electrical power sources inoperable, demonstrate the OPERABILITY of the remaining A.C. sources by performing Surveillance Requirements 4.8.1.1.1.a within one hour and 4.8.1.1.2.a.4, for one diesel generator at a time, within four hours and at least once per 8 hours thereafter; restore at least two offsite circuits and four diesel generators to OPERABLE status within 72 hours or be in at least HOT SHUTDOWN within the next 12 hours and in COLD SHUTDOWN within the following 24 hours.
- b. With one offsite circuit and one diesel generator of the above required A.C. electrical power sources inoperable, demonstrate the OPERABILITY of the remaining A.C. sources by performing Surveillance Requirements 4.8.1.1.1.a within one hour and 4.8.1.1.2.a.4, for one diesel generator at a time, within three hours and at least once per 8 hours thereafter; restore at least one of the inoperable A.C. sources to OPERABLE status within 12 hours or be in at least HOT SHUTDOWN within the next 12 hours and in COLD SHUTDOWN within the following 24 hours. Restore at least two offsite circuits and four diesel generators to OPERABLE status within 72 hours from time of initial loss or be in at least HOT SHUTDOWN within the next 12 hours and in COLD SHUTDOWN within the following 24 hours.

\*Shared with Unit 2.



Footnote to Specification 3.8.1.1

Insert A

When any diesel generator is removed from service in order to do work associated with tying in the additional diesel generator, the ACTIONS shall read as follows:

- a. With one diesel generator of the above required A.C. electrical power sources inoperable, demonstrate the OPERABILITY of the remaining A.C. sources by performing Surveillance Requirements 4.8.1.1.1.a within one hour and 4.8.1.1.2.a.4, within 24 hours and at least once per 72 hours thereafter; restore at least four diesel generators to OPERABLE status within 60 days of accumulated outage time for all four diesels or be in at least HOT SHUTDOWN within the next 12 hours and in COLD SHUTDOWN within the following 24 hours. The provisions of Specification 3.0.4 are not applicable. *212-11*
- b. With one offsite circuit and one diesel generator of the above required A.C. electrical power sources inoperable, demonstrate the OPERABILITY of the remaining A.C. sources by performing Surveillance Requirements 4.8.1.1.1.a within one hour and 4.8.1.1.2.a.4, within 24 hours and at least once per 72 hours thereafter; restore at least two offsite circuits to OPERABLE status within 12 hours or be in at least HOT SHUTDOWN within the next 12 hours and in COLD SHUTDOWN within the following 24 hours. With the two offsite circuits restored to OPERABLE status, follow ACTION a.
- c. With one diesel generator of the above required A.C. electrical power sources inoperable, in addition to ACTION a or b, above, verify within 2 hours that all required systems, subsystems, trains, components and devices that depend on the remaining diesel generators as a source of emergency power are also OPERABLE except as noted in Specification 3.7.1.2; otherwise, be in at least HOT SHUTDOWN within the next 12 hours and in COLD SHUTDOWN within the following 24 hours.
- d. With two of the above required offsite circuits and one diesel generator inoperable, demonstrate the OPERABILITY of three diesel generators by performing Surveillance Requirement 4.8.1.1.2.a.4, within four hours and at least once per 8 hours thereafter, unless the diesel generators are already operating; restore the two offsite circuits to OPERABLE status within 12 hours or be in at least HOT SHUTDOWN within the next 12 hours and in COLD SHUTDOWN within the following 24 hours. With the two offsite circuits restored to OPERABLE status, follow ACTION a.
- e. With two or more of the above required diesel generators inoperable, demonstrate the OPERABILITY of the remaining A.C. sources by performing Surveillance Requirement 4.8.1.1.1.a within one hour; restore at least three of the diesel generators to OPERABLE status within 2 hours or be in at least HOT SHUTDOWN within the next 12 hours and in COLD SHUTDOWN within the following 24 hours. With three diesel generators restored to OPERABLE status, follow ACTION a.

Rev. 1  
△

Rev. 1  
△

Insert A

Prior to but within 24 hours of removing any diesel generator from service in order to do work associated with tying in the additional diesel generator, Surveillance Requirement 4.8.1.1.2.a.4 shall be performed on the diesel generators which are to remain in service.

LIMITING CONDITION FOR OPERATION (Continued)ACTION (Continued)

- c. With one diesel generator of the above required A.C. electrical power sources inoperable, in addition to ACTION a or b, above, verify within 2 hours that all required systems, subsystems, trains, components and devices that depend on the remaining diesel generators as a source of emergency power are also OPERABLE; otherwise, be in at least HOT SHUTDOWN within the next 12 hours and in COLD SHUTDOWN within the following 24 hours.
- d. With two of the above required offsite circuits inoperable, demonstrate the OPERABILITY of four diesel generators by performing Surveillance Requirement 4.8.1.1.2.a.4, for one diesel generator at a time, within four hours and at least once per 8 hours thereafter, unless the diesel generators are already operating; restore at least one of the inoperable offsite circuits to OPERABLE status within 24 hours or be in at least HOT SHUTDOWN within the next 12 hours. With only one offsite circuit restored to OPERABLE status, restore at least two offsite circuits to OPERABLE status within 72 hours from time of initial loss or be in at least HOT SHUTDOWN within the next 12 hours and in COLD SHUTDOWN within the following 24 hours.
- e. With two or more of the above required diesel generators inoperable, demonstrate the OPERABILITY of the remaining A.C. sources by performing Surveillance Requirement 4.8.1.1.1.a within one hour and 4.8.1.1.2.a.4, for one diesel generator at a time, within 2 hours, and at least once per 8 hours thereafter; restore at least three of the diesel generators to OPERABLE status within 2 hours or be in at least HOT SHUTDOWN within the next 12 hours and in COLD SHUTDOWN within the following 24 hours. Restore four diesel generators to OPERABLE status within 72 hours from time of initial loss or be in at least HOT SHUTDOWN within the next 12 hours and in COLD SHUTDOWN within the following 24 hours.

## PLANT SYSTEMS

### EMERGENCY SERVICE WATER SYSTEM

#### LIMITING CONDITION FOR OPERATION

3.7.1.2 Two independent emergency service water system loops shall be OPERABLE with each loop comprised of:

- a. Two OPERABLE emergency service water pumps, and
- b. An OPERABLE flow path capable of taking suction from the spray pond and transferring the water to the associated safety-related equipment.

APPLICABILITY: OPERATIONAL CONDITIONS 1, 2, 3, 4, 5, and \*.

#### ACTION:

- a. In OPERATIONAL CONDITION 1, 2, or 3:
  1. With one emergency service water pump inoperable, restore the inoperable pump to OPERABLE status within 7 days or be in at least HOT SHUTDOWN within the next 12 hours and in COLD SHUTDOWN within the following 24 hours.
  2. With two emergency service water pumps inoperable, restore at least one inoperable pump to OPERABLE status within 72 hours or be in at least HOT SHUTDOWN within the next 12 hours and in COLD SHUTDOWN within the following 24 hours.
  3. With one emergency service water system loop otherwise inoperable, restore the inoperable loop to OPERABLE status with at least one OPERABLE pump within 72 hours or be in at least HOT SHUTDOWN within the next 12 hours and in COLD SHUTDOWN within the following 24 hours.
- b. In OPERATIONAL CONDITION 4, 5 or \*:
  1. With one pump in an emergency service water system loop inoperable, verify adequate cooling capability remains available for the diesel generators required to be operable by Specification 3.8.1.2 or declare the affected diesel generator(s) inoperable and take the ACTION required by Specification 3.8.1.2.
  2. With two pumps in an emergency service water system loop inoperable or with the loop otherwise inoperable declare the associated safety related equipment inoperable (except diesel generators), and follow the applicable ACTION statements. Verify adequate cooling remains available for the diesel generators required to be operable by Specification 3.8.1.2 or declare the affected diesel generator(s) inoperable and take the ACTION required by Specification 3.8.1.2.

#### SURVEILLANCE REQUIREMENTS

4.7.1.2 The emergency service water system shall be demonstrated OPERABLE:

- a. At least once per 31 days by verifying that each valve (manual, power operated, or automatic) servicing safety-related equipment that is not locked, sealed, or otherwise secured in position, is in its correct position.

\*When handling irradiated fuel in the secondary containment.



Footnote to Specification 3.7.1.2

When any diesel generator is removed from service in order to do work associated with tying in the additional diesel generator and its associated emergency service water pump is inoperable, Action a.1 shall read as follows:

- a.1 With one emergency service water pump inoperable, restore the inoperable pump to OPERABLE status when its associated diesel generator is restored to OPERABLE status per Specification 3.8.1.1.

## 3/4.8 ELECTRICAL POWER SYSTEMS

### 3/4.8.1 A.C. SOURCES

#### A.C. SOURCES - OPERATING

##### LIMITING CONDITION FOR OPERATION

---

3.8.1.1 As a minimum, the following A.C. electrical power sources shall be OPERABLE:

- a. Two physically independent circuits between the offsite transmission network and the onsite Class 1E distribution system, and
- b. Four separate and independent diesel generators\*, each with:
  1. Separate engine mounted day fuel tanks containing a minimum of 325 gallons of fuel,
  2. A separate fuel storage system containing a minimum of 47,570 gallons of fuel, and
  3. A separate fuel transfer pump.

APPLICABILITY: OPERATIONAL CONDITIONS 1, 2, and 3.

##### ACTION:#

- a. With either one offsite circuit or one diesel generator of the above required A.C. electrical power sources inoperable, demonstrate the OPERABILITY of the remaining A.C. sources by performing Surveillance Requirements 4.8.1.1.1.a within 1 hour and 4.8.1.1.2.a.4, for one diesel generator at a time, within 4 hours and at least once per 8 hours thereafter; restore at least two offsite circuits and four diesel generators to OPERABLE status within 72 hours or be in at least HOT SHUTDOWN within the next 12 hours and in COLD SHUTDOWN within the following 24 hours.
- b. With one offsite circuit and one diesel generator of the above required A.C. electrical power sources inoperable, demonstrate the OPERABILITY of the remaining A.C. sources by performing Surveillance Requirements 4.8.1.1.1.a within 1 hour and 4.8.1.1.2.a.4, for one diesel generator at a time, within 3 hours and at least once per 8 hours thereafter; restore at least one of the inoperable A.C. sources to OPERABLE status within 12 hours or be in at least HOT SHUTDOWN within the next 12 hours and in COLD SHUTDOWN within the following 24 hours. Restore at least two offsite circuits and four diesel generators to OPERABLE status within 72 hours from time of initial loss or be in at least HOT SHUTDOWN within the next 12 hours and in COLD SHUTDOWN within the following 24 hours.

\*Shared with Unit 1.

Footnote to Specification 3.8.1.1


Insert A

Δ Rev. 1

When any diesel generator is removed from service in order to do work associated with tying in the additional diesel generator, the ACTIONS shall read as follows:

- a. With one diesel generator of the above required A.C. electrical power sources inoperable, demonstrate the OPERABILITY of the remaining A.C. sources by performing Surveillance Requirements 4.8.1.1.1.a within one hour and 4.8.1.1.2.a.4, within <sup>72</sup>24 hours and at least once per 72 hours thereafter; restore at least four diesel generators to OPERABLE status within 60 days of accumulated outage time for all four diesels or be in at least HOT SHUTDOWN within the next 12 hours and in COLD SHUTDOWN within the following 24 hours. The provisions of Specification 3.0.4 are not applicable. *Tie-in*
- b. With one offsite circuit and one diesel generator of the above required A.C. electrical power sources inoperable, demonstrate the OPERABILITY of the remaining A.C. sources by performing Surveillance Requirements 4.8.1.1.1.a within one hour and 4.8.1.1.2.a.4, within 24 hours and at least once per 72 hours thereafter; restore at least two offsite circuits to OPERABLE status within 12 hours or be in at least HOT SHUTDOWN within the next 12 hours and in COLD SHUTDOWN within the following 24 hours. With the two offsite circuits restored to OPERABLE status, follow ACTION a.
- c. With one diesel generator of the above required A.C. electrical power sources inoperable, in addition to ACTION a or b, above, verify within 2 hours that all required systems, subsystems, trains, components and devices that depend on the remaining diesel generators as a source of emergency power are also OPERABLE except as noted in Specification 3.7.1.2; otherwise, be in at least HOT SHUTDOWN within the next 12 hours and in COLD SHUTDOWN within the following 24 hours.
- d. With two of the above required offsite circuits and one diesel generator inoperable, demonstrate the OPERABILITY of three diesel generators by performing Surveillance Requirement 4.8.1.1.2.a.4, within four hours and at least once per 8 hours thereafter, unless the diesel generators are already operating; restore the two offsite circuits to OPERABLE status within 12 hours or be in at least HOT SHUTDOWN within the next 12 hours and in COLD SHUTDOWN within the following 24 hours. With the two offsite circuits restored to OPERABLE status, follow ACTION a.
- e. With two or more of the above required diesel generators inoperable, demonstrate the OPERABILITY of the remaining A.C. sources by performing Surveillance Requirement 4.8.1.1.1.a within one hour; restore at least three of the diesel generators to OPERABLE status within 2 hours or be in at least HOT SHUTDOWN within the next 12 hours and in COLD SHUTDOWN within the following 24 hours. With three diesel generators restored to OPERABLE status, follow ACTION a.

Rev. 1  
Δ



Insert A

Prior to but within 24 hours of removing any diesel generator from service in order to do work associated with tying in the additional diesel generator, Surveillance Requirement 4.8.1.1.2.a.4 shall be performed on the diesel generators which are to remain in service.

LIMITING CONDITION FOR OPERATION (Continued)

ACTION (Continued)

- c. With one diesel generator of the above required A.C. electrical power sources inoperable, in addition to ACTION a or b, above, verify within 2 hours that all required systems, subsystems, trains, components and devices that depend on the remaining diesel generators as a source of emergency power are also OPERABLE; otherwise, be in at least HOT SHUTDOWN within the next 12 hours and in COLD SHUTDOWN within the following 24 hours.
- d. With two of the above required offsite circuits inoperable, demonstrate the OPERABILITY of four diesel generators by performing Surveillance Requirement 4.8.1.1.2.a.4, for one diesel generator at a time, within four hours and at least once per 8 hours thereafter, unless the diesel generators are already operating; restore at least one of the inoperable offsite circuits to OPERABLE status within 24 hours or be in at least HOT SHUTDOWN within the next 12 hours. With only one offsite circuit restored to OPERABLE status, restore at least two offsite circuits to OPERABLE status within 72 hours from time of initial loss or be in at least HOT SHUTDOWN within the next 12 hours and in COLD SHUTDOWN within the following 24 hours.
- e. With two or more of the above required diesel generators inoperable, demonstrate the OPERABILITY of the remaining A.C. sources by performing Surveillance Requirement 4.8.1.1.1.a within one hour and 4.8.1.1.2.a.4, for one diesel generator at a time, within 2 hours, and at least once per 8 hours thereafter; restore at least three of the diesel generators to OPERABLE status within 2 hours or be in at least HOT SHUTDOWN within the next 12 hours and in COLD SHUTDOWN within the following 24 hours. Restore four diesel generators to OPERABLE status within 72 hours from time of initial loss or be in at least HOT SHUTDOWN within the next 12 hours and in COLD SHUTDOWN within the following 24 hours.



10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28  
29  
30  
31  
32  
33  
34  
35  
36  
37  
38  
39  
40  
41  
42  
43  
44  
45  
46  
47  
48  
49  
50  
51  
52  
53  
54  
55  
56  
57  
58  
59  
60  
61  
62  
63  
64  
65  
66  
67  
68  
69  
70  
71  
72  
73  
74  
75  
76  
77  
78  
79  
80  
81  
82  
83  
84  
85  
86  
87  
88  
89  
90  
91  
92  
93  
94  
95  
96  
97  
98  
99  
100