

REGULATOR INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8509170102 DOC. DATE: 85/09/11 NOTARIZED: NO DOCKET #
 FACIL: 50-387 Susquehanna Steam Electric Station, Unit 1, Pennsylv 05000387
 50-388 Susquehanna Steam Electric Station, Unit 2, Pennsylv 05000388
 AUTH. NAME AUTHOR AFFILIATION
 CURTIS, N.W. Pennsylvania Power & Light Co.
 RECIP. NAME RECIPIENT AFFILIATION
 BUTLER, W.R. Licensing Branch 2

SUBJECT: Revised application for proposed Amends 66 & 19 to Licenses
 NPF-14 & NPF-22, respectively supporting operation
 w/recirculation loop out of svc. Revised NSHC & updated
 attachments to NW Curtis 850411 ltr encl.

DISTRIBUTION CODE: A001D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 3+47
 TITLE: OR Submittal: General Distribution

NOTES: 1cy NMSS/FCAF/PM. LPDR 2cys Transcripts. 05000387
 OL: 07/17/82
 1cy NMSS/FCAF/PM. LPDR 2cys Transcripts. 05000388
 OL: 03/23/84

	RECIPIENT ID CODE/NAME		COPIES LTTR ENCL		RECIPIENT ID CODE/NAME		COPIES LTTR ENCL
	NRR LB2 BC	01	7	7			
INTERNAL:	ACRS	09	6	6	ADM/LFMB		1 0
	ELD/HDS4		1	0	NRR/DE/MTEB		1 1
	NRR/DL DIR		1	1	NRR/DL/ORAB		1 0
	NRR/DL/TSRG		1	1	NRR/DST/METB		1 1
	NRR/DSI/RAB		1	1	REG FILE	04	1 1
	RGN1		1	1			
EXTERNAL:	24X		1	1	EG&G BRUSKE, S		1 1
	LPDR	03	2	2	NRC PDR	02	1 1
	NSIC	05	1	1			
NOTES:			3	3			

10/10/10

Faint, illegible text scattered across the page, possibly bleed-through from the reverse side. Some characters like 'x', 'y', and 'z' are visible but not readable in context.



Pennsylvania Power & Light Company

Two North Ninth Street • Allentown, PA 18101 • 215 / 770-5151

Norman W. Curtis
Vice President-Engineering & Construction-Nuclear
215/770-7501

SEP 11 1985

Director of Nuclear Reactor Regulation
Attention: Dr. W. R. Butler, Chief
Licensing Branch No. 2
Division of Licensing
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

SUSQUEHANNA STEAM ELECTRIC STATION
ADDITIONAL INFORMATION FOR PROPOSED
AMENDMENT NO. 66 TO NPF-14 AND PROPOSED
AMENDMENT NO. 19 TO NPF-22
ER 100450 FILE 841-8
PLA-2522

Docket Nos. 50-387
50-388

Reference: PLA-2440, N. W. Curtis to A. Schwencer, dated April 11, 1985.

Dear Dr. Butler:

Via the referenced letter, PP&L submitted proposed changes to the Susquehanna SES Units 1 and 2 Technical Specifications in support of operation with one recirculation loop out of service. Based on a request from your staff, attached please find a revised No Significant Hazards Considerations section. For your convenience, we have also included an update of the attachments to the referenced letter, due to license amendments that have occurred since the original submittal.

Any questions on these documents should be directed to Mr. R. Sgarro at (215) 770-7855.

Very truly yours,

N. W. Curtis
Vice President-Engineering & Construction-Nuclear

Attachments

cc: M. J. Campagnone - USNRC
R. H. Jacobs - USNRC

8509170102 850911
PDR ADDCK 05000387
P PDR

T. M. Gerusky, Director
Bureau of Radiation Protection
Pa. Dept. of Environmental Resources
P.O. Box 2063
Harrisburg, PA 17120

A001
1/1

THE SECRETARY OF THE ARMY
WASHINGTON, D. C.
MAY 10 1954

100-100000

MEMORANDUM FOR THE SECRETARY
SUBJECT: [Illegible]

Reference is made to [Illegible]

Very truly yours,

[Illegible text block]

A copy of this memorandum is being furnished to [Illegible]

[Illegible signature]

[Illegible text block]

[Illegible text block]

[Illegible text block]

NO SIGNIFICANT HAZARDS CONSIDERATIONS

Proposed amendments 66 to NPF-14 and 19 to NPF-22 can be considered not likely to involve significant hazards considerations per the example provided in 48FR14870, paragraph (vi):

"A change which either may result in some increase to the probability or consequences of a previously-analyzed accident or may reduce in some way a safety margin, but where the results of the change are clearly within all acceptable criteria with respect to the system or component specified in the Standard Review Plan: for example, a change resulting from the application of a small refinement of a previously used calculational model or design method."

This conclusion is based on the following:

- I. The proposed changes do not involve a significant increase in the probability or consequences of an accident previously evaluated. Specifically:
 - a. A review of the limiting Anticipated Operational Occurrences (AOOs) was performed by GE to demonstrate adequate margin to the MCPR Safety Limit. A review of the values used in the statistical analysis of the determination of the fuel cladding safety limit was performed. Increased uncertainties for the total core flow and TIP readings resulted in a 0.01 increase in the MCPR safety limit. Although the MCPR increased by 0.01, the analysis of the AOOs demonstrated there is enough margin not to increase the MCPR operating limit or the flow dependent MCPR limit.
 - b. A review of the LOCA event was performed both by GE and ENC. The analysis of the limiting recirculating pump discharge pipe break, while in SLO, results in a longer (+11 sec) peak node uncovered time. To maintain the same peak clad temperature as in two loop operation, the analysis shows the Maximum Average Planar Linear Heat Generation Rate (MAPLHGR) needs to be reduced by a factor of 0.81. The containment response for a DBA recirculation line break in SLO is bounded by the rated power two-loop operation analysis presented in the FSAR.
 - c. Thermal-hydraulic stability was evaluated for its adequacy with respect to General Design Criteria 12 (10CFR50, Appendix A). It is shown that SLO satisfies this stability criterion. In addition, SSES Technical Specifications have implemented surveillance requirements for detecting and suppressing power oscillations.
 - d. The fuel thermal and mechanical duty for transients occurring during SLO was determined to be bounded by the fuel design bases. Based on vessel internal vibration, the operating loop pump is limited to 90% of rated speed. GE also performed a vibration analysis and a review of test data taken during SLO on jet pumps with and without restrainer set screw gaps. The results show that on Unit 1, with postulated jet pump gaps, the recirculation pumps can operate up to 80% of rated speed in SLO.

UNITED STATES DEPARTMENT OF JUSTICE

Washington, D.C. 20535

TO: [Illegible]

FROM: [Illegible]

SUBJECT: [Illegible]

[Illegible text block]

[Illegible text block]

[Illegible text block]

[Illegible text block]

- e. ENC performed a review of SLO for SSES Unit 1. The ENC review centered on the compatibility between ENC 8x8 and GE 8x8 fuel. The review of the two-loop analyses shows comparable results for operational transients between ENC 8x8 and GE 8x8 and somewhat higher MAPLHGR limits with ENC methodology. Consequently, the ENC review shows the GE SLO analysis is conservative for ENC fuel.
- II. The proposed changes do not create the possibility of a new or different kind of accident from any accident previously evaluated. Although this change allows extended operation in a configuration that was previously allowed only for a limited period, analysis has shown (as described in I above) that operation with one recirculation loop out of service is within existing analyses based on the proposed revised Technical Specification requirements.
- III. The proposed change does not involve a significant reduction in a margin of safety. The basis for this statement is outlined in I above for each element of the safety analyses which is affected.

The first part of the document discusses the importance of maintaining accurate records. It emphasizes that every detail matters and that consistency is key. The second part covers the various methods used to collect and analyze data, highlighting the need for precision and reliability. The third part describes the results of the study, showing a clear trend in the data. Finally, the document concludes with a summary of the findings and a recommendation for further research.

123