

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8509270009 DOC. DATE: 85/09/23 NOTARIZED: NO DOCKET #  
 FACIL: 50-387 Susquehanna Steam Electric Station, Unit 1, Pennsylvania 05000387  
 50-388 Susquehanna Steam Electric Station, Unit 2, Pennsylvania 05000388  
 AUTH. NAME: KEISER, H.W. AUTHOR AFFILIATION: Pennsylvania Power & Light Co.  
 RECIP. NAME: BUTLER, W.R. RECIPIENT AFFILIATION: Licensing Branch 2

SUBJECT: Requests exemption from 10CFR50 App A, GDC 17 re single failure criteria for onsite electrical power supplies. Exemption necessary for temporary change to Tech Specs 3.8.1.1 & 3.7.1.2 to remove diesel generators from svc.

DISTRIBUTION CODE: A001D COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 4  
 TITLE: OR Submittal: General Distribution

NOTES: 1cy NMSS/FCAF/PM. LPDR 2cys Transcripts. 05000387  
 OL: 07/17/82  
 1cy NMSS/FCAF/PM.. LPDR 2cys Transcripts. 05000388  
 OL: 03/23/84

	RECIPIENT ID CODE/NAME		COPIES LTR ENCL		RECIPIENT ID CODE/NAME		COPIES LTR ENCL
	NRR LB2 BC	01	7				
INTERNAL:	ACRS	09	6		ADM/LFMB		1 0
	ELD/HDS4		1		NRR/DE/MTEB		1 1
	NRR/DL DIR		1		NRR/DL/ORAB		1 0
	NRR/DL/TSRG		1		NRR/DSI/METB		1 1
	NRR/DSI/RAB		1		REG FILE	04	1 1
	RGN1		1				
EXTERNAL:	24X		1		EG&G BRUSKE, S		1 1
	LPDR	03	2		NRC PDR	02	1 1
	NSIC	05	1				
NOTES:			3				

TOTAL NUMBER OF COPIES REQUIRED: LTR 32 ENCL 29



[The text in this section is extremely faint and illegible due to the quality of the scan. It appears to be a multi-paragraph document.]



Pennsylvania Power & Light Company

Two North Ninth Street • Allentown, PA 18101 • 215 / 770-5151

Harold W. Keiser  
Vice President-Nuclear Operations  
215/770-7502

SEP 23 1985

Director of Nuclear Reactor Regulation  
Attention: Dr. W. R. Butler, Chief  
Licensing Branch No. 2  
Division of Licensing  
U.S. Nuclear Regulatory Commission  
Washington, D.C. 20555

SUSQUEHANNA STEAM ELECTRIC STATION  
REQUEST FOR EXEMPTION FROM 10CFR50  
APPENDIX A, GDC 17  
ER 100450 FILE 841-8  
PLA-2540

Docket Nos. 50-387  
50-388

Dear Dr. Butler:

PP&L is installing a new fifth diesel generator at Susquehanna Steam Electric Station. Permanent tie-in of this diesel generator to the plant, requires connection of control and power circuits from the existing diesel generators to transfer points in the new diesel generator building. In this regard PP&L has requested a one time change to the LCO's for Technical Specifications 3.8.1.1 and 3.7.1.2 which would allow the existing diesel generators to be removed from service, one at a time, for an accumulated period of 60 days. (Ref. PLA-2346 dated December 21, 1984)

According to your Staff, these temporary LCO extensions require an exemption to the single failure criteria for onsite electric power supplies as stated in 10CFR50 Appendix A, Criterion 17. This letter constitutes PP&L's request for this exemption.

The proposed exemption is justified because of the following reasons:

- (1) The design of our offsite AC circuits as described in Section 8.2 of the Final Safety Analysis Report.
- (2) The results of our probabilistic evaluation on extending the diesel generator LCO.

Current Technical Specifications allow continued dual unit operation for up to three days with a diesel generator inoperable. The associated action statement requires demonstration of operability of the remaining diesel generators and the offsite AC sources. This assures the capability of affecting a safe shutdown and mitigating the effects of a design basis accident. This is maintained with (1) the onsite AC power system (3 diesel generators) or (2) the two offsite AC power sources.

8509270009 850923  
PDR ADOCK 05000387 PDR

A001  
1/0



[The text in this section is extremely faint and illegible due to low contrast and noise. It appears to be a multi-paragraph document.]

SEP 23 1985

Page 2

SSES PLA-2540  
ER 100450 File 841-8  
Dr. W. R. Butler

Since the electrical AC power sources are degraded below the Technical Specification LCO, a time limit on continued operation is specified. This limits the exposure time in the degraded condition which in turn minimizes the risk associated with this level of degradation. The LCO in the case of one diesel generator is not too severe due to the redundancy of AC power sources which remain.

The offsite transmission system for Susquehanna SES is described in Section 8.2 of the Final Safety Analysis Report. Based on historical operating data (1975-81) for the PP&L transmission network, the annual forced outage rate per 100 circuit miles for 500KV and 230KV lines is 1.05 and 2.24 outages, respectively.

Transient stability studies were conducted in 1976-77, 1980-81 and 1983. These studies show that for various 230KV and 500KV bus and line faults, system stability and satisfactory recovery voltages are maintained resulting in uninterrupted supply to the offsite power system. These studies also conclude that no single occurrence is likely to cause a simultaneous outage of all offsite sources during operating, accident or adverse environmental conditions.

In the unlikely event that an area-wide blackout were to occur, offsite power can be re-established to Susquehanna SES from either combustion turbine generators or hydro units. This restoration time is approximately 2 hours.

A recent draft report prepared by Battelle Columbus Laboratories for the NRC entitled: "Determination of Allowed Outage Times (AOT's) from a Risk Standpoint" dated July, 1984 states that AOT extensions are only justifiable if there is insufficient time to perform a task and there is no significant increase in total risk. To complete the 5th diesel tie-in, we have estimated that a 15 day LCO per diesel could be required, which exceeds the current LCO limit of 3 days. Further, we have probabilistically evaluated the impact of this temporary extension and conclude there is no significant risk increase. A detailed discussion of this evaluation follows.

Several tasks were performed to examine the impact this extension has on the unavailability of system required to insure adequate core cooling (the assumed indicator of risk). These steps are outlined below:

1. identify loss of offsite power (LOOP) sequences which when coupled with a diesel in an LCO would result in adequate core cooling,
2. estimate the LOOP frequency and the safety function unavailabilities,
3. estimate the frequency of inadequate core cooling with and without the temporary technical specification change.

Sequences leading to inadequate core cooling are identified using the event tree illustrated in Figure 1. The LOOP frequency and system unavailabilities associated with the event tree heading are derived from data available in open



[The page contains extremely faint and illegible text, likely bleed-through from the reverse side of the document. The text is scattered across the page and cannot be transcribed accurately.]

literature. The LOOP frequency and system unavailabilities were combined using the event tree logic to obtain the yearly frequency of inadequate core cooling. This yearly frequency was calculated for two conditions: with all four diesel generators in standby, and with three in standby and one in a LCO. The frequency of inadequate core cooling (per year) is then calculated by summing these frequencies weighted by the yearly fraction of time in each condition. The equation for the frequency of inadequate core cooling is as follows:

$$\text{Frequency of Inadequate Core Cooling} = \frac{365.25 - \text{days in LCO}}{365.25} F_2 + \frac{\text{days in LCO}}{365.25} F_3$$

$F_2$  = The frequency of inadequate core cooling with all diesels in standby.

$F_3$  = The frequency of inadequate core cooling with either diesel A or B in an LCO.

For the LOOP frequency and system unavailabilities associated with the event tree headings, the following references were used:

- o Loss of Offsite Power at U.S. Nuclear Power Plant - All Years Through 1983, NSAC-80, July 1984, H. Wychaft
- o Precursors to Potential Severe Core Damage Accidents: 1980-1981, A Status Report, W. B. Cottrell, et al. ORNL/NSIC-217/VI & 217/V2.
- o Precursors to Potential Severe Core Damage Accidents: 1969-1979, A Status Report, J. W. Minerick, C. A. Kukielka, ORNL/NSIC-182/VI and 182/V2.
- o Reactor Safety Study, Wash-1400, Appendix II, 1975.
- o NSAC HPCI/RCIC failure data.

The increased risk associated with continued operation of both units with a diesel generator inoperable for 3 days is acceptable. Arguments supporting this statement are found in the applicable Technical Specification Bases section and Regulatory Guide 1.93. In this evaluation, risk is defined as the probability of inadequate core cooling during a LOOP. The proposed temporary change in the diesel generator LCO increases the frequency of LOOP sequences leading to inadequate core cooling from  $5.0 \times 10^{-6}$ /yr. to no more than  $6.4 \times 10^{-6}$ /yr. This represents a minimal impact when considering the uncertainties in the data.

The temporary LCO extension has no impact on the probability of inadequate core cooling when offsite power is available. The design of the onsite AC power supplies is such that only three diesel generators are required to fulfill the electric power requirements for ECCS equipment assuming a loss of offsite power, a LOCA in one unit and the shutdown of the other unit. As was shown in the evaluation the increased frequency of inadequate core cooling

1947

The first part of the report deals with the general situation in the country. It is noted that the economy is in a state of depression and that the government is unable to meet its obligations. The report also mentions that the population is suffering from widespread poverty and that the government is unable to provide for their basic needs.

The second part of the report deals with the political situation. It is noted that the government is unable to carry out its policies and that there is a general feeling of disillusion among the people. The report also mentions that there is a growing movement for independence and that the people are demanding a more democratic form of government.

The third part of the report deals with the social situation. It is noted that there is a high level of unemployment and that the people are unable to find work. The report also mentions that there is a high level of illiteracy and that the people are unable to read or write. The report also mentions that there is a high level of crime and that the people are unable to feel safe.

The fourth part of the report deals with the economic situation. It is noted that the government is unable to collect taxes and that there is a general feeling of economic despair. The report also mentions that there is a high level of inflation and that the people are unable to afford the goods and services they need. The report also mentions that there is a high level of unemployment and that the people are unable to find work.

The fifth part of the report deals with the international situation. It is noted that the country is unable to attract foreign investment and that there is a general feeling of isolation. The report also mentions that there is a high level of corruption and that the people are unable to trust the government. The report also mentions that there is a high level of crime and that the people are unable to feel safe.

The sixth part of the report deals with the future of the country. It is noted that the country is in a state of crisis and that the people are unable to see a bright future. The report also mentions that there is a high level of unemployment and that the people are unable to find work. The report also mentions that there is a high level of illiteracy and that the people are unable to read or write. The report also mentions that there is a high level of crime and that the people are unable to feel safe.



SEP 23 1985

Page 4

SSES PLA-2540  
ER 100450 File 841-8  
Dr. W. R. Butler

during the LCO extension is small and therefore the one time LCO extension is acceptable.

In order to assure thoroughness and incorporation of recent ideas on Technical Specification changes, the draft Program Plan for Procedure Evaluating Technical Specifications (prepared for NRC by Brookhaven National Laboratory, October 1984) was reviewed. This report identifies 23 issues which should be addressed in the evaluation of Allowed Outage Times (AOTs). Many of these were determined to be irrelevant to this request. However the following are relevant: analysis level (e.g. system, function, core-damage, etc.), risk importance of the diesel generators, common cause failure, uncertainty, operating accident risk, the length of repair time, and system reconfiguration. Common cause failures, uncertainties, operating accident risk, and system reconfiguration were explicitly addressed in the probabilistic analysis. The length of repair was previously mentioned as the reason for the one-time extension request. The remaining issues are discussed below.

The impact of the extended AOT on operating accident risk was evaluated with respect to inadequate core cooling (as a measure of core damage). This level of analysis was selected since it did not require reference to a full plant probabilistic risk assessment (PRA) and is a level at which the results can be viewed with a meaningful perspective. The availability of diesel generators only affects accident sequences which include a loss of offsite power (LOOP). These are typically low contributors to core damage frequency and public risk as illustrated through the risk achievement worth. Findings of the NRC accident Sequence Precursor Program show the risk achievement worth is only  $9.8 \times 10^{-6}$  for emergency power as compared to  $3.5 \times 10^{-1}$  for long term core cooling. This means the diesel generators would have a relatively low risk importance. The results of our analysis show a negligible increase in the frequency of LOOP sequences which can lead to inadequate core cooling. Therefore, the overall impact on operating accident risk during the AOT is negligible. This negligible increase should be more than offset by the additional capability of the extra diesel generator over the plant lifetime. This diesel is expected to significantly reduce the number of shutdowns and startups of one unit primarily due to the performance of required maintenance (which takes more than three days) during refueling of the other unit.

If you have any questions, please contact us.

Very truly yours,



H. W. Keiser  
Vice President-Nuclear Operations

cc: M. J. Campagnone - NRC  
R. H. Jacobs - NRC

