

ATTACHMENT TO LICENSE AMENDMENT NO. 78

TO FACILITY COMBINED LICENSE NO. NPF-91

DOCKET NO. 52-025

Replace the following pages of the Facility Combined License No. NPF-91 with the attached revised pages. The revised pages are identified by amendment number and contain marginal lines indicating the areas of change.

Facility Combined License No. NPF-91

REMOVE

INSERT

7

7

Appendix C to Facility Combined License No. NPF-91

REMOVE

INSERT

C-195

C-195

(7) Reporting Requirements

- (a) Within 30 days of a change to the initial test program described in FSAR Section 14, Initial Test Program, made in accordance with 10 CFR 50.59 or in accordance with 10 CFR Part 52, Appendix D, Section VIII, "Processes for Changes and Departures," SNC shall report the change to the Director of NRO, or the Director's designee, in accordance with 10 CFR 50.59(d).
- (b) SNC shall report any violation of a requirement in Section 2.D.(3), Section 2.D.(4), Section 2.D.(5), and Section 2.D.(6) of this license within 24 hours. Initial notification shall be made to the NRC Operations Center in accordance with 10 CFR 50.72, with written follow up in accordance with 10 CFR 50.73.

(8) Incorporation

The Technical Specifications, Environmental Protection Plan, and ITAAC in Appendices A, B, and C, respectively of this license, as revised through Amendment No. 78, are hereby incorporated into this license.

(9) Technical Specifications

The technical specifications in Appendix A to this license become effective upon a Commission finding that the acceptance criteria in this license (ITAAC) are met in accordance with 10 CFR 52.103(g).

(10) Operational Program Implementation

SNC shall implement the programs or portions of programs identified below, on or before the date SNC achieves the following milestones:

- (a) Environmental Qualification Program implemented before initial fuel load;
- (b) Reactor Vessel Material Surveillance Program implemented before initial criticality;
- (c) Preservice Testing Program implemented before initial fuel load;
- (d) Containment Leakage Rate Testing Program implemented before initial fuel load;
- (e) Fire Protection Program
  - 1. The fire protection measures in accordance with Regulatory Guide (RG) 1.189 for designated storage building areas (including adjacent fire areas that could affect the storage area) implemented before initial receipt

Table 2.3.2-4  
Inspections, Tests, Analyses, and Acceptance Criteria

| No. | ITAAC No.      | Design Commitment   | Inspections, Tests, Analyses  | Acceptance Criteria   |
|-----|----------------|---|---|---|
| 296 | 2.3.02.06b     | 6.b) The Class 1E components identified in Table 2.3.2-1 are powered from their respective Class 1E division.         | Testing will be performed on the CVS by providing a simulated test signal in each Class 1E division.  | A simulated test signal exists at the Class 1E equipment identified in Table 2.3.2-1 when the assigned Class 1E division is provided the test signal. |
| 297 | 2.3.02.06c     | 6.c) Separation is provided between CVS Class 1E divisions, and between Class 1E divisions and non-Class 1E cable.    | See ITAAC Table 3.3-6, item 7.d.  | See ITAAC Table 3.3-6, item 7.d.  |
| 298 | 2.3.02.07a     | 7.a) The CVS preserves containment integrity by isolation of the CVS lines penetrating the containment.               | See ITAAC Table 2.2.1-3, item 7.  | See ITAAC Table 2.2.1-3, item 7.  |
| 299 | 2.3.02.07b     | 7.b) The CVS provides termination of an inadvertent RCS boron dilution by isolating demineralized water from the RCS. | See item 10b in this table.   | See item 10b in this table.   |
| 300 | 2.3.02.07c     | 7.c) The CVS provides isolation of makeup to the RCS.   | See item 10b in this table.   | See item 10b in this table.   |
| 301 | 2.3.02.08a.i   | 8.a) The CVS provides makeup water to the RCS.  | i) Testing will be performed by aligning a flow path from each CVS makeup pump, actuating makeup flow to the RCS at pressure greater than or equal to 2000 psia, and measuring the flow rate in the makeup pump discharge line with each pump suction aligned to the boric acid storage tank. | i) Each CVS makeup pump provides a flow rate of greater than or equal to 100 gpm.   |
| 302 | 2.3.02.08a.ii  | 8.a) The CVS provides makeup water to the RCS.  | ii) Inspection of the boric acid storage tank volume will be performed.   | ii) The volume in the boric acid storage tank is at least 70,000 gallons between the tank suction point and the tank overflow.                        |
| 303 | 2.3.02.08a.iii | 8.a) The CVS provides makeup water to the RCS.  | iii) Testing will be performed to measure the delivery rate from the DWS to the RCS. Both CVS makeup pumps will be operating and the RCS pressure will be below 6 psig.   | iii) The total CVS makeup flow to the RCS is less than or equal to 175 gpm.   |