



Steven D. Capps
Vice President
McGuire Nuclear Station

Duke Energy
MG01VP | 12700 Hagers Ferry Road
Huntersville, NC 28078
o: 980.875.4805
f: 704.875.4809
Steven.Capps@duke-energy.com

Serial No: MNS-17-016

May 18, 2017

U.S. Nuclear Regulatory Commission
Washington, DC 20555-001

ATTENTION: Document Control Desk

Subject: Duke Energy Carolinas, LLC (Duke Energy)
McGuire Nuclear Station, Units 1 and 2
Docket No. 50-369, 50-370
Renewed License No. NPF-9 and NPF-17

Nuclear Regulatory Commission (NRC) Annual Commitment Change Report

Attached is the summary of commitment changes processed for McGuire Nuclear Station during the 2016 calendar year. These changes were made per the guidance defined in NEI 99-04, "Guidelines for Managing NRC Commitments," and have no adverse effect on compliance with NRC rules or regulations.

Questions regarding this submittal should be directed to Brian Richards at (980) 875-5171.

Sincerely,

Steven D. Capps

Attachment

ADD1
NRR

U.S. Nuclear Regulatory Commission
May 18, 2017
Page 2

cc w/ Attachments:

C. Haney
Administrator, Region II
U.S. Nuclear Regulatory Commission
Marquis One Tower
245 Peachtree Center Ave., NE, Suite 1200
Atlanta, GA 30303-1257

Electronic Copies:

A. Hutto (MNS senior resident inspector)
andy.hutto@nrc.gov

M. Mahoney (NRC project manager)
michael.mahoney@nrc.gov

McGuire Nuclear Station
Commitment Change Summary Report
Docket Nos. 50-369 and 50-370

NUMBER	SOURCE DOCUMENT	ORIGINAL COMMITMENT	MODIFIED COMMITMENT
2016-M-001 2017-M-001	MNS Commitment Changes 2002- M-004 and 2003-M-001, letter dated 4/15/2004	"The 4kv and the 7kv buses have a PM frequency of 6R with grace. Lower voltage buses have a PM frequency of 6 years. However, a one time exception to the lower voltage bus PM frequency is allowed if needed to align the lower voltage buses in an overall bus matrix schedule."	"The 4kv and the 7kv buses have a PM frequency of 8R with grace. Lower voltage buses have a PM frequency of 6 years with grace. However, a one-time exception to the lower voltage bus PM frequency is allowed if needed to align the lower voltage buses in an overall bus matrix schedule."