



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

June 20, 2017

Mr. Kenneth Higginbotham
Vice President-Nuclear and CNO
Nebraska Public Power District
72676 648A Avenue
Brownville, NE 68321

SUBJECT: COOPER NUCLEAR STATION - ISSUANCE OF AMENDMENT
RE: ADOPTION OF TECHNICAL SPECIFICATIONS TASK FORCE TRAVELER
TSTF-545, REVISION 3, "TS INSERVICE TESTING PROGRAM REMOVAL &
CLARIFY SR USAGE RULE APPLICATION TO SECTION 5.5 TESTING"
(CAC NO. MF8321)

Dear Mr. Higginbotham:

The U.S. Nuclear Regulatory Commission (NRC) has issued the enclosed Amendment No. 259 to Renewed Facility Operating License No. DPR-46 for the Cooper Nuclear Station (CNS). The amendment consists of changes to the technical specifications (TSs) in response to your application dated August 26, 2016 (Agencywide Documents Access and Management System (ADAMS) Accession No. ML16245A288).

The amendment deletes TS 5.5.6, "Inservice Testing Program." A new defined term, "Inservice Testing Program," is added to TS Section 1.1, "Definitions." In addition, existing uses of the term "Inservice Testing Program" in the TSs are capitalized throughout to indicate that it is now a defined term. The NRC staff has concluded that the proposed amendment is consistent with Technical Specifications Task Force (TSTF) Standard Technical Specifications Change Traveler TSTF-545, Revision 3, "TS Inservice Testing Program Removal & Clarify SR [Surveillance Requirement] Usage Rule Application to Section 5.5 Testing," which was made available to the TSTF via an NRC letter dated December 11, 2015 (ADAMS Accession No. ML15317A071), as part of the consolidated line item improvement process.


The use of Code Case OMN-20, "Inservice Test Frequency," was previously approved for use at CNS in an NRC safety evaluation dated February 12, 2016 (ADAMS Accession No. ML16014A174).

K. Higginbotham

- 2 -

A copy of our related Safety Evaluation is also enclosed. The Notice of Issuance will be included in the Commission's next biweekly *Federal Register* notice.

Sincerely,

A handwritten signature in black ink, appearing to read "Thomas J. Wengert". The signature is fluid and cursive, with a prominent initial "T" and a long, sweeping underline.

Thomas J. Wengert, Senior Project Manager
Plant Licensing Branch IV
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket No. 50-298

Enclosures:

1. Amendment No. 259 to DPR-46
2. Safety Evaluation

cc w/encls: Distribution via Listserv



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

NEBRASKA PUBLIC POWER DISTRICT

DOCKET NO. 50-298

COOPER NUCLEAR STATION

AMENDMENT TO RENEWED FACILITY OPERATING LICENSE

Amendment No. 259
Renewed License No. DPR-46

1. The U.S. Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Nebraska Public Power District (the licensee), dated August 26, 2016, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this license amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Renewed Facility Operating License No. DPR-46 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendix A as revised through Amendment No. 259, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. The license amendment is effective as of its date of issuance and shall be implemented within 60 days from the date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Robert J. Pascarelli, Chief
Plant Licensing Branch IV
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Attachment:
Changes to the Renewed Facility
Operating License No. DPR-46
and Technical Specifications

Date of Issuance: June 20, 2017

ATTACHMENT TO LICENSE AMENDMENT NO. 259
RENEWED FACILITY OPERATING LICENSE NO. DPR-46
COOPER NUCLEAR STATION
DOCKET NO. 50-298

Replace the following page of the Renewed Facility Operating License No. DPR-46 and the Appendix A, Technical Specifications with the enclosed revised pages. The revised pages are identified by amendment number and contain marginal lines indicating the areas of change.

Renewed Facility Operating License

<u>REMOVE</u>	<u>INSERT</u>
-3-	-3-

Technical Specifications

<u>REMOVE</u>	<u>INSERT</u>
1.1-3	1.1-3
1.1-4	1.1-4
1.1-5	1.1-5
3.1-22	3.1-22
3.4-7	3.4-7
3.5-5	3.5-5
3.5-10	3.5-10
3.6-13	3.6-13
3.6-14	3.6-14
3.6-26	3.6-26
3.6-32	3.6-32
3.6-39	3.6-39
5.0-10	5.0-10

(5) Pursuant to the Act and 10 CFR Parts 30, 40, and 70, to possess, but not separate, such byproduct and special nuclear materials as may be produced by operation of the facility.

C. This license shall be deemed to contain and is subject to the conditions specified in the following Commission regulations in 10 CFR Chapter I: Part 20, Section 30.34 of Part 30, Section 40.41 of Part 40, Sections 50.54 and 50.59 of Part 50, and Section 70.32 of Part 70; is subject to all applicable provisions of the Act and to the rules, regulations, and orders of the Commission now or hereafter in effect; and is subject to the additional conditions specified or incorporated below:

(1) Maximum Power Level

The licensee is authorized to operate the facility at steady state reactor core power levels not in excess of 2419 megawatts (thermal).

(2) Technical Specifications

The Technical Specifications contained in Appendix A as revised through Amendment No. 259, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

(3) Physical Protection

The licensee shall fully implement and maintain in effect all provisions of the Commission-approved physical security, training and qualification and safeguards contingency plans including amendments made pursuant to provisions of the Miscellaneous Amendments and Search Requirements revisions to 10 CFR 73.55 (51 FR 27817 and 27822) and to the authority of 10 CFR 50.90 and 10 CFR 50.54(p). The combined set of plans, which contain Safeguards Information protected under 10 CFR 73.21, are entitled: "Cooper Nuclear Station Safeguards Plan," submitted by letter dated May 17, 2006.

NPPD shall fully implement and maintain in effect all provisions of the Commission-approved cyber security plan (CSP), including changes made pursuant to the authority of 10 CFR 50.90 and 10 CFR 50.54(p). The NPPD CSP was approved by License Amendment No. 238 as supplemented by changes approved by License Amendments 244 and 249.

(4) Fire Protection

NPPD shall implement and maintain in effect all provisions of the approved fire protection program that comply with 10 CFR 50.48(a) and 10 CFR 50.48(c), as specified in the license amendment request dated April 24, 2012 (and supplements dated July 12, 2012, January 14, 2013, February 12, 2013, March 13, 2013, June 13, 2013, December 12, 2013, January 17, 2014, February 18, 2014, and April 11, 2014), and as approved in the safety evaluation dated April 29, 2014. Except where NRC approval for changes or deviations is required by 10 CFR 50.48(c), and provided no other regulation, technical specification, license condition or requirement would require prior NRC approval, the licensee may make changes to the fire protection program without prior approval of the Commission if

1.1 Definitions

DOSE EQUIVALENT I-131 (continued)	I-133, I-134, and I-135 actually present. The DOSE EQUIVALENT I-131 concentration is calculated as follows: DOSE EQUIVALENT I-131 = (I-131) + 0.0060 (I-132) + 0.17 (I-133) + 0.0010 (I-134) + 0.029 (I-135). The dose conversion factors used for this calculation are those listed in Federal Guidance Report (FGR) 11, "Limiting Values of Radionuclide Intake and Air Concentration and Dose Conversion Factors for Inhalation, Submersion, and Ingestion," 1989.
INSERVICE TESTING PROGRAM	The INSERVICE TESTING PROGRAM is the licensee program that fulfills the requirements of 10 CFR 50.55a(f).
LEAKAGE	LEAKAGE shall be: <ul style="list-style-type: none"> a. <u>Identified LEAKAGE</u> <ul style="list-style-type: none"> 1. LEAKAGE into the drywell, such as that from pump seals or valve packing, that is captured and conducted to a sump or collecting tank; or 2. LEAKAGE into the drywell atmosphere from sources that are both specifically located and known either not to interfere with the operation of leakage detection systems or not to be pressure boundary LEAKAGE; b. <u>Unidentified LEAKAGE</u> All LEAKAGE into the drywell that is not identified LEAKAGE; c. <u>Total LEAKAGE</u> Sum of the identified and unidentified LEAKAGE; d. <u>Pressure Boundary LEAKAGE</u> LEAKAGE through a nonisolable fault in a Reactor Coolant System (RCS) component body, pipe wall, or vessel wall.
LINEAR HEAT GENERATION RATE (LHGR)	The LHGR shall be the heat generation rate per unit length of fuel rod. It is the integral of the heat flux over the heat transfer area associated with the unit length.

(continued)

1.1 Definitions

LOGIC SYSTEM FUNCTIONAL TEST	A LOGIC SYSTEM FUNCTIONAL TEST shall be a test of all logic components required for OPERABILITY of a logic circuit, from as close to the sensor as practicable up to, but not including, the actuated device, to verify OPERABILITY. The LOGIC SYSTEM FUNCTIONAL TEST may be performed by means of any series of sequential, overlapping, or total system steps so that the entire logic system is tested.
MINIMUM CRITICAL POWER RATIO (MCPR)	The MCPR shall be the smallest critical power ratio (CPR) that exists in the core for each class of fuel. The CPR is that power in the assembly that is calculated by application of the appropriate correlation(s) to cause some point in the assembly to experience boiling transition, divided by the actual assembly operating power.
MODE	A MODE shall correspond to any one inclusive combination of mode switch position, average reactor coolant temperature, and reactor vessel head closure bolt tensioning specified in Table 1.1-1 with fuel in the reactor vessel.
OPERABLE – OPERABILITY	A system, subsystem, division, component, or device shall be OPERABLE or have OPERABILITY when it is capable of performing its specified safety function(s) and when all necessary attendant instrumentation, controls, normal or emergency electrical power, cooling and seal water, lubrication, and other auxiliary equipment that are required for the system, subsystem, division, component, or device to perform its specified safety function(s) are also capable of performing their related support function(s).
PRESSURE AND TEMPERATURE LIMITS REPORT (PTLR)	The PTLR is the unit specific document that provides the reactor vessel pressure and temperature limits, including heatup and cooldown rates, for the current reactor vessel fluence period. These pressure and temperature limits shall be determined for each fluence period in accordance with Specification 5.6.7.
RATED THERMAL POWER (RTP)	RTP shall be a total reactor core heat transfer rate to the reactor coolant of 2419 MWt.
REACTOR PROTECTION SYSTEM (RPS) RESPONSE TIME	The RPS RESPONSE TIME shall be that time segment from the time the sensor contacts actuate to the time the scram solenoid valves deenergize.
SHUTDOWN MARGIN (SDM)	SDM shall be the amount of reactivity by which the reactor is subcritical or would be subcritical throughout the operating cycle assuming that:

(continued)

1.1 Definitions

SHUTDOWN MARGIN (SDM)
(continued)

- a. The reactor is xenon free;
- b. The moderator temperature is $\geq 68^{\circ}\text{F}$, corresponding to the most reactive state; and
- c. All control rods are fully inserted except for the single control rod of highest reactivity worth, which is assumed to be fully withdrawn.

With control rods not capable of being fully inserted, the reactivity worth of these control rods must be accounted for in the determination of SDM.

THERMAL POWER

THERMAL POWER shall be the total reactor core heat transfer rate to the reactor coolant.

**TURBINE BYPASS SYSTEM
RESPONSE TIME**

The **TURBINE BYPASS SYSTEM RESPONSE TIME** consists of two components:

- a. The time from initial movement of the main turbine stop valve or control valve until 80% of the turbine bypass capacity is established; and
- b. The time from initial movement of the main turbine stop valve or control valve until initial movement of the turbine bypass valve.

The response time may be measured by means of any series of sequential, overlapping, or total steps so that the entire response time is measured.

SURVEILLANCE REQUIREMENTS (continued)

SURVEILLANCE		FREQUENCY
(continued)		Once within 24 hours after solution temperature is restored within the limits of Figure 3.1.7-2
SR 3.1.7.6	Verify each SLC subsystem manual valve in the flow path that is not locked, sealed, or otherwise secured in position, is in the correct position or can be aligned to the correct position.	In accordance with the Surveillance Frequency Control Program
SR 3.1.7.7	Verify each pump develops a flow rate ≥ 38.2 gpm at a discharge pressure ≥ 1300 psig.	In accordance with the INSERVICE TESTING PROGRAM
SR 3.1.7.8	Verify flow through one SLC subsystem from pump into reactor pressure vessel.	In accordance with the Surveillance Frequency Control Program
SR 3.1.7.9	Verify all heat traced piping between storage tank and pump suction is unblocked.	In accordance with the Surveillance Frequency Control Program <u>AND</u> Once within 24 hours after solution temperature is restored within the limits of Figure 3.1.7-2

SURVEILLANCE REQUIREMENTS

SURVEILLANCE		FREQUENCY								
SR 3.4.3.1	Verify the safety function lift setpoints of the SRVs and SVs are as follows:	In accordance with the INSERVICE TESTING PROGRAM								
	<table border="1"> <thead> <tr> <th>Number of SRVs</th> <th>Setpoint (psig)</th> </tr> </thead> <tbody> <tr> <td style="text-align: center;">2</td> <td style="text-align: center;">1080 ± 32.4</td> </tr> <tr> <td style="text-align: center;">3</td> <td style="text-align: center;">1090 ± 32.7</td> </tr> <tr> <td style="text-align: center;">3</td> <td style="text-align: center;">1100 ± 33.0</td> </tr> </tbody> </table>		Number of SRVs	Setpoint (psig)	2	1080 ± 32.4	3	1090 ± 32.7	3	1100 ± 33.0
	Number of SRVs		Setpoint (psig)							
	2		1080 ± 32.4							
	3		1090 ± 32.7							
3	1100 ± 33.0									
<table border="1"> <thead> <tr> <th>Number of SVs</th> <th>Setpoint (psig)</th> </tr> </thead> <tbody> <tr> <td style="text-align: center;">3</td> <td style="text-align: center;">1240 ± 37.2</td> </tr> </tbody> </table>	Number of SVs	Setpoint (psig)	3	1240 ± 37.2						
Number of SVs	Setpoint (psig)									
3	1240 ± 37.2									
Following testing, lift settings shall be within ± 1%.										
SR 3.4.3.2	<p style="text-align: center;">-----NOTE-----</p> <p>Not required to be performed until 12 hours after reactor steam pressure and flow are adequate to perform the test.</p> <p style="text-align: center;">-----</p> <p>Verify each SRV opens when manually actuated.</p>	In accordance with the Surveillance Frequency Control Program								

SURVEILLANCE REQUIREMENTS (continued)

SURVEILLANCE		FREQUENCY																
SR 3.5.1.6	<p>Verify the following ECCS pumps develop the specified flow rate against a system head corresponding to the specified reactor pressure.</p> <table border="1"> <thead> <tr> <th><u>SYSTEM</u></th> <th><u>FLOW RATE</u></th> <th><u>NO. OF PUMPS</u></th> <th><u>SYSTEM HEAD CORRESPONDING TO A REACTOR PRESSURE OF</u></th> </tr> </thead> <tbody> <tr> <td>Core</td> <td></td> <td></td> <td></td> </tr> <tr> <td>Spray</td> <td>≥ 4720 gpm</td> <td>1</td> <td>≥ 113 psig</td> </tr> <tr> <td>LPCI</td> <td>≥ 15,000 gpm</td> <td>2</td> <td>≥ 20 psig</td> </tr> </tbody> </table>	<u>SYSTEM</u>	<u>FLOW RATE</u>	<u>NO. OF PUMPS</u>	<u>SYSTEM HEAD CORRESPONDING TO A REACTOR PRESSURE OF</u>	Core				Spray	≥ 4720 gpm	1	≥ 113 psig	LPCI	≥ 15,000 gpm	2	≥ 20 psig	In accordance with the INSERVICE TESTING PROGRAM
<u>SYSTEM</u>	<u>FLOW RATE</u>	<u>NO. OF PUMPS</u>	<u>SYSTEM HEAD CORRESPONDING TO A REACTOR PRESSURE OF</u>															
Core																		
Spray	≥ 4720 gpm	1	≥ 113 psig															
LPCI	≥ 15,000 gpm	2	≥ 20 psig															
SR 3.5.1.7	<p>-----NOTE-----</p> <p>Not required to be performed until 12 hours after reactor steam pressure and flow are adequate to perform the test.</p> <p>-----</p> <p>Verify, with reactor pressure ≤ 1020 and ≥ 920 psig, the HPCI pump can develop a flow rate ≥ 4250 gpm against a system head corresponding to reactor pressure.</p>	In accordance with the Surveillance Frequency Control Program																
SR 3.5.1.8	<p>-----NOTE-----</p> <p>Not required to be performed until 12 hours after reactor steam pressure and flow are adequate to perform the test.</p> <p>-----</p> <p>Verify, with reactor pressure ≤ 165 psig, the HPCI pump can develop a flow rate ≥ 4250 gpm against a system head corresponding to reactor pressure.</p>	In accordance with the Surveillance Frequency Control Program																

(continued)

SURVEILLANCE REQUIREMENTS (continued)

SURVEILLANCE		FREQUENCY												
SR 3.5.2.4	<p>Verify each required ECCS pump develops the specified flow rate against a system head corresponding to the specified reactor pressure.</p> <table border="1"> <thead> <tr> <th><u>SYSTEM</u></th> <th><u>FLOW RATE</u></th> <th><u>NO. OF PUMPS</u></th> <th><u>SYSTEM HEAD CORRESPONDING TO A REACTOR PRESSURE OF</u></th> </tr> </thead> <tbody> <tr> <td>CS</td> <td>≥ 4720 gpm</td> <td>1</td> <td>≥ 113 psig</td> </tr> <tr> <td>LPCI</td> <td>≥ 7700 gpm</td> <td>1</td> <td>≥ 20 psig</td> </tr> </tbody> </table>	<u>SYSTEM</u>	<u>FLOW RATE</u>	<u>NO. OF PUMPS</u>	<u>SYSTEM HEAD CORRESPONDING TO A REACTOR PRESSURE OF</u>	CS	≥ 4720 gpm	1	≥ 113 psig	LPCI	≥ 7700 gpm	1	≥ 20 psig	<p>In accordance with the INSERVICE TESTING PROGRAM</p>
<u>SYSTEM</u>	<u>FLOW RATE</u>	<u>NO. OF PUMPS</u>	<u>SYSTEM HEAD CORRESPONDING TO A REACTOR PRESSURE OF</u>											
CS	≥ 4720 gpm	1	≥ 113 psig											
LPCI	≥ 7700 gpm	1	≥ 20 psig											
SR 3.5.2.5	<p>-----NOTE----- Vessel injection/spray may be excluded. -----</p> <p>Verify each required ECCS injection/spray subsystem actuates on an actual or simulated automatic initiation signal.</p>	<p>In accordance with the Surveillance Frequency Control Program</p>												

SURVEILLANCE REQUIREMENTS (continued)

SURVEILLANCE		FREQUENCY
SR 3.6.1.3.3	<p style="text-align: center;">-----NOTES-----</p> <ol style="list-style-type: none"> 1. Valves and blind flanges in high radiation areas may be verified by use of administrative means. 2. Not required to be met for PCIVs that are open under administrative controls. <p>-----</p> <p>Verify each primary containment manual isolation valve and blind flange that is located inside primary containment and not locked, sealed, or otherwise secured and is required to be closed during accident conditions is closed.</p>	<p>Prior to entering MODE 2 or 3 from MODE 4 if primary containment was de-inerted while in MODE 4, if not performed within the previous 92 days</p>
SR 3.6.1.3.4	<p>Verify continuity of the traversing incore probe (TIP) shear isolation valve explosive charge.</p>	<p>In accordance with the Surveillance Frequency Control Program</p>
SR 3.6.1.3.5	<p>Verify the isolation time of each power operated, automatic PCIV, except for MSIVs, is within limits.</p>	<p>In accordance with the INSERVICE TESTING PROGRAM</p>

(continued)

SURVEILLANCE REQUIREMENTS (continued)

SURVEILLANCE		FREQUENCY
SR 3.6.1.3.6	Verify the isolation time of each MSIV is ≥ 3 seconds and ≤ 5 seconds.	In accordance with the INSERVICE TESTING PROGRAM
SR 3.6.1.3.7	Verify each automatic PCIV actuates to the isolation position on an actual or simulated isolation signal.	In accordance with the Surveillance Frequency Control Program
SR 3.6.1.3.8	Verify a representative sample of reactor instrumentation line EFCVs actuate to the isolation position on an actual or simulated instrument line break.	In accordance with the Surveillance Frequency Control Program
SR 3.6.1.3.9	Remove and test the explosive squib from each shear isolation valve of the TIP System.	In accordance with the Surveillance Frequency Control Program
SR 3.6.1.3.10	Verify leakage rate through each Main Steam line is ≤ 106 scfh when tested at ≥ 29 psig.	In accordance with the Primary Containment Leakage Rate Testing Program

(continued)

SURVEILLANCE REQUIREMENTS

SURVEILLANCE		FREQUENCY
SR 3.6.1.9.1	Verify each RHR containment spray subsystem manual, power operated, and automatic valve in the flow path that is not locked, sealed, or otherwise secured in position, is in the correct position or can be aligned to the correct position.	In accordance with the Surveillance Frequency Control Program
SR 3.6.1.9.2	Verify each required RHR pump develops a flow rate of > 7700 gpm through the associated heat exchanger while operating in the suppression pool cooling mode.	In accordance with the INSERVICE TESTING PROGRAM
SR 3.6.1.9.3	Verify each spray nozzle is unobstructed.	Following maintenance which could result in nozzle blockage

SURVEILLANCE REQUIREMENTS

SURVEILLANCE		FREQUENCY
SR 3.6.2.3.1	Verify each RHR suppression pool cooling subsystem manual, power operated, and automatic valve in the flow path that is not locked, sealed, or otherwise secured in position, is in the correct position or can be aligned to the correct position.	In accordance with the Surveillance Frequency Control Program
SR 3.6.2.3.2	Verify each RHR pump develops a flow rate > 7700 gpm through the associated heat exchanger while operating in the suppression pool cooling mode.	In accordance with the INSERVICE TESTING PROGRAM

SURVEILLANCE REQUIREMENTS

SURVEILLANCE		FREQUENCY
SR 3.6.4.2.1	<p style="text-align: center;">-----NOTES-----</p> <ol style="list-style-type: none"> 1. Valves and blind flanges in high radiation areas may be verified by use of administrative means. 2. Not required to be met for SCIVs that are open under administrative controls. <p>-----</p> <p>Verify each secondary containment isolation manual valve and blind flange that is not locked, sealed, or otherwise secured and is required to be closed during accident conditions is closed.</p>	In accordance with the Surveillance Frequency Control Program
SR 3.6.4.2.2	Verify the isolation time of each power operated automatic SCIV is within limits.	In accordance with the INSERVICE TESTING PROGRAM
SR 3.6.4.2.3	Verify each automatic SCIV actuates to the isolation position on an actual or simulated actuation signal.	In accordance with the Surveillance Frequency Control Program

5.5 Programs and Manuals (continued)

5.5.6 (Deleted)

(continued)



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION

RELATED TO AMENDMENT NO. 259 TO

FACILITY OPERATING LICENSE NO. DPR-46

NEBRASKA PUBLIC POWER DISTRICT

COOPER NUCLEAR STATION

DOCKET NO. 50-298

1.0 INTRODUCTION

By application dated August 26, 2016 (Agencywide Documents Access and Management System (ADAMS) Accession No. ML16245A288), Nebraska Public Power District (NPPD, the licensee), requested changes to the technical specifications (TSs) for Cooper Nuclear Station (CNS). Specifically, the licensee requested changes to the TSs consistent with Technical Specifications Task Force (TSTF) Standard Technical Specifications (STS) Change Traveler TSTF-545, Revision 3, "TS Inservice Testing Program Removal & Clarify SR [Surveillance Requirement] Usage Rule Application to Section 5.5 Testing," dated October 21, 2015 (ADAMS Accession No. ML15294A555).

The licensee's proposed changes delete CNS TS 5.5.6, "Inservice Testing Program," and add a new defined term, "INSERVICE TESTING PROGRAM," to the TSs. All existing references to the "Inservice Testing Program" in the CNS TS SRs are replaced with "INSERVICE TESTING PROGRAM" so that the SRs refer to the new definition in lieu of the deleted program.

2.0 REGULATORY EVALUATION

2.1 Description of Inservice Testing Requirements and TSTF-545

An inservice test is a test to assess the operational readiness of a structure, system, or component after first electrical generation by nuclear heat. The American Society of Mechanical Engineers (ASME) Code for Operation and Maintenance of Nuclear Power Plants (ASME OM Code) provides requirements for inservice testing of certain components in light-water nuclear power plants. The ASME OM Code identifies the components subject to the testing (i.e., pumps, valves, pressure relief devices, and dynamic restraints), responsibilities, methods, intervals, parameters to be measured and evaluated, criteria for evaluating results, corrective actions, personnel qualification, and recordkeeping. Title 10 of the *Code of Federal Regulations* (10 CFR) paragraph 50.55a(f), "Inservice testing requirements," requires that inservice testing of certain ASME Code Class 1, 2, and 3 components must meet the requirements of the ASME OM Code and applicable addenda. The facility's TSs also prescribe inservice testing requirements and frequencies for ASME Code Class 1, 2, and 3 components.

The regulation in 10 CFR 50.55a(f)(5)(ii) states, in part, "If a revised inservice test program for a facility conflicts with the technical specifications for the facility, the licensee must apply to the

Commission for amendment of the technical specifications to conform the technical specifications to the revised program.” TSTF-545, Revision 3, provides guidance to licensees on how to request license amendments that would eliminate conflicting requirements between 10 CFR 50.55a, “Codes and standards,” and the TSs. TSTF-545, Revision 3, proposes elimination of the Inservice Testing Program from the Administrative Controls section of the TSs. The TSs contain surveillances that require testing or test intervals in accordance with the Inservice Testing Program. The elimination of the Inservice Testing Program from the TSs could cause uncertainty regarding the correct application of these SRs. Therefore, TSTF-545, Revision 3, also proposes adding a new definition, “INSERVICE TESTING PROGRAM,” to the TSs, which would be defined as “the licensee program that fulfills the requirements of 10 CFR 50.55a(f).” TSTF-545, Revision 3, proposes replacement of existing uses of the term, “Inservice Testing Program,” with the defined term, as denoted by capitalized letters, throughout the TSs.

The U.S. Nuclear Regulatory Commission (NRC) approved TSTF-545, Revision 3, by letter dated December 11, 2015 (ADAMS Package Accession No. ML15317A071), and published a notice of availability in the *Federal Register* (FR) on March 28, 2016 (81 FR 17208).

2.2 Proposed Technical Specifications Changes

The licensee requested to delete TS 5.5.6 from the Administrative Controls section of TSs and replace it with the word “(Deleted).” TS 5.5.6 currently states:

This program provides controls for inservice testing of ASME Code Class 1, 2, and 3 pumps and valves:

- a. Testing Frequencies applicable to the ASME Code for Operation and Maintenance of Nuclear Power Plants (ASME OM Code) and applicable Addenda are as follows:

<u>ASME OM Code and applicable Addenda terminology for inservice testing activities</u>	<u>Required Frequencies for performing inservice testing activities</u>
Weekly	At least once per 7 days
Monthly	At least once per 31 days
Quarterly or every 3 months	At least once per 92 days
Semiannually or every 6 months	At least once per 184 days
Every 9 months	At least once per 276 days
Yearly or annually	At least once per 366 days
Biennially or every 2 years	At least once per 731 days

- b. The provisions of SR 3.0.2 are applicable to the above required Frequencies and to other normal and accelerated Frequencies specified as 2 years or less in the Inservice Testing Program for performing inservice testing activities;

- c. The provisions of SR 3.0.3 are applicable to inservice testing activities; and
- d. Nothing in the ASME OM Code shall be construed to supersede the requirements of any TS.

SR 3.0.2 allows an extension of inservice testing intervals by up to 25 percent. If it is discovered that a surveillance associated with an inservice testing activity was not performed within the required interval, SR 3.0.3 allows the licensee to delay declaring the associated limiting condition for operation not met in order to perform the missed surveillance. The licensee did not request changes to SR 3.0.2 or SR 3.0.3.

The licensee requested to revise the Definitions section of TSs by adding the term, "INSERVICE TESTING PROGRAM," with the following definition: "The INSERVICE TESTING PROGRAM is the licensee program that fulfills the requirements of 10 CFR 50.55a(f)." The licensee also requested that all existing occurrences of "Inservice Testing Program" in TS SRs be replaced with "INSERVICE TESTING PROGRAM," so that the SRs refer to the new definition in lieu of the deleted program.

2.3 Regulatory Requirements and Guidance

The NRC staff considered the following regulatory requirements, guidance, and licensing information during its review of the proposed changes:

Technical Specifications

Paragraph 50.36(c) of 10 CFR requires TSs to include the following categories: (1) safety limits, limiting safety systems settings, and control settings; (2) limiting conditions for operation; (3) SRs; (4) design features; (5) administrative controls; (6) decommissioning; (7) initial notification; and (8) written reports. Section 50.36(c)(3) of 10 CFR states that "[s]urveillance requirements are requirements relating to test, calibration, or inspection to assure that the necessary quality of systems and components is maintained, that facility operation will be within safety limits, and that the limiting conditions for operation will be met." Section 50.36(c)(5) of 10 CFR states that "[a]dministrative controls are the provisions relating to organization and management, procedures, recordkeeping, review and audit, and reporting necessary to assure operation of the facility in a safe manner."

The NRC staff's guidance for review of the TSs is in NUREG-0800, "Standard Review Plan for the Review of Safety Analysis Reports for Nuclear Power Plants: LWR [Light-Water Reactor] Edition," Chapter 16, "Technical Specifications," Revision 3, dated March 2010 (ADAMS Accession No. ML100351425). As described therein, as part of the regulatory standardization effort, the staff has prepared improved STSs for each of the LWR nuclear steam supply systems and associated balance-of-plant equipment systems. The licensee's proposed amendment is based on TSTF-545, Revision 3, which is an NRC-approved change to the improved STSs. The staff's review includes consideration of whether the proposed changes are consistent with TSTF-545, Revision 3. Special attention is given to TS provisions that depart from the improved STSs, as modified by NRC-approved TSTF travelers, to determine whether proposed differences are justified by uniqueness in plant design or other considerations so that 10 CFR 50.36 is met. In addition, the guidance states that comparing the change to previous STS can help clarify the TS intent.

Inservice Testing

Pursuant to 10 CFR 50.54, "Conditions of licenses," the applicable requirements of 10 CFR 50.55a are conditions of every nuclear power reactor operating license issued under 10 CFR Part 50. These requirements include inservice testing of pumps and valves at nuclear power reactors in accordance with the ASME OM Code as specified in 10 CFR 50.55a(f). The regulations in 10 CFR 50.55a(f) state, in part:

Systems and components of boiling and pressurized water-cooled nuclear power reactors must meet the requirements of the ASME BPV [Boiler and Pressure Vessel] Code and ASME Code for Operation and Maintenance of Nuclear Power Plants as specified in this paragraph. Each operating license for a boiling or pressurized water-cooled nuclear facility is subject to the following conditions [referring to 10 CFR 50.55a(f)(1) through (f)(6)]. . . .

The ASME OM Code is a consensus standard, which is incorporated by reference into 10 CFR 50.55a. During the incorporation process, the NRC staff reviewed the ASME OM Code requirements for technical sufficiency and found that the ASME OM Code inservice testing program requirements were suitable for incorporation into the NRC's rules.

The regulation in 10 CFR 50.55(a)(f)(5)(ii) states, in part: "If a revised inservice test program for a facility conflicts with the technical specifications for the facility, the licensee must apply to the Commission for amendment of the technical specifications to conform the technical specifications to the revised program."

NUREG-1482, Revision 2, "Guidelines for Inservice Testing at Nuclear Power Plants: Inservice Testing of Pumps and Valves and Inservice Examination and Testing of Dynamic Restraints (Snubbers) at Nuclear Power Plants," Final Report, October 2013 (ADAMS Accession No. ML13295A020) provides guidance for the inservice testing of pumps and valves.

NUREG-0800, Section 3.9.6, "Functional Design, Qualification, and Inservice Testing Programs for Pumps, Valves, and Dynamic Restraints," Revision 3, March 2007 (ADAMS Accession No. ML070720041), provides guidance and acceptance criteria for the NRC staff review of the inservice testing program for pumps and valves.

3.0 TECHNICAL EVALUATION

The NRC staff evaluated the licensee's application to determine if the proposed changes are consistent with the guidance, regulations, and licensing information discussed in Section 2.3 of this safety evaluation. In determining whether an amendment to a license will be issued, the Commission is guided by the considerations that govern the issuance of initial licenses to the extent applicable and appropriate. Among the considerations are whether the TSs, as amended, would provide the necessary administrative controls per 10 CFR 50.36(c)(5) (i.e., provisions relating to organization and management, procedures, recordkeeping, review and audit, and reporting necessary to assure operation of the facility in a safe manner). In making its determination as to whether to amend the license, the staff considered those regulatory requirements that are automatically conditions of the license through 10 CFR 50.54. Where the regulations already condition the license, there is no need for a duplicative requirement in the TSs; the regulations provide the necessary reasonable assurance of the health and safety of the public.

3.1 Deletion of the Inservice Testing Program from the TSs

TS 5.5.6 requires the licensee to have an inservice testing program that provides controls for inservice testing of ASME Code Class 1, 2, and 3 components (i.e., pumps and valves). Through 10 CFR 50.54, the applicable requirements of 10 CFR 50.55a are conditions of every nuclear power reactor operating license issued under 10 CFR Part 50. These requirements include 10 CFR 50.55a(f), which specifies the requirements for the inservice testing of pumps and valves. Therefore, requiring the licensee to have an inservice testing program in TSs is duplicative of the license condition in 10 CFR 50.54. Thus, with the proposed TS changes, the licensee will still be required to maintain an inservice testing program in accordance with the ASME OM Code, as specified in 10 CFR 50.55a(f). For the reasons explained below, it is not necessary to have additional administrative controls in the TSs relating to the inservice testing program to assure operation of the facility in a safe manner.

Consideration of TS 5.5.6.a

The ASME OM Code requires testing to normally be performed within certain time periods. TS 5.5.6.a sets inservice testing frequencies more precisely than those specified in the ASME OM Code and applicable addenda (e.g., “at least once per 31 days” contrasted with “monthly”). However, the NRC staff determined that the more precise inservice testing frequencies are not necessary to assure operation of the facility in a safe manner. Therefore, the NRC staff determined that deletion of TS 5.5.6.a is acceptable.

Consideration of TS 5.5.6.b

TS 5.5.6.b allows the licensee to extend, by up to 25 percent, the interval between inservice testing activities, as required by TS 5.5.6.a and for other normal and accelerated frequencies specified as 2 years or less in the inservice testing program. Similar to TS 5.5.6.b, the NRC authorization of ASME Code Case OMN-20, “Inservice Test Frequency,” by letter dated February 12, 2016 (ADAMS Accession No. ML16014A174), also permits the licensee to extend the inservice testing intervals specified in the ASME OM Code by up to 25 percent.

The NRC staff determined that the TS 5.5.6.b allowance to extend inservice testing intervals is not needed to assure operation of the facility in a safe manner. Therefore, the NRC staff determined that deletion of TS 5.5.6.b is acceptable. The deletion of TS 5.5.6.b does not impact the licensee’s ability to extend inservice testing intervals using Code Case OMN-20, as authorized by the NRC.

Consideration of TS 5.5.6.c

TS 5.5.6.c allows the licensee to use SR 3.0.3 when it discovers that an SR associated with an inservice test was not performed within its specified frequency. SR 3.0.3 allows the licensee to delay declaring a limiting condition for operation not met in order to perform the missed surveillance. The use of SR 3.0.3 for inservice tests is limited to those inservice tests required by an SR. In accordance with 10 CFR 50.55a, the licensee may also request relief from the ASME OM Code requirements to address issues associated with a missed inservice test. Deletion of TS 5.5.6.c does not change any of these requirements, and SR 3.0.3 will continue to apply to those inservice tests required by SRs. Based on the above, the NRC staff determined that deletion of TS 5.5.6.c is acceptable.

Consideration of TS 5.5.6.d

TS 5.5.6.d states that nothing in the ASME OM Code shall be construed to supersede the requirements of any TS. However, the regulations in 10 CFR 50.55a(f)(5)(ii) address what to do if a revised inservice testing program for a facility conflicts with the TSs for the facility; they require the licensee to apply for an amendment to the TSs to conform the TSs to the revised program at least 6 months prior to the start of the period for which the provisions become applicable. Accordingly, there is no need for a TS stating how to address conflicts between the TSs and the inservice testing program because the regulations specify how conflicts must be resolved.

Conclusion Regarding Deletion of TS 5.5.6

The NRC staff determined that the requirements currently in TS 5.5.6 are not necessary to assure operation of the facility in a safe manner. Based on this evaluation, the staff concludes that deletion of TS 5.5.6 from the licensee's TSs is acceptable, because TS 5.5.6 is not required by 10 CFR 50.36(c)(5).

3.2 Definition of INSERVICE TESTING PROGRAM and Revision to SRs

The licensee proposes to revise the TS Definitions section to include the term, "INSERVICE TESTING PROGRAM," with the following definition: "The INSERVICE TESTING PROGRAM is the licensee program that fulfills the requirements of 10 CFR 50.55a(f)." The proposed definition of the INSERVICE TESTING PROGRAM is consistent with the definition in TSTF-545, Revision 3. The definition is acceptable to the NRC staff because it correctly refers to the inservice testing requirements in 10 CFR 50.55a(f).

The licensee requested that all existing references to the "Inservice Testing Program" in SRs be revised to "INSERVICE TESTING PROGRAM" to reference the new TS defined term in lieu of the deleted program. The proposed change is consistent with the intent of TSTF-545, Revision 3, to replace the current references in SRs with the new definition. The NRC staff verified that for each SR reference to the "Inservice Testing Program," the licensee proposed to change the reference to "INSERVICE TESTING PROGRAM." The proposed change does not alter how the SR testing is performed. However, the inservice testing frequencies could change because the TSs will no longer include the more precise test frequencies in TS 5.5.6.a. As discussed in Section 3.1 of this safety evaluation, the staff determined that the TSs do not need to include the more precise testing frequencies currently in TS 5.5.6.a. Based on its review, the staff determined that revising the SRs to refer to the new definition is acceptable because these SRs will continue to be performed in accordance with the requirements of 10 CFR 50.55a(f). The staff also determined that, with the proposed changes that allow less-precise testing frequencies, 10 CFR 50.36(c)(3) will continue to be met because the SRs will continue to ensure that the necessary quality of systems and components is maintained, that facility operation will be within safety limits, and that the limiting conditions for operation will be met.

3.3 Deviations from TSTF-545

In its application, the licensee identified the following deviations from TSTF-545, Revision 3:

- Since the CNS TS do not include SR 3.4.5.1, Reactor Coolant System Pressure Isolation Valve Leakage, as shown on the General Electric BWR [Boiling Water Reactor]/4 STS pages in TSTF-545, there will be no corresponding change to the CNS TS.
- General Electric BWR/4 STS SR 3.5.1.7 is numbered SR 3.5.1.6 in the CNS TS.
- General Electric BWR/4 STS SR 3.5.2.5 is numbered SR 3.5.2.4 in the CNS TS.
- General Electric BWR/4 STS SR 3.6.1.3.6 is numbered SR 3.6.1.3.5 in the CNS TS.
- General Electric BWR/4 STS SR 3.6.1.3.8 is numbered SR 3.6.1.3.6 in the CNS TS.
- General Electric BWR/4 STS section 3.6.2.4 is titled Residual Heat Removal (RHR) Suppression Pool Spray. The equivalent section in the CNS TS is numbered 3.6.1.9 and titled RHR Containment Spray.
- General Electric BWR/4 STS SR 3.6.2.4.2 is numbered SR 3.6.1.9.2 in the CNS TS.
- General Electric BWR/4 STS IST Program is section 5.5.7. The equivalent CNS TS section is 5.5.6.
- TSTF-545 deletes the IST [inservice testing] program TS 5.5.6 and re-numbers all subsequent TS programs. NPPD proposes to retain the TS 5.5.6 reference, now shown as “[(Deleted)],” and not change the subsequent TS program numbers.

The NRC staff finds that the proposed deviations are editorial in nature and the licensee's proposed TS changes remain consistent with the intent of TSTF-545, Revision 3. Therefore, the staff finds that the licensee's proposed TS changes are acceptable.

4.0 STATE CONSULTATION

In accordance with the Commission's regulations, the Nebraska State official was notified of the proposed issuance of the amendment on May 26, 2017. The State official had no comments.

5.0 ENVIRONMENTAL CONSIDERATION

The amendment changes requirements with respect to the installation or use of facility components located within the restricted area as defined in 10 CFR Part 20 and changes SRs. The NRC staff has determined that the amendment involves no significant increase in the

amounts and no significant change in the types of any effluents that may be released offsite, and that there is no significant increase in individual or cumulative occupational radiation exposure. The Commission has previously issued a proposed finding that the amendment involves no significant hazards consideration, and there has been no public comment on such finding published in the FR on November 8, 2016 (81 FR 78649). Accordingly, the amendment meets the eligibility criteria for categorical exclusion set forth in 10 CFR 51.22(c)(9). Pursuant to 10 CFR 51.22(b), no environmental impact statement or environmental assessment need be prepared in connection with the issuance of the amendment.

6.0 CONCLUSION

The Commission has concluded, based on the considerations discussed above, that: (1) there is reasonable assurance that the health and safety of the public will not be endangered by operation in the proposed manner, (2) there is reasonable assurance that such activities will be conducted in compliance with the Commission's regulations, and (3) the issuance of the amendment will not be inimical to the common defense and security or to the health and safety of the public.

Principal Contributors: Blake Purnell, NRR
Caroline Tilton, NRR
John Huang, NRR

Date: June 20, 2017

**SUBJECT: COOPER NUCLEAR STATION - ISSUANCE OF AMENDMENT
 RE: ADOPTION OF TECHNICAL SPECIFICATIONS TASK FORCE TRAVELER
 TSTF-545, REVISION 3, "TS INSERVICE TESTING PROGRAM REMOVAL &
 CLARIFY SR USAGE RULE APPLICATION TO SECTION 5.5 TESTING"
 (CAC NO. MF8321) DATED: JUNE 20, 2017**

DISTRIBUTION:

PUBLIC	RidsNrrDssStsb Resource	RidsRgn4MailCenter Resource
LPL4 Reading	RidsNrrDeEpn Resource	JHuang, NRR
RidsACRS_MailCTR Resource	RidsNrrLAPBlechman Resource	CTilton, NRR
RidsNrrDoriLp4 Resource	RidsNrrPMCooperResource	

ADAMS Accession No. ML17144A082***via e-mail**

OFFICE	NRR/DORL/LPL4/PM	NRR/DORL/LPL4/LA	NRR/DORL/LPL4/PM	NRR/DSS/STSB/BC(A)*
NAME	APulvirenti	PBlechman	TWengert	JWhitman
DATE	5/26/17	5/25/17	5/30/17	6/5/17
OFFICE	NRR/DE/EPNB/BC	OGC (NLO)	NRR/DORL/LPL4/BC	NRR/DORL/LPL4/PM
NAME	DAley	AGhosh	RPascarelli	TWengert
DATE	5/31/17	6/15/17	6/19/17	6/20/17

OFFICIAL RECORD COPY