

REGULATOR INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8512230241 DOC. DATE: 85/12/19 NOTARIZED: YES DOCKET #  
 FACIL: 50-388 Susquehanna Steam Electric Station, Unit 2, Pennsylv 05000388  
 AUTH. NAME AUTHOR AFFILIATION  
 KEISER, H. W. Pennsylvania Power & Light Co.  
 RECIP. NAME RECIPIENT AFFILIATION  
 ADENSAM, E. BWR Project Directorate 3

SUBJECT: Application for amend to License NPF-22, changing Tech Specs to lower MSIV isolation on reactor vessel water level & to Level 1 to reduce challenges to safety/relief valves, per NUREG-0737, Section II. K. 3. Fee paid.

DISTRIBUTION CODE: A046D COPIES RECEIVED: LTR 3 ENCL 37 SIZE: 4x6  
 TITLE: DR Submittal: TMI Action Plan Rgmt NUREG-0737 & NUREG-0660

NOTES: 1cy NMSS/FCAF/PM. LPDR 2cys Transcripts. 05000388  
 OL: 03/23/84

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	BWR PD3 PD 01	5 5	CAMPAGNONE	1 1
INTERNAL:	ACRS 34	10 10	ADM/LFMB	1 0
	ELD/HDS4	1 0	IE/DEPER DIR 33	1 1
	IE/DEPER/EPB	3 3	NRR BWR ADTS	1 1
	NRR PAULSON, W.	1 1	NRR PWR-A ADTS	1 1
	NRR PWR-B ADTS	1 1	NRR/DNET	1 1
	NRR/ORAS 1B	3 3	<u>REG FILE</u> 04	1 1
	RGN1	1 1		
EXTERNAL:	24X	1 1	LPDR 03	2 2
	NRC PDR 02	1 1	NSIC 05	1 1
NOTES:		3 3		

*Rec'd w/check \$150.00*

*Add:*

EB (LIAW)  
 PSB (L. HULMAN)  
 EICSB (SRINIVASAN)  
 RSB (ACTING)  
 FOB (VASSALLO)  
 AD - G. Lainas (Ltr only)

TOTAL NUMBER OF COPIES REQUIRED: LTR 46 ENCL 43

Faint text at the top left corner, possibly a header or title.

Handwritten scribbles and marks in the upper left quadrant.

Main body of faint, illegible text in the upper right section.

A large block of very faint text in the center of the page, appearing as a grid or list.

Handwritten scribbles and marks in the lower right quadrant.

Small handwritten scribbles or marks below the lower right quadrant.

Small handwritten scribbles or marks at the bottom center of the page.



Pennsylvania Power & Light Company

Two North Ninth Street • Allentown, PA 18101 • 215 / 770-5151

Harold W. Kelsner  
Vice President-Nuclear Operations  
215/770-7502

DEC 19 1985

Director of Nuclear Reactor Regulation  
Attention: Ms. E. Adensam, Project Director  
BWR Project Directorate No. 3  
Division of Licensing  
U.S. Nuclear Regulatory Commission  
Washington, D.C. 20555

SUSQUEHANNA STEAM ELECTRIC STATION  
PROPOSED AMENDMENT 30 TO LICENSE NO. NPF-22  
ER 100450 FILE 841-8  
PLA-2569

Docket No. 50-388

Dear Ms. Adensam:

The purpose of this letter is to propose a change to the Susquehanna SES Unit 2 Technical Specifications.

The specification in question is the MSIV isolation on reactor vessel water level. Currently, the Technical Specifications require isolation at Level 2 (reference Table 3.3.2-2); we propose that it be lowered to Level 1. The reason we are requesting the change is in order to reduce the number of challenges to our safety-relief valves. The change is consistent with NRC recommendations, in Item 16 of NUREG-0737 Section II.K.3, "Reduction of Challenges and Failures of Relief Valves-Feasibility Study and system Modification." Although the NRC has approved the generic issue via this document, an independent overview of our considerations relative to the FSAR safety analyses is provided via the No Significant Hazards Considerations below.

NO SIGNIFICANT HAZARDS CONSIDERATIONS

- I. The proposed changes do not involve a significant increase in the probability or consequences of an accident previously evaluated.

FSAR Chapters 5, 6, and 15 were reviewed to determine the impact of changing the MSIV closure setpoint on the transient and accident analyses. Seven MCPR transients and the loss of coolant accidents result in MSIV closures on L2 water level.

The transient events include generator load rejection with and without bypass, turbine trip with and without bypass, two recirculation pump trip, recirculation pump seizure, and loss of feedwater flow. The first six events result in a loss of feedwater flow due to the L8 feedwater pump trip followed by a rapid drop in water level due to the void

ADD:J  
A046  
3/37  
rec'd w/40400K  
\$1 150.00

8512230241 851219  
PDR ADOCK 05000388  
P PDR

Faint, illegible text at the top of the page, possibly a header or introductory paragraph.

Second block of faint, illegible text, appearing to be the main body of the document.

Third block of faint, illegible text at the bottom of the page, possibly a conclusion or footer.

DEC 19 1985

Page 2

SSES PLA-2569  
ER 100450 File 841-8  
Ms. E. Adensam

collapse after the L8 turbine trip and scram. The L2 setpoint is reached approximately 30 seconds later since the water level decreases slowly following the initial drop. Changing the MSIV closure setpoint to L1 will result in HPCI and RCIC initiation at 30 seconds with no MSIV closure. Water level will increase following the HPCI and RCIC injection and MSIV closure is not expected to occur for these six transients. Since the reactor is scrammed 30 seconds prior to the L2 trip, the MCPR has increased well above the safety limit. Therefore, changing the MSIV closure setpoint does not affect the thermal margin for the first six transients listed above. The loss of feedwater flow event results in a slightly different scenario. Upon loss of feedwater flow, the reactor water level decreases to the L3 setpoint which results in a reactor scram. Since the water level is at the L3 setpoint, the void collapse following the scram causes water level to drop to the L2 setpoint. Changing the MSIV closure setpoint to L1 will result in HPCI and RCIC initiation with no MSIV closure. Water level will increase following the HPCI and RCIC injection and the MSIV closure is not expected to occur. Since reactor power decreases prior to the scram due to the reduced core inlet subcooling and since the reactor scrammed a few seconds prior to water level reaching the L2 setpoint, the MCPR has increased well above the safety limit prior to the time L2 is reached. Therefore, changing the MSIV closure setpoint does not affect the thermal margin evaluation for the loss of feedwater flow event.

The loss of coolant accidents also result in a rapid drop in reactor water level. As stated in FSAR Table 6.3-1, a loss of offsite power is assumed coincident with the LOCA. Chapter 15 of the FSAR shows MSIV closure will occur upon a loss of auxiliary power. Therefore, changing the MSIV closure setpoint from L2 to L1 does not affect the LOCA analysis since the MSIVs close due to the loss of offsite power. For a LOCA with offsite power available, changing the MSIV closure setpoint from L2 to L1 will result in a faster pressure decrease which results in earlier low pressure ECCS injection and lower peak clad temperature.

- II. The proposed changes do not create the possibility of a new or different kind of accident from any accident previously evaluated.

As described above, the change involves revising the setpoint of a previously evaluated trip function. This item can change the results of a previous analysis, but cannot create a different type of accident.

- III. The proposed changes do not involve a significant reduction in a margin of safety.

This proposed modification reduces the probability of a malfunction of equipment. It will delay or eliminate MSIV closures for many transient events which will reduce the number of SRV openings and MSIV closures. Challenges to the HPCI and RCIC systems are reduced by preserving the availability of the feedwater system which allows the operator to suppress those systems' cyclical operation. This reduces the probability



11

1. The first part of the document discusses the importance of maintaining accurate records of all transactions. It emphasizes that every entry must be supported by proper documentation and that any discrepancies should be investigated immediately. The text also mentions the need for regular audits to ensure the integrity of the data.

2. The second part of the document outlines the procedures for handling confidential information. It states that all sensitive data must be stored securely and accessed only by authorized personnel. Employees are reminded to use strong passwords and to log out of systems when they are not in use. The document also discusses the consequences of a data breach and the steps that should be taken to mitigate any damage.

3. The third part of the document provides a detailed overview of the company's financial reporting process. It describes how data is collected from various departments and how it is consolidated into a single report. The text also explains the review process and the roles of different stakeholders in ensuring the accuracy and timeliness of the reports.

4. The fourth part of the document discusses the company's commitment to environmental sustainability. It outlines the various initiatives that have been implemented to reduce the company's carbon footprint, such as energy conservation programs and recycling efforts. The document also mentions the company's goal of achieving net-zero emissions by a certain date.

5. The fifth part of the document provides a summary of the key findings from the recent project. It highlights the areas where the project was successful and the challenges that were encountered. The text also offers recommendations for how the project can be improved in the future and how the lessons learned can be applied to other projects.

6. The sixth part of the document discusses the company's plans for the future. It outlines the various initiatives that are being undertaken to drive growth and innovation, such as research and development efforts and strategic partnerships. The document also mentions the company's commitment to social responsibility and its goal of creating a positive impact on society.

7. The seventh part of the document provides a detailed overview of the company's human resources strategy. It describes the various programs and initiatives that are being implemented to attract, develop, and retain top talent. The text also discusses the company's commitment to diversity and inclusion and its goal of creating a supportive and inclusive work environment.

8. The eighth part of the document discusses the company's approach to risk management. It outlines the various risks that the company faces and the steps that are being taken to identify, assess, and mitigate those risks. The document also mentions the company's commitment to transparency and its goal of providing stakeholders with accurate and timely information about the company's risk profile.

9. The ninth part of the document provides a detailed overview of the company's legal and compliance framework. It describes the various laws and regulations that the company is subject to and the steps that are being taken to ensure that the company is in full compliance with those laws and regulations. The document also mentions the company's commitment to ethical conduct and its goal of promoting a culture of integrity and accountability.

10. The tenth part of the document provides a detailed overview of the company's information technology strategy. It describes the various technologies that are being used to support the company's operations and the steps that are being taken to ensure that the company's IT systems are secure and reliable. The document also mentions the company's commitment to innovation and its goal of leveraging technology to drive growth and efficiency.

DEC 19 1985

Page 3

SSES PLA-2569  
ER 100450 File 841-8  
Ms. E. Adensam

of a stuck open relief valve and failure of HPCI, RCIC, or MSIVs.  
Therefore, safety margin is improved due to this change.

IMPLEMENTATION

In order to reduce challenges to safety systems as described above and as experienced during the December 2, 1985 scram of Unit 2, we request that this change be processed on a priority basis; we would like to be able to install it during the next available opportunity. At the latest, we request that this change be approved prior to the Unit 2 first refueling and inspection outage, during which we will perform this modification. In either case, we request that the change be conditioned to become effective upon completion of the modification, associated testing, and procedural updates.

Any questions on this proposal should be directed to Mr. R. Sgarro at (215) 770-7855. Pursuant to 10CFR170.22, the appropriate fee is enclosed.

Very truly yours,



H. W. Keiser  
Vice President-Nuclear Operations

Attachment

cc: M. J. Campagnone USNRC  
R. H. Jacobs USNRC

T. M. Gerusky, Director  
Bureau of Radiation Protection  
Pennsylvania Dept. of Environmental Resources  
P.O. Box 2063  
Harrisburg, PA 17120

1950

1951

1952



BEFORE THE  
UNITED STATES NUCLEAR REGULATORY COMMISSION

---

In the Matter of :

PENNSYLVANIA POWER &  
LIGHT COMPANY :

Docket No. 50-388

---

PROPOSED AMENDMENT NO. 30

FACILITY OPERATING LICENSE NO. NPF-22

SUSQUEHANNA STEAM ELECTRIC STATION  
UNIT NO. 2

---

Licensee, Pennsylvania Power & Light Company, hereby files proposed Amendment No. 30 to its Facility Operating License No. NPF-22 dated March 23, 1984.


This amendment contains a revision to the Susquehanna SES Unit 2 Technical Specifications.

PENNSYLVANIA POWER & LIGHT COMPANY  
BY:



H. W. Keiser  
Vice President - Nuclear Operations

Sworn to and subscribed before me  
this 19th of December, 1985.



Notary Public

MARTHA C. BARTO, Notary Public  
Allentown, Lehigh County, Pa.  
My Commission Expires Jan. 13, 1986



1970 10 10

10 10 1970

10 10 1970

10 10 1970

10 10 1970

10 10 1970

10 10 1970

10 10 1970

10 10 1970

10 10 1970

10 10 1970

10 10 1970