



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

PENNSYLVANIA POWER & LIGHT COMPANY

ALLEGHENY ELECTRIC COOPERATIVE, INC.

DOCKET NO. 50-387

SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 54
License No. NPF-14

1. The Nuclear Regulatory Commission (the Commission or the NRC) having found that:
 - A. The application for the amendment filed by the Pennsylvania Power & Light Company, dated November 26, 1985, as supplemented on January 15, 1986, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the regulations of the Commission;
 - C. There is reasonable assurance: (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations set forth in 10 CFR Chapter I;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment and paragraph 2.C.(2) of Facility Operating License No. NPF-14 is hereby amended to read as follows:

(2) Technical Specifications and Environmental Protection Plan

The Technical Specifications contained in Appendix A, as revised through Amendment No. 54 and the Environmental Protection Plan contained in Appendix B, are hereby incorporated in the license. PP&L shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

8602250156 860214
PDR ADDCK 05000387
P PDR

3. This amendment is effective as of the date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

Elinor G. Adensam

Elinor G. Adensam, Director
BWR Project Directorate No. 3
Division of BWR Licensing

Attachment:
Changes to the Technical
Specifications

Date of Issuance: FEB 14 1986

ATTACHMENT TO LICENSE AMENDMENT NO. 54

FACILITY OPERATING LICENSE NO. NPF-14

DOCKET NO. 50-387

Replace the following pages of the Appendix "A" Technical Specifications with enclosed pages. The revised pages are identified by Amendment number and contain vertical lines indicating the area of change. The corresponding overleaf page is also provided to maintain document completeness.

REMOVE

3/4 3-11
3/4 3-12

3/4 3-23
3/4 3-24

INSERT

3/4 3-11
3/4 3-12 (overleaf)

3/4 3-23
3/4 3-24 (overleaf)

TABLE 3.3.2-1
ISOLATION ACTUATION INSTRUMENTATION

<u>TRIP FUNCTION</u>	<u>ISOLATION SIGNAL(S)^(a)</u>	<u>MINIMUM OPERABLE CHANNELS PER TRIP SYSTEM (b)</u>	<u>APPLICABLE OPERATIONAL CONDITION</u>	<u>ACTION</u>
1. PRIMARY CONTAINMENT ISOLATION				
a. Reactor Vessel Water Level				
1) Low, Level 3	A	2	1, 2, 3	20
2) Low Low, Level 2	B	2	1, 2, 3	20
3) Low Low Low, Level 1	X	2	1, 2, 3	20
b. Drywell Pressure - High	Y,Z,X	2	1, 2, 3	20
c. Manual Initiation	NA	1	1, 2, 3	24
d. SGTS Exhaust Radiation-High	R	1	1, 2, 3,4***,5***	20
e. Main Steam Line Radiation-High	C	2	1, 2, 3	20
2. SECONDARY CONTAINMENT ISOLATION				
a. Reactor Vessel Water Level - Low Low, Level 2	**	2	1, 2, 3 and *	25
b. Drywell Pressure - High	**	2	1, 2, 3	25
c. Refuel Floor High Exhaust Duct Radiation - High	**	2	*	25
d. Railroad Access Shaft Exhaust Duct Radiation - High	**	2	*	25
e. Refuel Floor Wall Exhaust Duct Radiation - High	**	2	*	25
f. Manual Initiation	NA	1	1, 2, 3 and *	24

TABLE 3.3.2-1 (Continued)

ISOLATION ACTUATION INSTRUMENTATION

<u>TRIP FUNCTION</u>	<u>ISOLATION SIGNAL(S)^(a)</u>	<u>MINIMUM OPERABLE CHANNELS PER TRIP SYSTEM (b)</u>	<u>APPLICABLE OPERATIONAL CONDITION</u>	<u>ACTION</u>
3. MAIN STEAM LINE ISOLATION				
a. Reactor Vessel Water Level - Low, Low, Low, Level 1	X	2	1, 2, 3	21
b. Main Steam Line Radiation - High	C	2	1, 2, 3	21
c. Main Steam Line Pressure - Low	P	2	1	22
d. Main Steam Line Flow - High	D	2/line	1, 2, 3	20
e. Condenser Vacuum - Low	UA	2	1, 2, 3	21
f. Reactor Building Main Steam Line Tunnel Temperature - High	E	2	1, 2, 3	21
g. Reactor Building Main Steam Line Tunnel Δ Temperature - High	E	2	1, 2, 3	21
h. Manual Initiation	NA	1	1, 2, 3	24
i. Turbine Building Main Steam Line Tunnel Temperature-High	E	2	1, 2, 3	21
4. REACTOR WATER CLEANUP SYSTEM ISOLATION				
a. RWCU Δ Flow - High	J	1	1, 2, 3	23
b. RWCU Area Temperature - High	W	3	1, 2, 3	23
c. RWCU Area Ventilation Δ Temp. - High	W	3	1, 2, 3	23
d. SLCS Initiation	I	2	1, 2, 3	23
e. Reactor Vessel Water Level - Low Low, Level 2	B	2	1, 2, 3	23
f. RWCU Flow - High	J	1	1, 2, 3	23
g. Manual Initiation	NA	1	1, 2, 3	24

TABLE 4.3.2.1-1

ISOLATION ACTUATION INSTRUMENTATION SURVEILLANCE REQUIREMENTS

<u>TRIP FUNCTION</u>	<u>CHANNEL CHECK</u>	<u>CHANNEL FUNCTIONAL TEST</u>	<u>CHANNEL CALIBRATION</u>	<u>OPERATIONAL CONDITIONS FOR WHICH SURVEILLANCE REQUIRED</u>
1. <u>PRIMARY CONTAINMENT ISOLATION</u>				
a. Reactor Vessel Water Level -				
1) Low, Level 3	S	M	R	1, 2, 3
2) Low Low, Level 2	S	M	R	1, 2, 3
3) Low Low Low, Level 1	S	M	R	1, 2, 3
b. Drywell Pressure - High	NA	M	R	1, 2, 3
c. Manual Initiation	NA	R	NA	1, 2, 3
d. SGTS Exhaust Radiation - High	S	M	R	1, 2, 3, 4, 5,
e. Main Steam Line Radiation - High	S	M	R	1, 2, 3
2. <u>SECONDARY CONTAINMENT ISOLATION</u>				
a. Reactor Vessel Water Level - Low Low, Level 2	S	M	R	1, 2, 3 and *
b. Drywell Pressure - High	NA	M	Q	1, 2, 3
c. Refuel Floor High Exhaust Duct Radiation - High	S	M	R	*
d. Railroad Access Shaft Exhaust Duct Radiation - High	S	M	R	*
e. Refuel Floor Wall Exhaust Duct Radiation - High	S	M	R	*
f. Manual Initiation	NA	R	NA	1, 2, 3 and *

TABLE 4.3.2.1-1 (Continued)

ISOLATION ACTUATION INSTRUMENTATION SURVEILLANCE REQUIREMENTS

<u>TRIP FUNCTION</u>	<u>CHANNEL CHECK</u>	<u>CHANNEL FUNCTIONAL TEST</u>	<u>CHANNEL CALIBRATION</u>	<u>OPERATIONAL CONDITIONS FOR WHICH SURVEILLANCE REQUIRED</u>
3. <u>MAIN STEAM LINE ISOLATION</u>				
a. Reactor Vessel Water Level - Low, Low Low, Level 1	S	M	R	1, 2, 3
b. Main Steam Line Radiation - High	S	M	R	1, 2, 3
c. Main Steam Line Pressure - Low	NA	M	Q	1
d. Main Steam Line Flow - High	S	M	R	1, 2, 3
e. Condenser Vacuum - Low	NA	M	Q	1, 2**, 3**
f. Reactor Building Main Steam Line Tunnel Temperature - High	NA	M	Q	1, 2, 3
g. Reactor Building Main Steam Line Tunnel Δ Temperature - High	NA	M	Q	1, 2, 3
h. Manual Initiation	NA	R	NA	1, 2, 3
i. Turbine Building Main Steam Line Tunnel Temperature - High	NA	M	Q	1, 2, 3
4. <u>REACTOR WATER CLEANUP SYSTEM ISOLATION</u>				
a. RWCU Δ Flow - High	S	M	R	1, 2, 3
b. RWCU Area Temperature - High	NA	M	Q	1, 2, 3
c. RWCU Area Ventilation Δ Temperature - High	NA	M	Q	1, 2, 3
d. SLCS Initiation	NA	R	NA	1, 2, 3
e. Reactor Vessel Water Level - Low Low, Level 2	S	M	R	1, 2, 3
f. RWCU Flow - High	S	M	R	1, 2, 3
g. Manual Initiation	NA	R	NA	1, 2, 3

SUSQUEHANNA - UNIT 1

3/4 3-24

Amendment No. 38



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

PENNSYLVANIA POWER & LIGHT COMPANY

ALLEGHENY ELECTRIC COOPERATIVE, INC.

DOCKET NO. 50-388

SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 22
License No. NPF-22

1. The Nuclear Regulatory Commission (the Commission or the NRC) having found that:
 - A. The application for the amendment filed by the Pennsylvania Power & Light Company, dated November 26, 1985, as supplemented on January 15, 1986, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the regulations of the Commission;
 - C. There is reasonable assurance: (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations set forth in 10 CFR Chapter I;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment and paragraph 2.C.(2) of Facility Operating License No. NPF-22 is hereby amended to read as follows:

(2) Technical Specifications and Environmental Protection Plan

The Technical Specifications contained in Appendix A, as revised through Amendment No. 22 and the Environmental Protection Plan contained in Appendix B, are hereby incorporated in the license. PP&L shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. This amendment is effective as of the date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Elinor G. Adensam, Director
BWR Project Directorate No. 3
Division of BWR Licensing

Attachment:
Changes to the Technical
Specifications

Date of Issuance: FEB 14 1986

ATTACHMENT TO LICENSE AMENDMENT NO. 22

FACILITY OPERATING LICENSE NO. NPF-22

DOCKET NO. 50-388

Replace the following pages of the Appendix "A" Technical Specifications with enclosed pages. The revised pages are identified by Amendment number and contain vertical lines indicating the area of change. The corresponding overleaf page is also provided to maintain document completeness.

REMOVE

3/4 3-11
3/4 3-12

3/4 3-23
3/4 3-24

INSERT

3/4 3-11
3/4 3-12 (overleaf)

3/4 3-23
3/4 3-24 (overleaf)

TABLE 3.3.2-1

ISOLATION ACTUATION INSTRUMENTATION

<u>TRIP FUNCTION</u>	<u>ISOLATION SIGNAL(S)(a)</u>	<u>MINIMUM OPERABLE CHANNELS PER TRIP SYSTEM (b)</u>	<u>APPLICABLE OPERATIONAL CONDITION</u>	<u>ACTION</u>
1. PRIMARY CONTAINMENT ISOLATION				
a. Reactor Vessel Water Level				
1) Low, Level 3	A	2	1, 2, 3	20
2) Low Low, Level 2	B	2	1, 2, 3	20
3) Low Low Low, Level 1	X	2	1, 2, 3	20
b. Drywell Pressure - High	Y,Z	2	1, 2, 3	20
c. Manual Initiation	NA	1	1, 2, 3	24
d. SGTS Exhaust Radiation - High	R	1	1, 2, 3, 4***, 5***	20
e. Main Steam Line Radiation - High	C	2	1, 2, 3	20
2. SECONDARY CONTAINMENT ISOLATION				
a. Reactor Vessel Water Level - Low Low, Level 2	**	2	1, 2, 3 and *	25
b. Drywell Pressure - High	**	2	1, 2, 3	25
c. Refuel Floor High Exhaust Duct Radiation - High	**	2	*	25
d. Railroad Access Shaft Exhaust Duct Radiation - High	**	2	*	25
e. Refuel Floor Wall Exhaust Duct Radiation - High	**	2	*	25
f. Manual Initiation	NA	1	1, 2, 3 and *	24

TABLE 3.3.2-1 (Continued)

ISOLATION ACTUATION INSTRUMENTATION

<u>TRIP FUNCTION</u>	<u>ISOLATION SIGNAL(S)(a)</u>	<u>MINIMUM OPERABLE CHANNELS PER TRIP SYSTEM (b)</u>	<u>APPLICABLE OPERATIONAL CONDITION</u>	<u>ACTION</u>
3. MAIN STEAM LINE ISOLATION				
a. Reactor Vessel Water Level - Low, Low, Level 2	B	2	1, 2, 3	21
b. Main Steam Line Radiation - High	C	2	1, 2, 3	21
c. Main Steam Line Pressure - Low	P	2	1	22
d. Main Steam Line Flow - High	D	2/line	1, 2, 3	20
e. Condenser Vacuum - Low	UA	2	1, 2, 3	21
f. Reactor Building Main Steam Line Tunnel Temperature - High	E	2	1, 2, 3	21
g. Reactor Building Main Steam Line Tunnel Δ Temperature - High	E	2	1, 2, 3	21
h. Manual Initiation	NA	1	1, 2, 3	24
i. Turbine Building Main Steam Line Tunnel Temperature - High	E	2	1, 2, 3	21
4. REACTOR WATER CLEANUP SYSTEM ISOLATION				
a. RWCU Δ Flow - High	J	1	1, 2, 3	23
b. RWCU Area Temperature - High	W	3	1, 2, 3	23
c. RWCU Area Ventilation Δ Temperature - High	W	3	1, 2, 3	23
d. SLCS Initiation	I	2	1, 2, 3	23
e. Reactor Vessel Water Level - Low Low, Level 2	B	2	1, 2, 3	23
f. RWCU Flow - High	J	1	1, 2, 3	23
g. Manual Initiation	NA	1	1, 2, 3	24

TABLE 4.3.2.1-1

ISOLATION ACTUATION INSTRUMENTATION SURVEILLANCE REQUIREMENTS

<u>TRIP FUNCTION</u>	<u>CHANNEL CHECK</u>	<u>CHANNEL FUNCTIONAL TEST</u>	<u>CHANNEL CALIBRATION</u>	<u>OPERATIONAL CONDITIONS FOR WHICH SURVEILLANCE REQUIRED</u>
1. <u>PRIMARY CONTAINMENT ISOLATION</u>				
a. Reactor Vessel Water Level -				
1) Low, Level 3	S	M	R	1, 2, 3
2) Low Low, Level 2	S	M	R	1, 2, 3
3) Low Low Low, Level 1	S	M	R	1, 2, 3
b. Drywell Pressure - High	NA	M	R	1, 2, 3
c. Manual Initiation	NA	R	NA	1, 2, 3
d. SGTS Exhaust Radiation - High	S	M	R	1, 2, 3, 4, 5
e. Main Steam Line Radiation - High	S	M	R	1, 2, 3
2. <u>SECONDARY CONTAINMENT ISOLATION</u>				
a. Reactor Vessel Water Level - Low Low, Level 2	S	M	R	1, 2, 3 and *
b. Drywell Pressure - High	NA	M	Q	1, 2, 3
c. Refuel Floor High Exhaust Duct Radiation - High	S	M	R	*
d. Railroad Access Shaft Exhaust Duct Radiation - High	S	M	R	*
e. Refuel Floor Wall Exhaust Duct Radiation - High	S	M	R	*
f. Manual Initiation	NA	R	NA	1, 2, 3 and *

TABLE 4.3.2.1-1 (Continued)

ISOLATION ACTUATION INSTRUMENTATION SURVEILLANCE REQUIREMENTS

<u>TRIP FUNCTION</u>	<u>CHANNEL CHECK</u>	<u>CHANNEL FUNCTIONAL TEST</u>	<u>CHANNEL CALIBRATION</u>	<u>OPERATIONAL CONDITIONS FOR WHICH SURVEILLANCE REQUIRED</u>
3. MAIN STEAM LINE ISOLATION				
a. Reactor Vessel Water Level - Low Low, Level 2	S	M	R	1, 2, 3
b. Main Steam Line Radiation - High	S	M	R	1, 2, 3
c. Main Steam Line Pressure - Low	NA	M	Q	1
d. Main Steam Line Flow - High	S	M	R	1, 2, 3
e. Condenser Vacuum - Low	NA	M	Q	1, 2**, 3**
f. Reactor Building Main Steam Line Tunnel Temperature - High	NA	M	Q	1, 2, 3
g. Reactor Building Main Steam Line Tunnel Δ Temperature - High	NA	M	Q	1, 2, 3
h. Manual Initiation	NA	R	NA	1, 2, 3
i. Turbine Building Main Steam Line Tunnel Temperature - High	NA	M	Q	1, 2, 3
4. REACTOR WATER CLEANUP SYSTEM ISOLATION				
a. RWCU Δ Flow - High	S	M	R	1, 2, 3
b. RWCU Area Temperature - High	NA	M	Q	1, 2, 3
c. RWCU Area Ventilation Δ Temperature - High	NA	M	Q	1, 2, 3
d. SLCS Initiation	NA	R	NA	1, 2, 3
e. Reactor Vessel Water Level - Low Low, Level 2	S	M	R	1, 2, 3
f. RWCU Flow - High	S	M	R	1, 2, 3
g. Manual Initiation	NA	R	NA	1, 2, 3