

TABLE 3.6.3-1 (Continued)

PRIMARY CONTAINMENT ISOLATION VALVES

<u>VALVE FUNCTION AND NUMBER</u>	<u>MAXIMUM ISOLATION TIME (Seconds)</u>	<u>ISOLATION SIGNAL(S)<sup>(a)</sup></u>
<u>Automatic Isolation Valves (Continued)</u>		
<u>Suppression Pool Cleanup<sup>(b)</sup></u>		
HV-25766	35	A,Z
HV-25768	30	A,Z
<u>HPCI Vacuum Breaker</u>		
HV-255F075	15	LB,Z
HV-255F079	15	LB,Z
<u>RCIC Vacuum Breaker</u>		
HV-249F062	10	KB,Z
HV-249F084	10	KB,Z
<u>TIP Ball Valves (d)</u>		
CS1-J004 A,B,C,D,E	5	A,Z
b. <u>Manual Isolation Valves</u>		
<u>MSIV-LCS Bleed Valve</u>		
HV-239F001 B,F,K,P		
<u>Feedwater<sup>(e)</sup></u>		
HV-241F032 A,B		
<u>RWCU Return</u>		
<del>HV-244F042</del> HV-24182A,B		
<del>HV-244F104</del>		
<u>RCIC Injection</u>		
HV-249F013		
2-49-020		

B604090254 B60404  
PDR ADDCK 05000388  
P PDR



1944

1945

TABLE 3.8.4.2-1 (Continued)

MOTOR-OPERATED VALVES THERMAL OVERLOAD PROTECTION

<u>VALVE NUMBER</u>	<u>SYSTEM(S) AFFECTED</u>
HV-E51-2F019	RCIC
HV-E51-2F060	RCIC
HV-E51-2F059	RCIC
HV-E51-2F022	RCIC
HV-E51-2F062	RCIC
HV-E41-2F012	HPCI
HV-E41-2F001	HPCI
HV-E41-2F011	HPCI
HV-E41-2F006	HPCI
HV-E41-2F079	HPCI
HV-E41-2F059	HPCI
HV-E41-2F004	HPCI
HV-E41-2F003	HPCI
HV-E41-2F042	HPCI
HV-E41-2F075	HPCI
HV-E41-2F008	HPCI
HV-E41-2F007	HPCI
HV-E41-2F066	HPCI
HV-G33-2F004	RWCU
HV-B21-2F019	NSSS
HV-E11-2F008	RHR
HV-E11-2F023	RHR
HV-E11-2F049	RHR
HV-B31-2F032A	Rx Recirc
HV-B31-2F032B	Rx Recirc
HV-B31-2F031A	Rx Recirc
HV-B31-2F031B	Rx Recirc

HV-24182A  
HV-24182B

~~RWCU~~  
RWCU