


SECONDARY CONTAINMENT FUNCTIONAL DIAGRAM

B605200105 860514
PDR ADDCK 05000387
PDR



CONTAINMENT SYSTEMS

3/4.6.5 SECONDARY CONTAINMENT

SECONDARY CONTAINMENT INTEGRITY

LIMITING CONDITION FOR OPERATION

3.6.5.1 SECONDARY CONTAINMENT INTEGRITY** shall be maintained.

APPLICABILITY: OPERATIONAL CONDITIONS 1, 2, 3, and *.

ACTION:

Without SECONDARY CONTAINMENT** INTEGRITY:

- a. In OPERATIONAL CONDITION 1, 2, or 3, restore SECONDARY CONTAINMENT INTEGRITY within 4 hours or be in at least HOT SHUTDOWN within the next 12 hours and in COLD SHUTDOWN within the following 24 hours.
- b. In Operational Condition *, suspend handling of irradiated fuel in the secondary containment, CORE ALTERATIONS and operations with a potential for draining the reactor vessel. The provisions of Specification 3.0.3 are not applicable.

SURVEILLANCE REQUIREMENTS

4.6.5.1 SECONDARY CONTAINMENT** INTEGRITY shall be demonstrated by:

- a. Verifying at least once per 24 hours that the pressure within the secondary containment is less than or equal to 0.25 inch of vacuum water gauge.
- b. Verifying at least once per 31 days that:
 - 1a. When the railroad bay door (No. 101) is closed; all Zone I and III hatches, removable walls, dampers, and doors connected to the railroad access bay are closed, ## or
 - i) Only Zone I removable walls and/or doors are open to the railroad access shaft, ## or
 - ii) Only Zone III hatches and/or dampers are open to the railroad access shaft. ##
 - 1b. When the railroad bay door (No. 101) is open; all Zone I and III hatches, removable walls, dampers, and doors connected to the railroad access bay are closed.

*When irradiated fuel is being handled in the secondary containment and during CORE ALTERATIONS and operations with a potential for draining the reactor vessel.

**Secondary Containment consists of Zone I, Zone II and Zone III or Zone I and Zone III when Zone II is isolated from Zone I and Zone III. During Operational Condition * When no operations with a potential for draining the reactor vessel are being performed, Secondary Containment may consist of Zone III as long as Zone I is isolated from Zone III.

Personnel ingress and egress through doors within the secondary containment is not prohibited by this specification.

CONTAINMENT SYSTEMS

3/4.6.5 SECONDARY CONTAINMENT

SECONDARY CONTAINMENT INTEGRITY

LIMITING CONDITION FOR OPERATION

3.6.5.1 SECONDARY CONTAINMENT INTEGRITY** shall be maintained.

APPLICABILITY: OPERATIONAL CONDITIONS 1, 2, 3, and *.

ACTION:

Without SECONDARY CONTAINMENT** INTEGRITY:

- a. In OPERATIONAL CONDITION 1, 2, or 3, restore SECONDARY CONTAINMENT** INTEGRITY within 4 hours or be in at least HOT SHUTDOWN within the next 12 hours and in COLD SHUTDOWN within the following 24 hours.
- b. In Operational Condition *, suspend handling of irradiated fuel in the secondary containment, CORE ALTERATIONS and operations with a potential for draining the reactor vessel. The provisions of Specification 3.0.3 are not applicable.

SURVEILLANCE REQUIREMENTS

4.6.5.1 SECONDARY CONTAINMENT** INTEGRITY shall be demonstrated by:

- a. Verifying at least once per 24 hours that the pressure within the secondary containment is less than or equal to 0.25 inch of vacuum water gauge.
- b. Verifying at least once per 31 days that:
 - 1a. When the railroad bay door (No. 101) is closed; all Zone I and III hatches, removable walls, dampers, and doors connected to the railroad access bay are closed,## or
 - i) Only Zone I removable walls and/or doors are open to the railroad access shaft,## or
 - ii) Only Zone III hatches and/or dampers are open to the railroad access shaft.##
 - 1b. When the railroad bay door (No. 101) is open; all Zone I and III hatches, removable walls, dampers, and doors connected to the railroad access bay are closed.

*When irradiated fuel is being handled in the secondary containment and during CORE ALTERATIONS and operations with a potential for draining the reactor vessel.

**Secondary Containment consists of Zone I, Zone II and Zone III or Zone I and Zone III when Zone I is isolated from Zone II and Zone III.

##Personnel ingress and egress through doors within the secondary containment is not prohibited by this specification.

*During Operational Condition * when no operations with a potential for draining the reactor vessel are being performed, Secondary Containment may consist of Zone III as long as*

Zone II is isolated from Zone III.
SUSQUEHANNA - UNIT 2 3/4 6-31