

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8610060398 DDC. DATE: 86/09/17 NOTARIZED: NO DOCKET #  
 FACIL: 50-387 Susquehanna Steam Electric Station, Unit 1, Pennsylv 05000387  
 50-388 Susquehanna Steam Electric Station, Unit 2, Pennsylv 05000388  
 AUTH. NAME AUTHOR AFFILIATION  
 KEISER, H. W. Pennsylvania Power & Light Co.  
 RECIP. NAME RECIPIENT AFFILIATION  
 ADENSAM, E. BWR Project Directorate 3

SUBJECT: Discusses threat to operability of seven inboard containment valves from postulated high energy line break jet impingement per NRC request. Probability of accident not increased, based on safety of existing plant design.

DISTRIBUTION CODE: A001D COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 2  
 TITLE: DR Submittal: General Distribution

NOTES: 1cy NMSS/FCAF/PM. LPDR 2cys Transcripts. 05000387  
 1cy NMSS/FCAF/PM. LPDR 2cys Transcripts. 05000388

	RECIPIENT		COPIES			RECIPIENT		COPIES	
	ID CODE/NAME		LTR	ENCL		ID CODE/NAME		LTR	ENCL
	BWR EB		1	1		BWR EICSB		2	2
	BWR FOB		1	1		BWR PD3 LA		1	0
	BWR PD3 PD	01	5	5		CAMPAGNONE		1	1
	BWR PSB		1	1		BWR RSB		1	1
INTERNAL:	ACRS	09	6	0		ADM/LFMB		1	0
	ELD/HDS4		1	0		NRR/DHET/TSCB		1	1
	NRR/ORAS		1	0		<u>REG FILE</u>	04	1	1
	RGNI		1	1					
EXTERNAL:	EG&G BRUSKE, S		1	1		LPDR	03	2	2
	NRC PDR	02	1	1		NSIC	05	1	1
NOTES:			3	3					

TOTAL NUMBER OF COPIES REQUIRED: LTR 33 ENCL 2





Pennsylvania Power & Light Company

Two North Ninth Street • Allentown, PA 18101 • 215 / 770-5151

Harold W. Keiser  
Vice President-Nuclear Operations  
215/770-7502

SEP 17 1986

Director of Nuclear Reactor Regulation  
Attention: Ms. E. Adensam, Project Director  
BWR Project Directorate No. 3  
Division of Licensing  
U.S. Nuclear Regulatory Commission  
Washington DC 20555

SUSQUEHANNA STEAM ELECTRIC STATION  
JET IMPINGEMENT ON CONTAINMENT  
ISOLATION VALVES  
FILE R41-2  
PLA-2702

Docket Nos. 50-387  
50-388

Dear Ms. Adensam:

Pennsylvania Power & Light Company is forwarding this information to you at the request of our Region I senior resident inspector.

A threat to the operability of seven inboard containment isolation valves from a postulated high energy line break jet impingement has been identified on each of the Susquehanna SES Units. The breaks involved are at the terminal end welds of five pipes which join the reactor pressure vessel. These lines are in two categories, one 28 inch reactor recirculation suction line and four 12 inch reactor recirculation jet pump supply lines. The breaks are at the pipe-to-safe-end welds which are located in the inside diameter of the sacrificial shield door. These doors deflect the break jets and tend to focus them on the containment isolation valves. This is an apparent violation of General Design Criteria 4 (GDC4) and FSAR commitments.

The initial discovery was made during a routine review of the reactor recirculation calculations for postulated pipe breaks and affected the "A" and "D" inboard MSIV's. Nonconformance Reports (NCR) were immediately written and the investigation was expanded to include piping with similar modeling geometry. The remaining inboard MSIV's and three other inboard containment isolation valves were also identified as potentially threatened valves. NCR's have also been written for these valves.

A more detailed analysis was pursued for the postulated reactor recirculation suction line break without success. It was then decided to pursue a leak - before - break (LBB) analyses to show that the postulated breaks are not credible. This decision was based on the fact that a precedent has been established for this approach and it is considered to be a more realistic mechanism of failure. This approach would cover all the postulated pipe breaks in question and eliminate the need for modifications. The leak-before-break analyses are presently in progress.

8610060398 860917  
PDR ADDCK 05000387  
P PDR

A001  
1/10

Faint, illegible text covering the majority of the page, possibly representing a document or report.

SEP 17 1986

Page 2

SSES PLA-2702  
File R41-2  
Ms. E. Adensam

PP&L is continuing to operate both units at Susquehanna in accordance with our procedures. A safety evaluation has been performed justifying continued operation. The evaluation identified the assumed double-ended-guillotine-break (DEGB) as a non-mechanistic assumption since large nuclear piping has no history of this type of failure. In addition, the quality control used during construction, the Pre-Service Inspections (PSI) performed, the In-Service Inspections (ISI) performed and planned, the existing leak detection systems, the good water chemistry controls, the Induced Heating Stress Improvement (IHSI) performed on both units with attendant reinspection, the corrosion resistant cladding on the jet pump supply lines, and the relatively short service life of both units all raise the confidence level that an actual DEGB would not occur at Susquehanna. PP&L has calculated the probability of a DEGB failure along with a random failure of one of the corresponding outboard containment isolation valves to be less than  $1.2 \times 10^{-6}$  events per year.

In the event that a DEGB were to occur at one of the identified welds and assuming the impacted valves would fail to close, the outboard isolation valve could reasonably be expected to provide containment isolation. If an unlikely random failure of the outboard isolation valve were to occur simultaneously it would be reasonable to assume that the affected system's integrity would be maintained and serve as an effective containment barrier. Additionally, in all cases except for the MSIV's, if containment were lost, the leakage would be into the reactor building and subject to Standby Gas Treatment System processing. In the case of the MSIV's, a Design Basis Accident (DBA) using the MSIV's and main steam lines as the release pathway would yield Peak Cladding Temperatures of less than 2200°F. This would not result in significant fuel damage or the release of radioisotopes of significant concern.

The probability of an accident occurring has not changed as a result of the described discovery. In fact, upon completing the LBB analysis, PP&L expects to conclusively show that the probability of a DEGB at the welds in question will be virtually nonexistent. A large margin of safety is inherent in the existing plant design, the consequences of an accident as described above do not exceed those previously reported in the FSAR, and the margin of safety as defined in the basis of the technical specification has not been reduced. ✓

If you have any questions please contact us.

Very truly yours,



H. W. Keiser  
Vice President - Nuclear Operations

cc: M. J. Campagnone NRC  
L. R. Plisco NRC



11/11/11

1. The first part of the document discusses the importance of maintaining accurate records of all transactions. It emphasizes that this is crucial for ensuring the integrity of the financial statements and for providing a clear audit trail. The text notes that any discrepancies or errors in the records can lead to significant complications during an audit and may result in penalties or legal action.

2. The second part of the document outlines the specific procedures for recording transactions. It details the steps involved in identifying the nature of the transaction, determining the appropriate accounting treatment, and ensuring that all necessary supporting documents are properly filed. The text stresses the need for consistency and accuracy in the recording process to avoid any potential issues.

3. The third part of the document addresses the role of the accounting system in providing timely and reliable information. It highlights the importance of regular reconciliations and the use of appropriate accounting software to facilitate the recording and reporting process. The text also discusses the need for ongoing monitoring and review of the system to ensure it remains effective and up-to-date.

4. The fourth part of the document discusses the impact of these procedures on the overall financial health of the organization. It notes that accurate record-keeping is essential for identifying trends, managing risks, and making informed decisions. The text concludes by emphasizing the responsibility of management to ensure that these procedures are followed consistently and that the accounting system is properly maintained.