



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION
RELATED TO THE INSERVICE INSPECTION PROGRAM AND REQUESTS FOR RELIEF
PENNSYLVANIA POWER AND LIGHT COMPANY
SUSQUEHANNA STEAM ELECTRIC STATION UNIT 2
DOCKET NO. 50-388

INTRODUCTION

The Technical Specification for the Susquehanna Steam Electric Station Unit 2 states that inservice examination of ASME Code Class 1, 2, and 3 components shall be performed in accordance with Section XI of the ASME Boiler and Pressure Vessel Code and applicable Addenda as required by 10 CFR 50.55a(g) except where specific written relief has been granted by the Commission. Some plants were designed in conformance to early editions of this Code Section, consequently certain requirements of later editions and addenda of Section XI are impractical to perform because of the plants' design, component geometry, material of construction or the need for extensive temporary modifications and the resultant substantial exposure to plant personnel. Regulation 10 CFR 50.55a(g)(6)(i) authorizes the Commission to grant relief from those requirements upon making the necessary findings.

By letters dated February 28, 1985, and August 12, 1986, Pennsylvania Power and Light Co. (PP&L) submitted its inservice inspection program and additional information related to requests for relief from certain Code requirements determined to be impractical to perform on the Susquehanna Steam Electric Station Unit 2 during the 1st inspection interval. The program is based on the requirements of the 1980 Edition through Winter 1980 Addenda of Section XI of the ASME Code and remains in effect until February 12, 1995, unless the program is modified or changed prior to the interval end date.

EVALUATION

The inservice inspection program and the results for relief from the requirements of Section XI that have been determined to be impractical to perform have been reviewed by the Staff's contractor, Science Applications International Corporation (SAIC). The contractor's Technical Evaluation Report (TER), evaluating the licensee's inservice inspection program plan and relief requests, is attached. The staff has reviewed the TER and agrees with its evaluations and conclusions. A summary of the relief request determinations made by the staff is presented in the attachment 1. The granting of relief is based upon the fulfillment of any commitments made by the licensee in its basis for the relief request and the alternate proposed examination.

8702250219 870212
PDR ADOCK 05000388
P PDR

2/12/87 8702250206



1954

CONCLUSION

Based on the review, the staff concludes that the relief from the code-required examination and testing may be granted provided the alternate methods imposed through this document are followed. The staff further concludes that the licensee's inservice inspection program will still provide reasonable assurance of the piping and component pressure boundary structural integrity. During the review of the licensee's inservice inspection plan, the staff has not identified any significant misinterpretation or omissions of Code requirements. Thus, the inservice inspection plan is acceptable for implementation.

Principal Contribution: B. Turovlin



ATTACHMENT 1

TABLE 1

CLASS 1 COMPONENTS

LICENSEE'S REQUEST NO.	IWB-2500-1 ITEM NO.	IWB-2500 EXAM CAT.	SYSTEM OR COMPONENT	AREA TO BE EXAMINED	REQUIRED METHOD	LICENSEE PROPOSED ALTERNATE EXAMINATION	RELIEF REQUEST STATUS
2RR-9	B1.11	B-A	Reactor Vessel	Circumferen- tial Shell welds AD	Volumetric	80% of weld AD with special wedge	Granted
	B1.12			Longitudinal Shell Welds BK and BM	Volumetric	None	Granted
2RR-5	B3.90	B-D	Reactor Vessel	Nozzle-to- Vessel Welds N4A and N4D	Volumetric	Periodic System Leakage Test* (Category B-P) and Inservice Hydrosta- tic Test* (Category B-P)	Granted
2RR-8	B9.10 B9.11 B9.12	B-J	Piping Selection	Nominal Pipe Size 4 in. & Greater, B9.11: Circumfer- ential Welds, B9.12: Longi- tudinal Welds.	Surface & Volumetric		Relief not needed for this (1st) interval only.

* These alternatives described by the licensee are already required by the code.



TABLE 1

CLASS 1 COMPONENTS (CONTINUED)

LICENSEE'S REQUEST NO.	IWB-2500-1 ITEM NO.	IWB-2500 EXAM CAT.	SYSTEM OR COMPONENT	AREA TO BE EXAMINED	REQUIRED METHOD	LICENSEE PROPOSED ALTERNATE EXAMINATION	RELIEF REQUEST STATUS	
2RR-8	B9.20 B9.21	B-J	Piping Selection	Nominal Pipe Size < 4 in. Circumfer- ential Welds	Surface		Relief not needed for this (1st) interval only	
	B9.22			Longitudinal Welds			Same as above	
	B9.30			Branch Piping Connections Selection				
	B9.31			Nominal Pipe size \geq 4 in.			Volumetric and Surface	Same as above
	B9.32			Nominal Pipe size < 4 in.			Surface	Same as above
	B9.40			Socket Welds			Surface	Same as above
2RR-1	B12.20	B-L-2	Pump Casings	Internal surfaces Reactor Recircu- lation Pump	Visual VT-3	Any valve(s) or pump(s) disassembled have visual examination	Granted	
2RR-2	B12.50	B-M-2	Valve Bodies Exceeding 4 in.	Internal surfaces	Visual, VT-3	Same as above	Granted	

TABLE 2

CLASS 2 COMPONENTS

LICENSEE'S REQUEST NO.	IWB-2500-1 ITEM NO.	IWB-2500 EXAM CAT.	SYSTEM OR COMPONENT	AREA TO BE EXAMINED	REQUIRED METHOD	LICENSEE PROPOSED ALTERNATE EXAMINATION	RELIEF REQUEST STATUS
2RR-3	C5.10	C-F	Piping < ½ in. Nominal wall thickness	Circumfer- ential welds	Surface		Relief not needed for (1st) interval only
	C5.20		Piping >½ in. nominal	Circumfer- and Longi- tudinal welds	Surface and Volumetric		
	C5.31		Branch Pipe Connections	Circumfer- Welds	Surface		
2RR-4	C6.10	C-G	Pumps, Core Spray and RHR	Pressure Retaining Pump Casing Welds	Surface	Visual (VT-3) when dis- assembled for main- tenance.	Granted
				Discharge elbow-to-sleeve forging weld Discharge elbow-to-sleeve plate flange weld			Relief not needed welds are located within pressure boundary



TABLE 3

ASME CLASS 3 COMPONENTS - NO RELIEF REQUESTS

PRESSURE TESTS - NO RELIEF REQUESTS



TABLE 4

COMPONENT SUPPORTS

<u>Licensee's Request No.</u>	<u>Code Requirements</u>	<u>Licensee's Proposed Alternative Examination</u>	<u>Relief Request Status</u>
<u>2RR-6</u>	<u>Non-Snubber Exemption and Selection Criteria</u>		
<u>IWF-1230 Supports Exempt from Examination and Test:</u>	In the course of preparation.	<u>Exemption</u>	Relief not needed exemption criteria conforms to code
		Component supports shall be exempt from the VT-3 and VT-4 examination requirements as follows:	
		(a) Class 1 and 2 components which are exempt from surface and volumetric examination in accordance with IWB-1220 and IWC-1220, respectively, of the Code.	
		(b) Class 3 components which are 4 inch nominal pipe size and smaller in accordance with IWD-1220.1 of the Code.	
<u>IWF-2510 Supports Selected for Examination</u>	(a) Component supports selected for examination shall be the supports of those components that are required to be examined under IWB, IWC, and IWD during the first inspection interval.	<u>Selection Criteria</u>	Granted
	(b) For multiple components within a system of similar design, function, and service, the supports of only one of the multiple components are required to be examined.	Criteria for Class 1, 2 and 3 pipe supports not exempt from examination is based on statistical sampling.	




TABLE 5

STANDARDS FOR EXAMINATION EVALUATIONS

<u>LICENSEE'S RELIEF REQUEST NO.</u>	<u>SYSTEM OR COMPONENT</u>	<u>REQUIREMENT</u>	<u>LICENSEE PROPOSED ALTERNATIVE EXAMINATION</u>	<u>RELIEF REQUEST STATUS</u>
2RR-7	Snubbers 50 kips or greater	In preparation	Functional testing require- ments of Techni- cal Specification 3.4.7.4	No relief required. Testing per T.S. should meet Code requirements if Licensee ensures that 10% of all snubbers rated less than 50 kips are examined.
	Snubbers less than 50 kips	Representative 10% sample tested each inspection period.	VT-3 and VT-4 visual	



11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60 61 62 63 64 65 66 67 68 69 70 71 72 73 74 75 76 77 78 79 80 81 82 83 84 85 86 87 88 89 90 91 92 93 94 95 96 97 98 99 100

