

TABLE 3.8.4.1-1 (Continued)

PRIMARY CONTAINMENT PENETRATION CONDUCTOR
OVERCURRENT PROTECTIVE DEVICES

<u>Circuit Breaker Designation</u>	<u>System/Equipment Powered</u>
16. 1B253043	Drywell Sump/1P403A
17. 1B263072	Drywell Sump/1P403B
C. <u>Type KB-TM</u>	
1. 1B216092 1B216083	Cont. H2 Recombiner/1E440A
2. 1B226103 1B226102	Cont. H2 Recombiner/1E440B
3. 1B236103 1B236122	Cont. H2 Recombiner/1E440C
4. 1B246033 1B246044	Cont. H2 Recombiner/1E440D
D. <u>Circuit Breakers Tripped By Overcurrent Relays</u>	
1. 1A20501 1A20502	Rx Recirc/1P401A
2. 1A20601 1A20602	Rx Recirc/1P401B

*Each circuit breaker designation represents two redundant circuit breakers.

8706250165 870619
PDR ADOCK 05000387
P PDR



11-11-11