

XN-NF-87-23

SUSQUEHANNA UNIT 1 CYCLE 4
RELOAD ANALYSIS
Design and Safety Analyses

APRIL 1987

RICHLAND, WA 99352

ADVANCED NUCLEAR FUELS CORPORATION

AN AFFILIATE OF KRAFTWERK UNION



8706260245 870619
PDR ADOCK 05000387
P PDR




ADVANCED NUCLEAR FUELS CORPORATION


XN-NF-87-23


Issue Date: 4/21/87


SUSQUEHANNA UNIT 1 CYCLE 4 RELOAD ANALYSIS


Design and Safety Analyses


Prepare:  4-17-87
J. A. White
BWR Safety Analysis
Date


Approve:  4/17/87
H. E. Williamson, Manager
Licensing and Safety Engineering
Date

Approve:  4/20/87
L. J. Federico, Manager
Neutronics and Fuel Management
Date

Concur:  4/17/87
G. W. Ward, Manager
Reload Licensing
Date

Concur:  4/20/87
J. N. Morgan, Manager
Customer Services Engineering
Date

Approve:  4/21/87
G. J. Busselman, Manager
Fuel Design
Date

Approve:  4/20/87
G. L. Ritter, Manager
Fuel Engineering and Technical Services
Date

11h

CUSTOMER DISCLAIMER

**IMPORTANT NOTICE REGARDING CONTENTS AND USE OF THIS
DOCUMENT**

PLEASE READ CAREFULLY

Advanced Nuclear Fuels Corporation's warranties and representations concerning the subject matter of this document are those set forth in the Agreement between Advanced Nuclear Fuels Corporation and the Customer pursuant to which this document is issued. Accordingly, except as otherwise expressly provided in such Agreement, neither Advanced Nuclear Fuels Corporation nor any person acting on its behalf makes any warranty or representation, expressed or implied, with respect to the accuracy, completeness, or usefulness of the information contained in this document, or that the use of any information, apparatus, method or process disclosed in this document will not infringe privately owned rights; or assumes any liabilities with respect to the use of any information, apparatus, method or process disclosed in this document.

The information contained herein is for the sole use of Customer.

In order to avoid impairment of rights of Advanced Nuclear Fuels Corporation in patents or inventions which may be included in the information contained in this document, the recipient, by its acceptance of this document, agrees not to publish or make public use (in the patent use of the term) of such information until so authorized in writing by Advanced Nuclear Fuels Corporation or until after six (6) months following termination or expiration of the aforesaid Agreement and any extension thereof, unless otherwise expressly provided in the Agreement. No rights or licenses in or to any patents are implied by the furnishing of this document.

TABLE OF CONTENTS

<u>Section</u>	<u>Page</u>
1.0 INTRODUCTION.....	1
2.0 FUEL MECHANICAL DESIGN ANALYSIS.....	2
3.0 THERMAL HYDRAULIC DESIGN ANALYSIS.....	3
3.2 Hydraulic Characterization.....	3
3.2.1 Hydraulic Compatibility.....	3
3.2.2 Thermal Margin Performance, Comparison.....	3
3.2.3 Fuel Centerline Temperature.....	3
3.2.5 Bypass Flow.....	3
3.3 MCPR Fuel Cladding Integrity Safety Limit.....	4
3.3.1 Coolant Thermodynamic Condition.....	4
3.3.2 Design Basis Radial Power Distribution.....	4
3.3.3 Design Basis Local Power Distribution.....	4
4.0 NUCLEAR DESIGN ANALYSIS.....	5
4.1 Fuel Bundle Nuclear Design Analysis.....	5
4.2 Core Nuclear Design Analysis.....	5
4.2.1 Core Configuration.....	5
4.2.2 Core Reactivity Characteristics.....	6
4.2.4 Core Hydrodynamic Stability.....	6
5.0 ANTICIPATED OPERATIONAL OCCURRENCES.....	7
5.1 Analysis Of Plant Transients At Rated Conditions.....	7
5.2 Analyses For Reduced Flow Operation.....	7
5.3 Analyses For Reduced Power Operation.....	8
5.4 ASME Overpressurization Analysis.....	8
5.5 Control Rod Withdrawal Error (CRWE).....	8
5.6 Fuel Loading Error.....	9
5.7 Determination Of Thermal Margins.....	9
6.0 POSTULATED ACCIDENTS.....	10
6.1 Loss-Of-Coolant Accident.....	10
6.1.1 Break Location Spectrum.....	10

TABLE OF CONTENTS

(Continued)

<u>Section</u>	<u>Page</u>
6.1.2 Break Size Spectrum.....	10
6.1.3 MAPLHGR Analyses.....	10
6.2 Control Rod Drop Accident.....	11
7.0 TECHNICAL SPECIFICATIONS.....	12
7.1 Limiting Safety System Settings.....	12
7.1.1 MCPR Fuel Cladding Integrity Safety Limit.....	12
7.1.2 Steam Dome Pressure Safety Limit.....	12
7.2 Limiting Conditions For Operation.....	12
7.2.1 Average Planar Linear Heat Generation Rate Limits.....	12
7.2.2 Minimum Critical Power Ratio.....	13
7.2.3 LHGR Limits.....	14
7.3 Surveillance Requirements.....	14
7.3.1 Scram Insertion Time Surveillance.....	14
7.3.2 Stability Surveillance.....	14
8.0 METHODOLOGY REFERENCES.....	15
9.0 ADDITIONAL REFERENCES.....	16

APPENDICES

A. SEISMIC-LOCA EVALUATION.....	A-1
---------------------------------	-----

LIST OF TABLES

<u>Table</u>		<u>Page</u>
4.1	Neutronic Design Values.....	24

LIST OF FIGURES

<u>Figure</u>		<u>Page</u>
3.1	Susquehanna Unit 1 Cycle 4 Hydraulic Demand Curve Power vs. Flow.....	17
3.2	Susquehanna Unit 1 Cycle 4 Design Basis Radial Power.....	18
3.3	Design Basis Local Power Distribution - ANF XN-3 9x9 Fuel.....	19
3.4	Design Basis Local Power Distribution - ANF XN-2 8x8 Fuel.....	20
3.5	Design Basis Local Power Distribution - ANF XN-1 (Central) 8x8 Fuel.....	21
3.6	Design Basis Local Power Distribution - ANF XN-1 (Peripheral) 8x8 Fuel.....	22
3.7	Design Basis Local Power Distribution - General Electric 8x8R Fuel - Conservatively Flat.....	23
4.1	Susquehanna Unit 1 Cycle 4 (XN-3) Central Enrichment Distribution.....	25
4.2	Susquehanna Unit 1 Cycle 4 Reference Core Loading Plan.....	26
5.1	Susquehanna Unit 1 Cycle 4 Control Rod Withdrawal Error Analysis Control Rod Pattern.....	27
5.2	Susquehanna Unit 1 Cycle 4 Reduced Flow MCPR Operating Limit.....	28


1.0 INTRODUCTION

This report provides the results of the analyses performed by Advanced Nuclear Fuels Corporation (ANF)* in support of the Cycle 4 reload for Susquehanna Unit 1, which is scheduled to commence operation in the fall of 1987. This report is intended to be used in conjunction with ANF topical report XN-NF-80-19(P)(A), Volume 4, Revision 1, "Application of the Exxon Nuclear Company Methodology to BWR Reloads," which describes the analyses performed in support of this reload, identifies the methodology used for those analyses, and provides a generic reference list. However, LHGR mechanical design limits (Reference 9.1) and plant transient simulation model developments (Reference 9.2) have been revised by ANF subsequent to NRC approval of XN-NF-80-19(P)(A), Volume 4, Revision 1. Both References 9.1 and 9.2 have been approved by the NRC for use in referencing in license applications. Section numbers in this report are the same as corresponding section numbers in XN-NF-80-19(P)(A), Volume 4, Revision 1.

The Susquehanna Unit 1 Cycle 4 core will comprise a total of 764 fuel assemblies, including 240 unirradiated ANF XN-3 9x9 assemblies, 296 irradiated ANF XN-2 8x8 assemblies, 192 irradiated ANF XN-1 8x8 assemblies, and 36 previously irradiated 8x8R assemblies fabricated by General Electric. The reference core configuration is described in Section 4.2.

The design and safety analyses reported in this document were based on the design and operational assumptions in effect for Susquehanna Unit 1 during the previous operating cycle. Additional information and the results of design studies covering the development of 9x9 fuel assemblies for BWR reloads are contained in Reference 9.3.

*Formerly Exxon Nuclear Company (ENG).



2.0 FUEL MECHANICAL DESIGN ANALYSIS

Applicable ANF Fuel Design Report:

Reference 9.1

To assure that the expected power history for the fuels to be irradiated during Cycle 4 of Susquehanna Unit 1 is bounded by the assumed power history in the fuel mechanical design analysis, LHGR operating limits (Figures 3.1 and 3.3 of Reference 9.1) have been specified. In addition, a LHGR transient operating limit for Anticipated Operating Occurrences (Figure 3.4 of Reference 9.1) has been specified for ANF 8x8 and 9x9 fuels. Additional information on rod bow, as requested in the NRC's safety evaluation report for Reference 9.1, has been transmitted in Reference 9.4.

3.0 THERMAL HYDRAULIC DESIGN ANALYSIS

3.2 Hydraulic Characterization

3.2.1 Hydraulic Compatibility

Component hydraulic resistances for the constituent fuel types in the Susquehanna Unit 1 Cycle 4 core have been determined in single phase flow tests of full scale assemblies. Figure 3.1 shows the hydraulic demand curves for ANF 9x9 fuel and ANF 8x8 fuel in the Susquehanna Unit 1 core. The similar hydraulic performance indicates compatibility for co-residence in the Susquehanna Unit 1 core. The remaining General Electric fuel assemblies are in the peripheral (low power) region of the core, and do not represent limiting locations in operation of the plant.

3.2.2 Thermal Margin Performance, Comparison

<u>Core Configuration</u>	<u>ANF 9x9 MCPR</u>	<u>ANF 8x8 MCPR</u>
Cycle 4, Mixed Core	1.325	1.298
All ANF 8x8 Core	--	1.294
All ANF 9x9 Core	1.333	--

3.2.3 Fuel Centerline Temperature

Applicable Generic Report	Reference 9.1
---------------------------	---------------

3.2.5 Bypass Flow

Calculated Bypass Flow Fraction at 100% Power/100% Flow*	9.4%
-------------------------------------------------------------	------

* does not include flow through water rods (.42%).

3.3 MCPR Fuel Cladding Integrity Safety Limit

Safety Limit MCPR = 1.06

3.3.1 Coolant Thermodynamic Condition

Rated Thermal Power	3293 MWt
Feedwater Flowrate (at SLMCPR)	15.4 Mlbm/hr
Steam Pressure (at SLMCPR)	1030 psia
Feedwater Temperature	383°F

3.3.2 Design Basis Radial Power Distribution

See Figure 3.2

3.3.3 Design Basis Local Power Distribution

See Figures 3.3 through 3.7

4.0 NUCLEAR DESIGN ANALYSIS

4.1 Fuel Bundle Nuclear Design Analysis

Assembly Average Enrichment	3.31%
Radial Enrichment Distribution	Figure 4.1
Axial Enrichment Distribution	Uniform 3.42% with 6" natural uranium top blanket

Burnable Poisons

Figure 4.1

Note: Burnable poisons are distributed uniformly over the enriched length of the designated rods. The natural uranium axial blanket sections do not contain burnable absorber material.

Non-Fueled Rods

Figure 4.1

Neutronic Design Parameters

Table 4.1

4.2 Core Nuclear Design Analysis

4.2.1 Core Configuration

Figure 4.2

Core Exposure at EOC3, MWD/MTU	18606
Core Exposure at BOC4, MWD/MTU	10590
Core Exposure at EOC4, MWD/MTU	21590
Maximum Cycle 4 Licensing Exposure Limit, MWD/MTU	21700

4.2.2 Core Reactivity Characteristics

BOC Cold K-effective, All Rods Out	1.11441
BOC Cold K-effective, Strongest Rod Out	0.98399
Reactivity Defect (R-Value)	0.00% rho
Standby Liquid Control System Reactivity, Cold Conditions, 660 ppm	0.98070

4.2.4 Core Hydrodynamic Stability

<u>Power/Flow State Points</u>	<u>Decay Ratio (COTRAN)</u>
64/42*	0.74
68/45**	0.66

*Two pump minimum flow - APRM Rod Block intercept point. Extended operation at lower flow is not allowed by Technical Specifications.

**Operation at less than 45% flow requires APRM/LPRM surveillance. This point exhibits the highest power to flow ratio in the region where surveillance not required.

5.0 ANTICIPATED OPERATIONAL OCCURRENCES

Applicable Generic Transient
Analysis Methodology Report

Reference 9.5 & 9.7

5.1 Analysis Of Plant Transients At
Rated Conditions

Reference 9.6

Limiting Transient(s): Load Rejection Without Bypass (LRWB)
Feedwater Controller Failure (FWCF)
Loss of Feedwater Heating (LFWH)

<u>Event</u>	<u>Power*</u>	<u>Flow</u>	<u>% Rated Maximum Heat Flux</u>	<u>% Rated Maximum Power</u>	<u>Maximum Pressure (psia)</u>	<u>Delta CPR**</u>	<u>Model</u>
LRWB	100%	100%	113.6%	259%	1195	0.22	COTRANSA/ XCOBRA-T
FWCF	100%	100%	115.3%	236%	1179	0.21	COTRANSA/ XCOBRA-T
LFWH	100%	100%	124.1%	125%	1079	0.17	PTSBWR3/ XCOBRA

5.2 Analyses For Reduced Flow Operation

Reference 9.6

Limiting Transient(s): Recirculation Flow Increase Transient (RFIT)

*104% power used in analysis as design bases.

**Delta-CPR results for most limiting fuel type.

5.3 Analyses For Reduced Power Operation

Reference 9.6

Limiting Transient(s): Feedwater Controller Failure (FWCF)

<u>% Power</u>	<u>Transient</u>	<u>Delta CPR</u>	
		<u>ANF 8x8</u>	<u>ANF 9x9</u>
100	FWCF	0.19	0.21
80	FWCF	0.21	0.24
65	FWCF	0.22	0.25
40	FWCF	0.24	0.28

5.4 ASME Overpressurization Analysis

Reference 9.6

Limiting Event

Full MSIV

Worst Single Failure

Isolation

Maximum Pressure

Direct Scram

Maximum Steam Dome Pressure

1304 psig

1288 psig

5.5 Control Rod Withdrawal Error (CRWE)

Starting Control Rod Pattern for Analysis

Figure 5.1

<u>Rod Block Setting</u>	<u>100% Flow</u>	
	<u>Distance Withdrawn (ft)</u>	<u>Delta CPR</u>
105	4.0	0.15
106	4.5	0.16
107	5.0	0.17
108*	5.5	0.18

*Rod Block Monitor setting selected for Cycle 4 operation.

5.6 Fuel Loading Error

Maximum Delta CPR 0.08

5.7 Determination Of Thermal Margins

Summary of Thermal Margin Requirements

<u>Event</u>	<u>Power*</u>	<u>Flow</u>	<u>Delta CPR**</u>	<u>MCPR Limit</u>
LRWB	100%	100%	0.22	1.28
LFWH	100%	100%	0.17	1.23
FWCF	100%	100%	0.21	1.27
CRWE	100%	100%	0.18 at 108% RBM	1.24

MCPR Operating Limits at Rated Conditions

MCPR Operating Limit

1.28

Reduced Flow MCPR Limits

Figure 5.2

Power Dependent MCPR Operating Limit Results for Cycle 4:

<u>% Power/% Flow</u>	<u>Limiting Transient</u>	<u>ANF 8x8</u>	<u>ANF 9x9</u>
100/100	LRWB	1.25	1.28
80/100	FWCF	1.27	1.30
65/100	FWCF	1.28	1.31
40/100	FWCF	1.30	1.34

*104% power used in analysis as design bases.

**Delta CPR results for most limiting fuel type.



6.0 POSTULATED ACCIDENTS6.1 Loss-Of-Coolant Accident6.1.1 Break Location Spectrum

Reference 9.8

6.1.2 Break Size Spectrum

Reference 9.8

6.1.3 MAPLHGR Analyses

ANF XN-3 (9x9) Fuel

Reference 9.9

Limiting Break: Double-ended guillotine pipe break
 Recirculation pump discharge line
 0.4 Discharge Coefficient

<u>Bundle Average Exposure (GWD/MTU)</u>	<u>MAPLHGR (kw/ft)</u>	<u>Peak Clad Temperature* (Degree F)</u>	<u>Peak Local MWR** (Percent)</u>
0	10.2	2060	3.9
5	10.2	2069	3.7
10	10.2	2121	3.7
15	10.2	2140	4.8
20	10.2	2147	5.2
25	9.6	2016	2.7
30	8.9	1839	1.0
35	8.2	1752	0.7
40	7.5	1675	0.5

*Peak clad temperatures shown are for ANF 9x9 fuel in Susquehanna Unit 2. Changes in PCT, due to minor fuel design changes, were investigated for ANF 9x9 fuel in Susquehanna Unit 1, and found to be insignificant. Calculations were performed at exposure intervals of 5 GWD/MTU from BOL to 20 GWD/MT, and at 30 and 40 GWD/MT. All PCT's were lower, the largest change was 21°F decrease in PCT at 10 GWD/MTU and the smallest was 1°F decrease in PCT at 20 GWD/MTU.

**Metal Water Reaction.

ANF XN-1 (8x8) Fuel

Reference 9.10

Limiting Break: Double-ended guillotine pipe break
 Recirculating pump discharge line
 0.4 Discharge Coefficient

<u>Bundle Average Exposure (GWD/MTU)</u>	<u>MAPLHGR (kw/ft)</u>	<u>Peak Clad Temperature* (Degree F)</u>	<u>Peak Local MWR** (Percent)</u>
0	13.0	2074	1.9
5	13.0	2093	2.0
10	13.0	2116	2.1
15	13.0	2136	2.2
19	13.0	2147	2.3
25	11.5	1977	1.6
30	10.4	1846	1.0
35	10.4	1852	1.2

6.2 Control Rod Drop Accident

Section 8.0

Dropped Control Rod Worth, mk	6.2
Doppler Coefficient, 1/k dk/dT	-11.0 x(10) ⁻⁶
Effective Delayed Neutron Fraction	0.0050
Four-Bundle Local Peaking Factor	1.34
Maximum Deposited Fuel Rod Enthalpy, cal/gm	91

*Peak clad temperatures shown are for ANF XN-1 8x8 fuel. The possible change in PCTs due to the fuel design changes in ANF XN-2 8x8 fuel was investigated at three exposures. A 22°F increase resulted at BOL, no change at 10 GWD/MTU, and a 15°F increase resulted at 19 GWD/MTU.

**Metal Water Reaction.

7.0 TECHNICAL SPECIFICATIONS7.1 Limiting Safety System Settings7.1.1 MCPR Fuel Cladding Integrity Safety Limit

MCPR Safety Limit 1.06

7.1.2 Steam Dome Pressure Safety Limit

Pressure Safety Limit (as measured in steam dome) 1325 psig

Analysis shows that a steam dome pressure safety limit of 1358 psig is allowed but the 1325 psig value used in Cycle 3 is to be conservatively retained.

7.2 Limiting Conditions For Operation7.2.1 Average Planar Linear Heat Generation Rate Limits

Bundle Average Exposure (GWD/MT)	MAPLHGR Limits (kw/ft)	
	ANF XN-3 9x9 Fuel	ANF XN-1 & XN-2 8x8 Fuel
0	10.2	13.0
5	10.2	13.0
10	10.2	13.0
15	10.2	13.0
19		13.0
20	10.2	
25	9.6	11.5
30	8.9	10.4
35	8.2	10.4
40	7.5	

7.2.2 Minimum Critical Power Ratio

MCPR Operating Limits at Rated Conditions:

MCPR Operating Limit

1.28

MCPR Operating Limits at Off-Rated Conditions:

At Reduced Flow

Figure 5.2

Total Core Recirculation Flow (% Rated)
105
90
70
50
42

Reduced Flow MCPR <u>Operating Limit</u>
1.06
1.11
1.19
1.34
1.42

At Reduced Power

Power Level (% Rated)
100
80
65
40

Reduced Power MCPR <u>Operating Limit</u>
1.28
1.30
1.31
1.34

7.2.3 LHGR Limits

LHGR Limits

Figures 3.1, 3.3 and 3.4 of
Reference 9.1

7.3 Surveillance Requirements

7.3.1 Scram Insertion Time Surveillance

Thermal limits established in Section 5.0 are based on minimum acceptable scram insertion performance as defined in the Technical Specifications. No additional surveillance for scram insertion is required for validation of thermal limits.

7.3.2 Stability Surveillance

Stability surveillance established to provide assurance of stable operation during Cycle 3 shall be continued during Cycle 4.



8.0 METHODOLOGY REFERENCES

See XN-NF-80-19(P)(A), Volume 4, Revision 1 for complete bibliography.



9.0 ADDITIONAL REFERENCES

- 9.1 "Generic Mechanical Design for Exxon Nuclear Jet Pump BWR Reload Fuel," XN-NF-85-67(P)(A), Rev. 1, Advanced Nuclear Fuels Corporation*, Richland, Washington, September 4, 1986.
- 9.2 "Exxon Nuclear Methodology for Boiling Water Reactors, THERMEX: Thermal Limits Methodology Summary Description," XN-NF-80-19(P)(A), Volume 3, Revision 2, Advanced Nuclear Fuels Corporation, Richland, Washington, January, 1987.
- 9.3 "Demonstration of 9x9 Assemblies for BWRs," EPRI NP-3468, Electric Power Research Institute, Palo Alto, California, May 1, 1984.
- 9.4 Letter, G. N. Ward (ANF) to G. C. Lainas (NRC), "Additional Information on Rod Bow," serial no. GNW:021:87, dated March 11, 1987.
- 9.5 "Exxon Nuclear Plant Transient Methodology for Boiling Water Reactors," XN-NF-79-71(P), Revision 2, Advanced Nuclear Fuels Corporation, Richland, Washington, November 16, 1981.
- 9.6 "Susquehanna Unit 1 Cycle 4 Plant Transient Analysis," XN-NF-87-22, Advanced Nuclear Fuels Corporation, Richland, Washington, April 1987.
- 9.7 "XCOBRA-T: A Computer Code for BWR Transient Thermal-Hydraulic Core Analysis," XN-NF-84-105(P)(A), Volume 1 and Volume 1, Supplements 1 and 2, Advanced Nuclear Fuels Corporation, Richland, Washington, February 1987.
- 9.8 "Generic LOCA Break Spectrum Analysis BWR 3 & 4 with Modified Low Pressure Coolant Injection Logic Using the EXEM Evaluation Model," XN-NF-84-117(P), Advanced Nuclear Fuels Corporation, Richland, Washington, December 1984.
- 9.9 "Susquehanna LOCA-ECCS Analysis MAPLHGR Results for ENC 9x9 Fuel," XN-NF-86-65, Advanced Nuclear Fuels Corporation, Richland, Washington, May 1986.
- 9.10 "Susquehanna Unit 1 LOCA-ECCS Analysis, MAPLHGR Results," XN-NF-84-119, Advanced Nuclear Fuels Corporation, Richland, Washington, December 1984.

*Formerly Exxon Nuclear Company.




Figure 3.1 Susquehanna Unit 1 Cycle 4 Hydraulic Demand Curve Power vs. Flow




Figure 3.2 Susquehanna Unit 1 Cycle 4 Design Basis Radial Power

0.88	0.91	0.96	1.04	1.03	1.04	0.96	1.00	0.97
0.91	0.93	0.98	1.06	0.92	1.07	0.97	1.04	1.00
0.96	0.98	0.90	1.04	1.02	1.04	1.04	0.99	0.96
1.04	1.06	1.04	0.99	0.99	1.00	1.05	0.94	1.04
1.03	0.92	1.02	0.99	0.00	0.97	1.04	1.06	1.04
1.04	1.07	1.04	1.00	0.97	0.00	1.03	0.97	1.05
0.96	0.97	1.04	1.05	1.04	1.03	1.07	0.99	0.97
1.00	1.04	0.99	0.94	1.06	0.97	0.99	0.95	1.01
0.97	1.00	0.96	1.04	1.04	1.05	0.97	1.01	0.97

Figure 3.3
 Design Basis Local Power Distribution
 Advanced Nuclear Fuels XN-3 9X9 Fuel

* W-W corner, rod adjacent to control blade location.

* 0.95	0.95	0.98	1.01	1.01	1.02	1.00	0.99
0.95	1.01	0.92	1.05	1.04	0.98	0.95	1.00
0.98	0.92	1.04	1.02	1.01	1.03	0.98	1.02
1.01	1.05	1.02	0.00	0.94	1.01	1.04	1.01
1.01	1.04	1.01	0.94	0.00	1.02	1.05	1.01
1.02	0.98	1.03	1.01	1.02	1.04	0.92	1.02
1.00	0.95	0.98	1.04	1.05	0.92	0.97	1.00
0.99	1.00	1.02	1.01	1.01	1.02	1.00	0.99

Figure 3.4
Design Basis Local Power Distribution
Advanced Nuclear Fuels XN-2 8X8 Fuel

* W-W corner, rod adjacent to control blade location.

* 0.99	0.98	0.99	1.01	1.01	0.99	0.98	0.99
0.98	0.98	1.03	0.93	1.02	1.03	1.01	0.98
0.99	1.03	1.01	1.01	1.00	1.01	0.94	0.99
1.01	0.93	1.01	0.00	0.96	1.00	1.03	1.01
1.01	1.02	1.00	0.96	0.00	1.01	0.98	1.01
0.99	1.03	1.01	1.00	1.01	1.02	1.04	1.02
0.98	1.01	0.94	1.03	0.98	1.04	0.97	1.01
0.99	0.98	0.99	1.01	1.01	1.02	1.01	1.02

Figure 3.5
Design Basis Local Power Distribution
Advanced Nuclear Fuels XN-1(Central) 8X8 Fuel

* W-W corner, rod adjacent to control blade location.

0.96*	0.97	1.00	1.03	1.03	1.00	0.97	0.96
0.97	0.98	1.05	0.91	1.03	1.05	1.02	0.97
1.00	1.05	1.02	1.01	1.00	1.01	0.93	1.00
1.03	0.91	1.01	0.00	0.93	1.00	1.03	1.03
1.03	1.03	1.00	0.93	0.00	1.00	0.97	1.03
1.00	1.05	1.01	1.00	1.00	1.02	1.05	1.04
0.97	1.02	0.93	1.03	0.97	1.05	0.97	1.03
0.96	0.97	1.00	1.03	1.03	1.04	1.03	1.01

Figure 3.6
 Design Basis Local Power Distribution
 Advanced Nuclear Fuels XN-1(Peripheral) 8X8 Fuel

* W-W corner, rod adjacent to control blade location.

1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00
1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00
1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00
1.00	1.00	1.00	1.00	0.00	1.00	1.00	1.00	1.00
1.00	1.00	1.00	0.00	1.00	1.00	1.00	1.00	1.00
1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00
1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00
1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00

Figure 3.7
 Design Basis Local Power Distribution
 General Electric 8X8R Fuel - Conservatively Flat

* W-W corner, rod adjacent to control blade location.

TABLE 4.1 NEUTRONIC DESIGN VALUES

<u>Fuel Pellet</u>	Reference 9.2
<u>Fuel Rod</u>	Reference 9.2
<u>Fuel Assembly</u>	Reference 9.2
<u>Core Data</u>	
Number of fuel assemblies	764
Rated thermal power, MW	3293
Rated core flow, Mlbm/hr	100
Core inlet subcooling, BTU/lbm	24.0
Moderator temperature, F	548.8
Channel thickness, inch	.080
Fuel assembly pitch, inch	6.00
Wide water gap thickness, inch	0.562
Narrow water gap thickness, inch	0.562
<u>Control Rod Data</u>	
Absorber material	B ₄ C
Total blade span, inch	9.75
Total blade support span, inch	1.58
Blade thickness, inch	0.260
Blade face-to-face internal dimension, inch	0.200
Absorber rods per blade	76
Absorber rod outside diameter, inch	0.188
Absorber rod inside diameter, inch	0.138
Absorber density, % of theoretical	70.0

LL	L	ML	M	M	M	ML	ML	L
L	ML	M	MH	M*	MH	M*	M	ML
ML	M	M*	H	H	H	MH	M	ML
M	MH	H	H	H	H	H	M*	M
M	M*	H	H	W	MH	H	MH	M
M	MH	H	H	MH	W	MH	M	M
ML	M*	MH	H	H	MH	MH	M*	ML
ML	M	M	M*	MH	M	M*	ML	ML
L	ML	ML	M	M	M	ML	ML	L

- LL RODS (1) --- 1.45 W/O U235
- L RODS (5) --- 1.95 W/O U235
- ML RODS (16) --- 2.53 W/O U235
- M RODS (20) --- 3.27 W/O U235
- MH RODS (13) --- 4.19 W/O U235
- H RODS (15) --- 4.62 W/O U235
- M* RODS (9) --- 3.27 W/O U235 + 4.00 W/O GD203
- W RODS (2) --- INERT WATER ROD

FIGURE 4.1 Susquehanna Unit 1 Cycle 4 (XN-3) Central Enrichment Distribution

	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15
1	B2	C1	D0	B2	D0	B2	D0	B2	D0	B2	D0	C1	D0	C1	A3
2	C1	D0	C1	D0	C1	D0	B2	D0	C1	D0	C1	D0	C1	C1	B2
3	D0	C1	B2	B2	C1	B2	D0	B2	C1	B2	D0	C1	D0	C1	B2
4	B2	D0	B2	D0	C1	D0	B2	D0	C1	D0	C1	D0	C1	C1	B2
5	D0	C1	C1	C1	B2	C1	D0	B2	D0	B2	C1	C1	D0	C1	B2
6	B2	D0	B2	D0	C1	D0	C1	D0	C1	D0	C1	D0	C1	C1	B2
7	D0	B2	D0	B2	D0	C1	B2	B2	C1	C1	D0	C1	B2	C1	A3
8	B2	D0	B2	D0	B2	D0	B2	D0	C1	D0	C1	D0	C1	A3	
9	D0	C1	C1	C1	D0	C1	C1	C1	D0	C1	B2	C1	B2		
10	B2	D0	B2	D0	B2	D0	C1	D0	C1	D0	C1	B2	A3		
11	D0	C1	D0	C1	C1	C1	D0	C1	B2	C1	B2				
12	C1	D0	C1	D0	C1	D0	C1	D0	C1	B2					
13	D0	C1	D0	C1	D0	C1	B2	C1	B2	A3					
14	C1	C1	C1	C1	C1	C1	C1	A3							
15	A3	B2	B2	B2	B2	A3	A3								

XY - Fuel Type X
Burned Y Cycles

Fuel Type	No. of Bundles	Description
A	36	GE 8X8 Type III 2.19 w/o U-235
B	192	XN-1 ANF 8X8 2.72 w/o U-235
C	296	XN-2 ANF 8X8 2.89 w/o U-235
D	240	XN-3 ANF 9X9 3.42 w/o U-235

Figure 4.2 Susquehanna Unit 1 Cycle 4 Reference Core Loading Plan

	2	6	10	14	18	22	26	30	34	38	42	46	50	54	58	
59					--	--	--	--	--	--	--					59
55				--	--	00	--	00	--	00	--	--				55
51			--	--	--	--	--	--	--	--	--	--	--			51
47		--	--	04	--	08	--	16	--	08	--	04	--	--		47
43	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	43
39	--	00	--	08	--	00	--	18	--	00	--	08	--	00	--	39
35	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	35
31	--	00	--	16	--	18	--	08	--	18	--	16	--	00	--	31
27	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	27
23	--	00	--	08	--	00	--	18	--	**	--	08	--	00	--	23
19	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	19
15		--	--	04	--	08	--	16	--	08	--	04	--	--		15
11			--	--	--	--	--	--	--	--	--	--	--			11
7				--	--	00	--	00	--	00	--	--				7
3					--	--	--	--	--	--	--					3
	2	6	10	14	18	22	26	30	34	38	42	46	50	54	58	

** Control Rod Being Withdrawn
 Rod Position in Notches Withdrawn
 Full in - 00
 Full Out - --

Figure 5.1 Susquehanna Unit 1 Cycle 4 Control Rod Withdrawal
 Error Analysis Control Rod Pattern




Figure 5.2 Susquehanna Unit 1 Cycle 4 Reduced Flow MCPR Operating Limit

APPENDIX A

SEISMIC-LOCA EVALUATION

The structural response of Advanced Nuclear Fuels Corporation's (ANF's) 9x9 fuel is the same as the structural response of the 8x8 fuel it replaces in the Susquehanna Unit 1 core. Therefore, the seismic-LOCA structural response evaluation performed in support of the initial core remains applicable and continues to provide assurance that control blade insertion will not be inhibited following the occurrence of the design basis seismic-LOCA event.

The physical and structural properties of the 9x9 and the 8x8 fuel types which are important to the dynamic response of the fuel are summarized in Table A1. The close agreement between the important parameters for the ANF 9x9 and Exxon 8x8 fuel types indicates that the structural response would be very similar for both fuel types.

Similarity in the natural frequencies of the two fuel types mentioned above is further assured by the stiffness of the fuel assembly channel box. Both fuel types use the same fuel assembly channel box, and the channel box dominates the overall dynamic response of the incore fuel. ANF calculations show that approximately 97% of the stiffness of a fuel assembly is attributable to the stiffness of the channel box. For this reason, the dynamic structural response of the reload core is essentially that of the initial core, and the original seismic-LOCA analysis remains applicable. Deformation of the channel to the point that control blade insertion is inhibited is not predicted to occur.

TABLE A1 COMPARISON OF PHYSICAL AND STRUCTURAL CHARACTERISTICS
FOR 8X8 AND 9X9 FUEL ASSEMBLIES

<u>Property</u>	<u>Fuel Types</u>		
	<u>ANF 9x9</u>	<u>ANF 8x8</u>	<u>GE 8x8R</u>
Assembly Weight, lbs	580	596	600
Number of Spacers	7	7	7
Overall Assembly Length, in	171.29	171.29	171.40
Assembly Frequencies, cps			
Mode	1	1.9	1.7
	2	3.7	3.5
	3	6.5	6.5
	4	10.4	10.8
	5	15.5	16.6
	6	21.9	24.2
	7	29.1	33.9
			*

*GE proprietary

XN-NF-87-23
Issue Date: 4/21/87

SUSQUEHANNA UNIT 1 CYCLE 4 RELOAD ANALYSIS

Design and Safety Analyses

Distribution:

D. J. Braun
R. E. Collingham
S. F. Gaines
R. G. Grummer
M. J. Hibbard
S. E. Jensen
T. H. Keheley
T. L. Krysinski
J. N. Morgan
L. A. Nielsen
P. M. O'Leary
H. G. Shaw/PP&L (20)
G. A. Sofer
J. A. White
H. E. Williamson

Document Control (5)