

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8708280266 .DOC. DATE: 87/08/25 NOTARIZED: NO DOCKET #
 FACIL: 50-387 Susquehanna Steam Electric Station, Unit 1, Pennsylv 05000387
 50-388 Susquehanna Steam Electric Station, Unit 2, Pennsylv 05000388
 AUTH. NAME AUTHOR AFFILIATION
 SAXTON, C. H. Pennsylvania Power & Light Co.
 RECIP. NAME RECIPIENT AFFILIATION
 PTASHINSKI, R. R. Pennsylvania, Commonwealth of

SUBJECT: NPDES noncompliance notification: on 870821 & 22, two samples of drinking water collected for bacteriological analysis, per 870817 request. Results indicated less than 2.2 most probable number of bacteria per 100 ml. Posting removed on 870824.

DISTRIBUTION CODE: IE25D COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 2
 TITLE: Environmental Monitoring Rept (per Tech Specs)

NOTES: 1cy NMSS/FCAF/PM. LPDR 2cys Transcripts. 05000387
 1cy NMSS/FCAF/PM. LPDR 2cys Transcripts. 05000388

	RECIPIENT		COPIES			RECIPIENT		COPIES	
	ID	CODE/NAME	L	T		ID	CODE/NAME	L	T
	PD1-2	LA	1	0		PD1-2	PD	1	1
		THADANI, M	5	5					
INTERNAL:	ACRS		1	1		AEOD/DOA		1	1
	AEOD/DSP/TPAB		1	1		ARM TECH ADV		1	1
	NRR/DEST/ADE		1	1		NRR/DREP/RPB		4	4
	<u>REG FILE</u>	01	1	1		RES DEPY GI		1	1
	RGN1 FILE	02	1	1		RGN2/DRSS/EPRPB		1	1
EXTERNAL:	LPDR		2	2		NRC PDR		1	1
NOTES:			3	3					

TOTAL NUMBER OF COPIES REQUIRED: LTR 26 ENCL 25



[The page contains extremely faint and illegible text, likely bleed-through from the reverse side. The text is scattered across the page and is not readable.]



Pennsylvania Power & Light Company

Two North Ninth Street • Allentown, PA 18101 • 215/770-5151

50-387,388

August 25, 1987

Mr. Ronald R. Ptashinski
Acting Sanitarian Supervisor
Bureau of Community Environmental Control
Pennsylvania Department of Environmental Resources
290 South Pennsylvania Boulevard
Wilkes-Barre, PA 18701

SUSQUEHANNA STEAM ELECTRIC STATION
DRINKING WATER POSTING REMOVAL
PWS 2400998, OPERATING PERMIT #4085504
CCN 741326 FILE R9-88
PLE- 9733

Dear Mr. Ptashinski:

On August 17, 1987, Pennsylvania Power & Light Company informed the Pennsylvania Department of Environmental Resources of our intent to remove a drinking water posting established earlier due to low chlorine residual. Per the Bureau's request, two samples of the drinking water were collected on August 21 and 22, 1987 for bacteriological analysis. The results of both of these samples indicated less than 2.2 most probable number of bacteria per 100 ml. Following verification of these sample results by telephone the posting was removed on August 24, 1987.

If you have any questions, please contact me at (215) 770-7891.

Respectfully yours,

Curtis H. Saxton

chs/1th1074b:cly

Copy to:

Mr. J. P. LaBuz	Pa DER
Mr. R. Sager	Pa DER
Dr. W. R. Butler	US NRC

8708280266 870825
PDR ADDCK 05000387
S PDR

IE25
1/0

