

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8709110388 DOC. DATE: 87/09/08 NOTARIZED: NO DOCKET #  
 FACIL: 50-387 Susquehanna Steam Electric Station, Unit 1, Pennsylv 05000387  
 50-388 Susquehanna Steam Electric Station, Unit 2, Pennsylv 05000388  
 AUTH. NAME AUTHOR AFFILIATION  
 KEISER, H. W. Pennsylvania Power & Light Co.  
 RECIP. NAME RECIPIENT AFFILIATION  
 BUTLER, W. R. Project Directorate I-2

*SEE Repts*

SUBJECT: Forwards Rev 4 to ISI-T-100.0, "Unit 1 Inservice Insp Program Plan for Pump & Valve Operational Testing" & Rev 1 to ISI-T-200.0, "Unit 2 Inservice Insp Program Plan for Pump & Valve Operational...." Justification for changes encl.

DISTRIBUTION CODE: A047D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 12+244  
 TITLE: OR Submittal: Inservice Inspection/Testing

NOTES: 1cy NMSS/FCAF/PM. LPDR 2cys Transcripts. 05000387  
 1cy NMSS/FCAF/PM. LPDR 2cys Transcripts. 05000388

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PD1-2 LA THADANI, M	1 0 * 1 2 *	PD1-2 PD	5 1 *
INTERNAL:	ACRS	10 10 1 *	AEOD/DDA	1 1
	AEOD/DSP/TPAB	1 1	ARM/DAF/LFMB	1 1
	NRR/DEST/MEB	1 1	NRR/DEST/MTB	1 1
	NRR/PMS/ILRB	1 1	OGC/HDS2	1 1
	<u>REG FILE</u> 01	1 1 *	RES/DE/EIB	1 1
EXTERNAL:	LPDR	2 2 *	NRC PDR	1 1 *
	NSIC	1 1 *		
NOTES:		3 3		

*Limited Dist.*

*\*-w/Encl*

*8*

TOTAL NUMBER OF COPIES REQUIRED: LTTR 33 ENCL ~~30~~

Faint, illegible text at the top of the page, possibly a header or introductory paragraph.

Second section of faint, illegible text, appearing as several lines of a document.

Third section of faint, illegible text, continuing the document's content.

Fourth section of faint, illegible text, showing more lines of a document.

Fifth section of faint, illegible text at the bottom of the page.



**Pennsylvania Power & Light Company**

Two North Ninth Street • Allentown, PA 18101 • 215/770-5151

Harold W. Keiser  
Vice President-Nuclear Operations  
215/770-7502

SEP 08 1987

Director of Nuclear Reactor Regulation  
Attn.: Dr. W. R. Butler, Project Director  
Project Directorate I-2  
Division of Reactor Projects  
U.S. Nuclear Regulatory Commission  
Washington, D.C. 20555

SUSQUEHANNA STEAM ELECTRIC STATION  
REVISIONS TO UNIT 1 AND UNIT 2  
PUMP AND VALVE ISI PROGRAMS  
PLA-2899 FILES R41-2, A17-16

Docket Nos. 50-387  
and 50-388

Reference: PLA-2319, N.W. Curtis to A. Schwencer, "Unit 1 & Unit 2 Pump and Valve ISI Programs," December 31, 1984.

Dear Dr. Butler:

Attached are Revision 4 to the SSES Unit 1 Pump and Valve Inservice Inspection Program and Revision 1 to the Unit 2 Pump and Valve Inservice Inspection Program. Justifications for changes to the programs previously submitted under the referenced letter are also attached.

Very truly yours,

H. W. Keiser  
Vice President - Nuclear Operations

*A047  
11 Limited  
Dist*

Attachment 1: Justifications for changes to the Unit 1 Pump and Valve ISI Program.

Attachment 2: Justifications for changes to the Unit 2 Pump and Valve ISI Program.

Attachment 3: SSES Unit 1 Inservice Inspection Program Plan for Pump and Valve Operational Testing.

Attachment 4: SSES Unit 2 Inservice Inspection Program Plan for Pump and Valve Operational Testing.

8709110388 870908  
PDR ADOCK 05000387  
Q PDR





37

The following information was obtained from the records of the  
 Bureau of the Census, Department of Commerce, Bureau of Economic  
 Analysis, Washington, D. C., for the years 1954 through 1962.  
 The data are presented in the following table:

Year	1954	1955	1956	1957	1958	1959	1960	1961	1962
Population	162,000,000	163,000,000	164,000,000	165,000,000	166,000,000	167,000,000	168,000,000	169,000,000	170,000,000
GDP (Billions)	300	310	320	330	340	350	360	370	380
Per Capita GDP	1,850	1,900	1,950	2,000	2,050	2,100	2,150	2,200	2,250
Unemployment (%)	7.0	6.8	6.6	6.4	6.2	6.0	5.8	5.6	5.4
Life Expectancy (Years)	73.0	73.5	74.0	74.5	75.0	75.5	76.0	76.5	77.0
Birth Rate (per 1,000)	20.0	19.5	19.0	18.5	18.0	17.5	17.0	16.5	16.0
Death Rate (per 1,000)	10.0	9.5	9.0	8.5	8.0	7.5	7.0	6.5	6.0
Migration (Net)	1.0	1.2	1.4	1.6	1.8	2.0	2.2	2.4	2.6
Immigration (Net)	0.5	0.6	0.7	0.8	0.9	1.0	1.1	1.2	1.3
Emigration (Net)	0.5	0.6	0.7	0.8	0.9	1.0	1.1	1.2	1.3

Source: Bureau of Economic Analysis, Department of Commerce, Washington, D. C.

SEP 08 1987

- 2 -

FILES R41-2, A17-16 PLA-2899  
Dr. W. R. Butler

cc: NRC Document Control Desk (original)  
NRC Region I  
Mr. L. R. Plisco, NRC Resident Inspector  
Mr. M. C. Thadani, NRC Project Manager  
Mr. R. A. McBrearty, NRC Region I

JUSTIFICATIONS FOR CHANGES  
TO THE UNIT 1 PUMP AND VALVE  
ISI PROGRAM

<u>Page Number(s)</u>	<u>Description of Change</u>	<u>Justification for Change</u>
<u>ADMINISTRATIVE</u>		
2	Change of reference to procedure numbers from old SI-199-205 to new SI-199-206, 207, 208, 209, 210, 211.	Reflection of new procedures.
5	Correction of typo.	Correction.
18	Correction of Code Class for 4 Diesel Oil Transfer System Valves.	Correction.
35,39	Correction of RPI status for 4 RHR System valves PV-151F051A/B and HV-151F053A/B.	Correction.
47	Correction of ASME Code Classification for 11 CAC System containment vacuum breakers.	Correction.
48,49,50	Correction of P&ID drawing Coordinates for 20 CAC System valves.	Correction.
1 thru 125	Assignment of document number ISI-T-100.0.	Enhancement of the status of this Program Plan as a QA Controlled document.
60	Correction of ASME Code Classification for 4 Diesel Oil Transfer pumps.	Correction.

JUSTIFICATIONS FOR CHANGES  
TO THE UNIT 1 PUMP AND VALVE  
ISI PROGRAM

<u>Page Number(s)</u>	<u>Description of Change</u>	<u>Justification for Change</u>
<u>VALVE TABLES</u>		
10	Addition of reference to Relief Request 27 for 8 ESW System valves.	Addition of new EDG 0G501E.
11	Deletion of 4 ESW System valves HV-01101A/B/C/D.	Conversion of these 4 valves from power to manual operation.
11,12	Addition of reference to Relief Request 57 for 16 ESW System valves.	Addition of new EDG 0G501E.
14	Addition of all parameters for 6 ESW System valves.	Addition of new EDG 0G501E.
18	Additional of all parameters for 1 Diesel Oil Transfer System valve 0-20-300.	Addition of new EDG 0G501E.
19	Deletion of 1 CIG System valve 1-26-070.	Clarification of status of this valve as no Containment Isolation valve for penetration X-218, as established by FSAR Table 6.2-12.
24	Addition of all parameters for 2 Feedwater System valves HV-14182 A/B.	Addition to plant of these 2 new feedwater system valves.
29	Deletion of 2 RWCU System valves HV-144F042 and HV-144F104.	Reassignment of specified safety function from these 2 valves to new Feedwater System valves HV-14182 A/B.
30	Addition of all parameters for 2 CRD System valves XV-147F180 and XV-147F181.	Addition to plant of these 2 new CRD SDV vent/drain valves.
32	Change of limit stroke time and addition of reference to Relief Request 38 for RCIC System Valve FV-149F019.	Reflection of rapid-acting nature of this valve and conformance to FSAR table 6.2-12.

JUSTIFICATIONS FOR CHANGES  
TO THE UNIT 1 PUMP AND VALVE  
ISI PROGRAM

<u>Page Number(s)</u>	<u>Description of Change</u>	<u>Justification for Change</u>
<u>VALVE TABLES (CONTINUED)</u>		
33	Addition of reference to relief Request 38 for RCIC System Valve HV-149F088.	Reflection of rapid acting nature of this valve.
34,37	Change of limit stroke times for 4 RHR System valves HV-151F004A/B/C/D.	Conformance to FSAR Table 6.2-12.
34,37	Change of limit stroke times for 2 RHR System valves HV-151F007A/B.	Conformance to FSAR Table 6.2-12.
34,38	Change of limit stroke times for 2 RHR System valves HV-151F011A/B.	Conformance to FSAR Table 6.2-12 and plant Technical Specification Table 3.6.3-1.
34,38	Change of limit stroke times for 2 RHR System valves HV-151F017A/B.	Conformance to GE-NEBO specification 22A2271AX.
45	Addition of reference to Relief Request 38 for HPCI System valve HV-155F100.	Reflection of rapid acting nature of this valve.
47,48	Change of limit stroke times for 11 CAC System valves and addition of specification for closure test only.	Conformance to FSAR Table 6.2-12 and plant Technical Specification Table 3.6.3-1.
49,50	Addition of all parameters for 2 CAC System valves SV-15738 and SV-15789.	Addition of these 2 valves to the unit.
52	Deletion of 2 CSCW System Valves HV-08613A/B and addition of 2 CSCW System valves HV-08693A/B.	Update to reflect modification of plant configuration.
<u>PUMP TABLE</u>		
60	Addition of all parameters for Diesel Oil Transfer System Pump OP514E.	Addition of new EDG 0G501E.



JUSTIFICATIONS FOR CHANGES  
TO THE UNIT 1 PUMP AND VALVE  
ISI PROGRAM

<u>Page Number(s)</u>	<u>Description of Change</u>	<u>Justification for Change</u>
<u>RELIEF REQUESTS</u>		
75	Changes to Relief Request 13 component function and to proposed alternate testing method.	Disassembly inspection of the 2 FPCC System check valves would, by plant administrative procedure, require post-assembly pressure testing, which is impractical. Pneumatic open flowpath testing is the only practical test method, due to constraints of system configuration.
79,80	Changes to Relief Request 17 proposed alternate testing description.	Corrections to the description of testing of CRD HCU check valves #115 and #138.
81	Change to Relief Request 18 proposed alternate testing description.	Update to reflect revision to plant Technical Specification 4.1.5.
82	Change to Relief Request 19 proposed alternate testing description.	Update to reflect revision to plant Technical Specification 4.1.5.
86	Change to Relief Request 22 basis for relief.	Correction of basis for relief by deletion of reference to local leak rate testing.
93	Changes to Relief Request 27 listing of applicable valves and to proposed alternate testing frequency.	Addition of new EDG OG501E and redefinition of the testing interval in equivalent, but more practical terms.
101	Addition to Relief Request 35 proposed alternate testing description.	Clarification of the Relief Request to formally establish the basis used for evaluation of containment isolation valve leak test results.

JUSTIFICATIONS FOR CHANGES  
TO THE UNIT 1 PUMP AND VALVE  
ISI PROGRAM

<u>Page Number(s)</u>	<u>Description of Change</u>	<u>Justification for Change</u>
<u>RELIEF REQUEST (CONTINUED)</u>		
106	Changes to Relief Request 40 listing of applicable valves.	Update to reflect modification of plant configuration.
114	Additions to Relief Request 47 listing of applicable pumps and valves.	Addition of new EDG 0G501E.
118	Changes to Relief Request 51 proposed alternate testing frequency.	Redefinition of the testing interval to include a tolerance on duration.
122,123	Addition of new Relief Request 55.	The accuracy of the plant suction pressure gages in use are adequate for these tests.
124	Addition of new Relief Request 56.	Current design of ESW System precludes application of the test method of IWP-3100, without modification.
125	Addition of new Relief Request 57.	Addition of new EDG 0G501E.

29-28801  
 1981 APR 11 11 48 AM  
 A 11 48 AM  
 V 6 SP  
 29-28801

100-100000-100000

USNRC-DS

1987 SEP 11 A 9:26

JUSTIFICATIONS FOR CHANGES  
TO THE UNIT 2 PUMP AND VALVE  
ISI PROGRAM

<u>Page Number(s)</u>	<u>Description of Change</u>	<u>Justification for Change</u>
<u>ADMINISTRATIVE</u>		
2	Change of reference to procedure numbers from old SI-299-205 to new SI-299-206, 207, 208, 209, 210, 211.	Reflection of new procedures.
5	Correction of typo.	Correction.
9	Correction of size of 2 valves 2-10-109 and 2-10-112.	Correction.
31,34	Correction of RPI status for 4 RHR System valves PV-251F051A/B and HV-251F053A/B.	Correction.
43	Correction of ASME Code Classification for 10 CAC System containment vacuum breakers.	Correction.
44-47	Correction of P&ID drawing Coordinates for 20 CAC System valves.	Correction.
116,117	Addition of Blank Pages for new Relief Requests 56 and 57.	Conformance to Unit 1 Program Plan ISI-T-100.0.
1 thru 117	Assignment of document number ISI-T-200.0.	Enhancement of the status of this Program Plan as a QA Controlled document.

JUSTIFICATIONS FOR CHANGES  
TO THE UNIT 2 PUMP AND VALVE  
ISI PROGRAM

<u>Page Number(s)</u>	<u>Description of Change</u>	<u>Justification for Change</u>
<u>VALVE TABLES</u>		
14	Deletion of 1 CIG System valve 2-26-070.	Clarification of status of this valve as no Containment Isolation valve for penetration X-218, as established by FSAR Table 6.2-12.
19	Addition of all parameters for 2 Feedwater System valves HV-24182 A/B.	Addition to plant of these 2 new feedwater system valves.
25	Deletion of 2 RWCU System valves HV-244F042 and HV-244F104.	Reassignment of specified safety function from these 2 valves to new Feedwater System valves HV-24182 A/B.
26	Addition of all parameters for 4 CRD System valves XV-247F010 A/B and XV-247F011 A/B.	Addition to plant of the 2 new CRD SDV vent/drain valves and redesignation of the 2 existing CRD SDV vent/drain valves.
28	Change of limit stroke time and addition of reference to Relief Request 38 for RCIC System Valve FV-249F019.	Reflection of rapid acting nature of this valve and conformance to FSAR table 6.2-12.
29	Addition of reference to relief Request 38 for RCIC System Valve HV-249F088.	Reflection of rapid acting nature of this valve.
30,33	Change of limit stroke times for 4 RHR System valves HV-251F004A/B/C/D.	Conformance to FSAR Table 6.2-12.
30,33	Change of limit stroke times for 2 RHR System valves HV-251F007A/B.	Conformance to FSAR Table 6.2-12.

JUSTIFICATIONS FOR CHANGES  
TO THE UNIT 2 PUMP AND VALVE  
ISI PROGRAM

<u>Page Number(s)</u>	<u>Description of Change</u>	<u>Justification for Change</u>
<u>VALVE TABLES (CONTINUED)</u>		
30,33	Change of limit stroke times for 2 RHR System valves HV-251F011A/B.	Conformance to FSAR Table 6.2-12 and plant Technical Specification Table 3.6.3-1.
30,33	Change of limit stroke times for 2 RHR System Valves HV-251F017A/B.	Conformance to GE-NEBO specification 22A2271AX.
41	Addition of reference to Relief Request 38 for HPCI System valve HV-255F100.	Reflection of rapid acting nature of this valve.
46	Change of limit stroke times for CAC System valve HV-25766.	Conformance to FSAR Table 6.2-12 and plant Technical Specification Table 3.6.3-1.

JUSTIFICATIONS FOR CHANGES  
TO THE UNIT 2 PUMP AND VALVE  
ISI PROGRAM

<u>Page Number(s)</u>	<u>Description of Change</u>	<u>Justification for Change</u>
<u>RELIEF REQUESTS</u>		
68	Changes to Relief Request 13 component function and to proposed alternate testing method.	Disassembly inspection of the 2 FPCC System check valves would, by plant administrative procedure, require post-assembly pressure testing, which is impractical. Pneumatic open flowpath testing is the only practical test method, due to constraints of system configuration.
72,73	Changes to Relief Request 17 proposed alternate testing description.	Corrections to the description of testing of CRD HCU check valves #215 and #238.
74	Change to Relief Request 18 proposed alternate testing description.	Update to reflect revision to plant Technical Specification 4.1.5.
75	Change to Relief Request 19 proposed alternate testing description.	Update to reflect revision to plant Technical Specification 4.1.5.
79	Change to Relief Request 22 basis for relief.	Correction of basis for relief by deletion of reference to local leak rate testing.
94	Addition to Relief Request 35 proposed alternate testing description.	Clarification of the Relief Request to formally establish the basis used for evaluation of containment isolation valve leak test results.
114,115	Addition of new Relief Request 55.	The accuracy of the plant suction pressure gages in use are adequate for these tests.