REGULATERY INFORMATION DISTRIBUTIO BYSTEM (RIDS)

• _ •

hat i							
ACCESSION FACIL: 50 50 AUTH. NA KEISER, N RECIP. N BUTLER, N	N NBR: 8710210052 D-387 Susquehanna D-388 Susquehanna AME AUTHOR H.W. Pennsyl NAME RECIPI W.R. Proj	DOC.DA Steam El Steam El AFFILIAT Vania Pou ENT AFFIL ect Direc	TE: ectr ION er & IATI tora	87/10/15 NOTARIZED ic Station, Unit 1, ic Station, Unit 2, Light Co. ON te I-2	YES Pennse Pennse	ylva ylva	DOCKET # 05000387 05000388
SUBJECT	: Application for Tech Specs to a diesel generato paid.	amends t llow adju r loading	o Li stme tim	censes NPF-14 & NPF nt of required tole ers associated w/RH	-22, re rance R pumps	visin for s.Fee	9
DISTRIBUTION CODE: A001D COPIES RECEIVED:LTR LENCL SIZE: 445 TITLE: OR Submittal: General Distribution							
NOTES: 10	cy NMSS/FCAF/PM. cy NMSS/FCAF/PM.	LPDR 2cy LPDR 2cy	s Tr s Tr	anscripts. anscripts.			05000387 05000388
	RECIPIENT ID CODE/NAME PD1-2 LA THADANI,M	COPIES LTTR E 1 1	NCL. 0 1	RECIPIENT ID CODE/NAME PD1-2 PD	COP LTTR 5	IES ENCL 5	
INTERNAL:	ACRS NRR/DEST/ADS NRR/DEST/MTB NRR/DOEA/TSB OGC/HDS2 RES/DE/EIB	6 1 1 1 1	6 1 1 0 1	ARM/DAF/LFMB NRR/DEST/CEB NRR/DEST/RSB NRR/DEST/RSB NRR/PMAS/ILRB REG FILE 01	1 1 1 1	0 .1 1 1	
EXTERNAL:	EG&G BRUSKE,S NRC PDR	1 1	1 1	LPDR ·	2	2 1	

NOTES:

W Cheere \$ 150 # 793233

3

З

TOTAL NUMBER OF COPIES REQUIRED: LTTR 31 ENCL 28

'n

e i i



Pennsylvania Power & Light Company

Two North Ninth Street • Allentown, PA 18101 • 215 / 770-5151

OCT 1 5 1987

Harold W. Keiser Vice President-Nuclear Operations 215/770-7502

Director of Nuclear Reactor Regulation Attention: Dr. W. R. Butler, Project Director Project Directorate I-2 Division of Reactor Projects U.S. Nuclear Regulatory Commission Washington, D.C. 20555

1987 OCT 20 A 9

SUSQUEHANNA STEAM ELECTRIC STATION PROPOSED AMENDMENTS 104 AND 54 TO LICENSE NOS. NPF-14 AND NPF-22 PLA-2931 FILES A17-2, R41-2

Docket Nos. 50-387 and 50-388

Dear Dr. Butler:

The purpose of this letter is to propose changes to the Susquehanna SES Units 1 and 2 Technical Specifications in order to allow adjustment of the required tolerance for the diesel generator loading timers associated with the RHR pumps.

BACKGROUND

8710210052 87101

Technical Specification Surveillance Requirement 4.8.1.1.2d.12 states the following:

"(Each of the above required diesel generators shall be demonstrated OPERABLE (by)): Verifying that each diesel generator loading sequence timer shown in Table 4.8.1.1.2-2 is OPERABLE with its setpoint within ±10% of its design setpoint."

There is no explicit Bases provided for this requirement, but $\pm 10\%$ is an accepted tolerance for these instruments when their setpoints are at the midpoint of their range. In the specific case of the RHR pump timers, difficulty has been experienced in meeting the upper ($\pm 10\%$) side of the setpoint tolerance, and it is believed that this is because the setpoint (3.0 seconds) is at the low end of the timer range (1.5 to 15 seconds).

PP&L is proposing that Specification 4.8.1:1.2d.12 be revised as follows (see attached marked up pages):

· · · · 4

,

Na Re L r

131 CC2 م المحمدي الوشاري العلمة الله المحمل المراجع المحمل المراجع المحملة المحملة المحملة المحمل المراجع المحمل المراجع المحمد المراجع المحمل المحم المحمد المراجع المحمل المحم • > <u>ہ</u> a term of a trate and a second and a second and a second and a second and a second and a second and a second and a second Ç ς. 43 and the second second second second second

Received and the second second

•

ې د او د او د او د او

Δ.

¥

.

and speed in the **Long Extension** of a solution of the **green of the green of the Long E**arth and the green and green and green and green and green on the green of the second the second the second the second the s and second the second th بر مراجع ما الم

.

GANO> X B. ..

e Fui Fair a a

المادم الذي المُعْلَم الذي المادي المراجع التي العالي التي التي الم يعهد المحادية المحادية المحادية المحادية ال المادي المحادية المحادية المحادية المحادية التي المحادية الذي المحادية المحادية المحادية المحادية المحادية المح المحادية الحادية الذي المادية في محادية المحادية الذي المادية في محادية المحادية المحادية المحادية المحادية المحادية المحادية المحادية المحادي

\$

الا المحمد التي التي التي المحمد ا المحمد المحمد التي المحمد ا N

> . . 1

OCT 1 5_1987

FILE A17-2, R41-2 PLA-2931 Dr. W. R. Butler

"(Each of the above required diesel generators shall be demonstrated OPERABLE (by)): Verifying that each diesel generator loading sequence timer shown in Table 4.8.1.1.2-2 is OPERABLE with its setpoint within ±10% of its design setpoint, except for the RHR pump timers, which may have a tolerance of +20%, -10%. "

2 -

This change is acceptable based on our review of the impact of this change on both ECCS response time and diesel generator load sequencing as described below. Please be advised that we have considered replacement of the subject timers in order to preclude the need for this request, but our conclusion was that the costs associated with such an action considerably outweighed any perceptible safety benefit from being able to achieve +10% precision on the timer setting.

JUSTIFICATION

The setpoints for the RHR pump timers are selected such that:

- the Low Pressure Coolant Injection (LPCI) flow enters the vessel to cool the core in sufficient time to assure peak fuel cladding temperature remains below 2200°F during a LOCA, and
- 2) the diesel generator electrical bus voltage remains high enough to prevent an undervoltage trip during the loading of all major equipment.

The proposed change in the upper tolerance of the timer setting from +10% (0.3. seconds) to +20% (0.6 seconds) is evaluated below against both of the above criteria.

o Criterion 1: ECCS Response Time

Both of the fuel suppliers for Susquehanna, General Electric and Advanced Nuclear Fuels (ANF), have analyzed the timing of the ECCS pump startup and valve opening sequence during a large, suction-side, recirculation break LOCA. These analyses indicate that an additional 0.3, second delay in the RHR pump startup would have no effect on LPCI injection time. This is because even with the additional delay, the RHR pumps reach rated speed at least one full second prior to the vessel pressure reaching the assumed LPCI injection valve opening permissive of 400 psi. The discharge side recirculation break and small break LOCAs result in reaching the LPCI valve opening permissive even later into the event sequence. Therefore the proposed additional 0.3 second delay in the RHR pump start signal has no affect on these events either.

o Criterion 2: Diesel Generator Load Sequencing

The concern with this criterion is to ensure that the RHR and Core Spray pumps are not started close enough together that an undervoltage trip could occur. •

41 E

The states are the to construct of the 2 is

•

TRANSPORT BANK

· . . .

• •

- and a start of the second start A start of the second start of t A start of the second start of the se
- . . .

data en en la seconda de l La seconda de

and I and again the Article of the set of the set

المراجع معاد المراجع معاد المراجع على المراجع على أن من مراجع أن من مراجع الله المراجع من مراجع من مراجع المراجع المر المراجع ا المراجع الم المراجع ال المراجع المحا المراجع المراجع المراجع المراجع المراجع المراجع ال

a Gran Star St. M. el G a reactor frace Segur and

م محمد می بود و در در این می و مرافق به را در در به هم هو در آمای است. از م



FILE A17-2, R41-2 PLA-2931 Dr. W. R. Butler

The RHR and Core Spray pump timers are normally set at 3.0 and 10.5 seconds, respectively, with a $\pm 10\%$ margin on pickup. With the proposed change to $\pm 20\%$ in place for the RHR timers, the worst case scenario would have the RHR pump starting at $3.0 \pm 0.6 = 3.6$ seconds and the Core Spray pump starting at 10.5 - 1.1 = 9.4 seconds. This provides a 5.8 second (9.4-3.6) window for the RHR pump to start; the diesel generator response when the RHR pump motor is energized was evaluated against this interval.

- 3 -

Strip Charts for each diesel were investigated for minimum/maximum voltage levels and the time at which each occurs. Diesel generator "D" was used as a basis because it exhibited the longest response time to reach maximum voltage after the RHR pump starts (see figure 1). A minimum voltage of 3100V (75% of maximum) is reached 0.25 seconds after the RHR pump starts. 100% voltage (4160V) is reached 2.6 seconds after the RHR pump starts.

Our calculations indicate a start time of 2.7 seconds for an RHR pump at 100% voltage. Thus, the worst case start time for an RHR pump is 2.6 + 2.7 = 5.3 seconds. This value is conservative because it does not take into account the acceleration of the RHR pump motor during the time the motor voltage is less than 100%. Comparing the start time of the RHR pump (5.3 seconds) with the available window (5.8 seconds) conservatively provides 0.5 seconds margin to avoid an undervoltage trip. This time is sufficient to justify changing the upper tolerance of the RHR timer from +10% to +20%.

NO SIGNIFICANT HAZARDS DETERMINATION

The proposed changed does not:

- I. Involve a significant increase in the probability or consequences of an accident previously evaluated. Both ECCS response time and diesel generator load sequencing were evaluated in light of this proposal. The conclusions of these evaluations were:
 - a. LPCI injection is unaffected for the LOCA break spectrum since injection cannot begin until the vessel low pressure permissive is reached, and even with the proposed change, this pressure still occurs after the RHR pump start.
 - b. Sufficient time exists between the starting of the RHR and the Core Spray pumps to ensure that diesel generator loading capability is not jeopardized.

Based on these conclusions, no significant change occurs to the probability or consequences of any previously analyzed accident.

II. Create the possibility of a new or different kind of accident from any accident previously evaluated. This change only affects the timing of previously analyzed event sequences as analyzed in I above. It does not propose any physical or functional changes that could create the possibility of a new event. the state of the s

C. C. De De de la complete de la complete de la complete de de la complete de la co

م الدي فرقي الاست الذي المحالية المحالية التي العالم الأن العالي المحالي المحالي المحالي المحالية من المحالية م المحالي المحالي المحالية المحالية المحالية المحالية المحالية العالم المحالية المحالية المحالية المحالية المحالية المحالي المحالية المح المحالية المح

NO SIGNIMICANT MULANDA MARSH MARSH 140

الما با برازم ^منحو⁵ الم الا الى الأما ا

1 de la composición de la comp

.

.

• •

•

- ి ఉన్న విజనవారంగా సంగారణ గ్రామం ప్రాటింగి సినిమాలు స్రామింగి సినిమాలు స్రామింగి స్రామింగి సినిమాలు. గ్రామం ప్రహాసం ప్రాటింగి గ్రామం కకరిళ గ్రామం గ్రామం
- الآن و الاردون من بولان المحالية في المحالية التي المحالية المحالية المحالية المحالية المحالية المحالية المحالي المحالية الآن المحالية الاردون من كلف اللاردون المحالية المحالية المحالية المحالية المحالية المحالية المحالية ا المحالية الم المحالية الم



FILE A17-2, R41-2 PLA-2931 Dr. W. R. Butler

III. Involve a significant reduction in a margin of safety. With respect to ECCS response time, no delay occurs in LPCI injection due to this change. For diesel generator load sequencing, the worst-case scenario was conservatively evaluated and the gap between RHR and Core Spray pump starts changed from 0.8 to 0.5 seconds. This change is not significant because the gap has not been reduced to the level where calculational uncertainties could overcome it and thereby result in overlap between the pump starts. Based on the above, no significant reduction in any safety margin will occur due to this change.

Any questions on the above material should be directed to Mr. R. Sgarro at (215) 770-7916. Pursuant to 10CFR170, the appropriate fee is enclosed.

Very truly yours,

N Keises

H. W. Keiser Vice President-Nuclear Operations

Attachments

cc: NRC Document_Control_Desk (original)
NRC Region I
Mr. L. R. Plisco, NRC Resident Inspector
Mr. M. C. Thadani, NRC Project Manager
Mr. T. M. Gerusky, Pa DER



ار هو التروم أي من الحج المحالة ويوده كالما الله المربوع المحلّة المحالية المحلّة المحالية المحلية المح المحلية ا المحلية المحل المحلية الم المحلية الم المحلية الم المحلية المحل

n and that is not a tale that is there in the late of the first of the second second state and the term of the A second the second s

a sta statistica

اړ**. ۲۰ ۱۰ دی.** ۲۲۵۰ اس وړه • د آمد ۲۰ د

T Sal Star 1 845