


ANF-87-126  
REVISION 1



**ADVANCED NUCLEAR FUELS CORPORATION**

---

SUSQUEHANNA UNIT 2 CYCLE 3 RELOAD ANALYSIS  
DESIGN AND SAFETY ANALYSES.

NOVEMBER 1987

AN AFFILIATE OF KRAFTWERK UNION



8712310158 871223  
PDR ADOCK 05000388  
P ... POA

**ADVANCED NUCLEAR FUELS CORPORATION**

ANF-87-126  
Revision 1  
Issue Date: 11/25/87

**SUSQUEHANNA UNIT 2 CYCLE 3 RELOAD ANALYSIS**

**Design and Safety Analyses**

Prepared By:

  
\_\_\_\_\_  
J. A. White  
BWR Safety Analysis  
Licensing and Safety Engineering  
Fuel Engineering and Technical Services

**CUSTOMER DISCLAIMER**

**IMPORTANT NOTICE REGARDING CONTENTS AND USE OF THIS  
DOCUMENT**

**PLEASE READ CAREFULLY**

Advanced Nuclear Fuels Corporation's warranties and representations concerning the subject matter of this document are those set forth in the Agreement between Advanced Nuclear Fuels Corporation and the Customer pursuant to which this document is issued. Accordingly, except as otherwise expressly provided in such Agreement, neither Advanced Nuclear Fuels Corporation nor any person acting on its behalf makes any warranty or representation, expressed or implied, with respect to the accuracy, completeness, or usefulness of the information contained in this document, or that the use of any information, apparatus, method or process disclosed in this document will not infringe privately owned rights; or assumes any liabilities with respect to the use of any information, apparatus, method or process disclosed in this document.

The information contained herein is for the sole use of Customer.

In order to avoid impairment of rights of Advanced Nuclear Fuels Corporation in patents or inventions which may be included in the information contained in this document, the recipient, by its acceptance of this document, agrees not to publish or make public use (in the patent use of the term) of such information until so authorized in writing by Advanced Nuclear Fuels Corporation or until after six (6) months following termination or expiration of the aforesaid Agreement and any extension thereof, unless otherwise expressly provided in the Agreement. No rights or licenses in or to any patents are implied by the furnishing of this document.

TABLE OF CONTENTS

| <u>Section</u>  | <u>Page</u> |
|---|-------------|
| 1.0 INTRODUCTION.....                                     | 1           |
| 2.0 FUEL MECHANICAL DESIGN ANALYSIS.....                  | 2           |
| 3.0 THERMAL HYDRAULIC DESIGN ANALYSIS.....                | 3           |
| 3.2 Hydraulic Characterization.....                       | 3           |
| 3.2.1 Hydraulic Compatibility.....                        | 3           |
| 3.2.3 Fuel Centerline Temperature.....                    | 3           |
| 3.2.5 Bypass Flow.....                                    | 3           |
| 3.3 MCPR Fuel Cladding Integrity Safety Limit.....        | 3           |
| 3.3.1 Coolant Thermodynamic Condition.....                | 3           |
| 3.3.2 Design Basis Radial Power Distribution.....         | 4           |
| 3.3.3 Design Basis Local Power Distribution.....          | 4           |
| 4.0 NUCLEAR DESIGN ANALYSIS.....                          | 5           |
| 4.1 Fuel Bundle Nuclear Design Analysis.....              | 5           |
| 4.2 Core Nuclear Design Analysis.....                     | 5           |
| 4.2.1 Core Configuration.....                             | 5           |
| 4.2.2 Core Reactivity Characteristics.....                | 6           |
| 4.2.4 Core Hydrodynamic Stability.....                    | 6           |
| 5.0 ANTICIPATED OPERATIONAL OCCURRENCES.....              | 7           |
| 5.1 Analysis Of Plant Transients At Rated Conditions..... | 7           |
| 5.2 Analyses For Reduced Flow Operation.....              | 7           |
| 5.3 Analyses For Reduced Power Operation.....             | 8           |
| 5.4 ASME Overpressurization Analysis.....                 | 8           |
| 5.5 Control Rod Withdrawal Error (CRWE).....              | 8           |
| 5.6 Fuel Loading Error.....                               | 9           |
| 5.7 Determination Of Thermal Margins.....                 | 9           |
| 6.0 POSTULATED ACCIDENTS.....                             | 10          |
| 6.1 Loss-Of-Coolant Accident.....                         | 10          |
| 6.1.1 Break Location Spectrum.....                        | 10          |

TABLE OF CONTENTS  
(Continued)

| <u>Section</u>   | <u>Page</u> |
|--|-------------|
| 6.1.2 Break Size Spectrum.....                               | 10          |
| 6.1.3 MAPLHGR Analyses.....                                  | 10          |
| 6.2 Control Rod Drop Accident.....                           | 11          |
| 7.0 TECHNICAL SPECIFICATIONS.....                            | 12          |
| 7.1 Limiting Safety System Settings.....                     | 12          |
| 7.1.1 MCPR Fuel Cladding Integrity Safety Limit.....         | 12          |
| 7.1.2 Steam Dome Pressure Safety Limit.....                  | 12          |
| 7.2 Limiting Conditions For Operation.....                   | 12          |
| 7.2.1 Average Planar Linear Heat Generation Rate Limits..... | 12          |
| 7.2.2 Minimum Critical Power Ratio.....                      | 13          |
| 7.2.3 LHGR Limits.....                                       | 14          |
| 7.3 Surveillance Requirements.....                           | 14          |
| 7.3.1 Scram Insertion Time Surveillance.....                 | 14          |
| 7.3.2 Stability Surveillance.....                            | 14          |
| 8.0 METHODOLOGY REFERENCES.....                              | 15          |
| 9.0 ADDITIONAL REFERENCES.....                               | 16          |

APPENDICES

|                                 |     |
|---------------------------------|-----|
| A. SINGLE LOOP OPERATION.....   | A-1 |
| B. SEISMIC-LOCA EVALUATION..... | B-1 |

LIST OF TABLES

| <u>Table</u> |   | <u>Page</u> |
|--------------|---|-------------|
| 4.1          | Neutronic Design Values.....  | 23          |
| B.1          | Comparison Of Physical And Structural Characteristics<br>For 8x8 And 9x9 Fuel Assemblies..... | B-2         |

LIST OF FIGURES

| <u>Figure</u> |   | <u>Page</u> |
|---------------|---|-------------|
| 3.1           | Susquehanna Unit 2 Cycle 3 Hydraulic Demand Curve<br>Power vs. Flow.....                                      | 17          |
| 3.2           | Susquehanna Unit 2 Cycle 3 Design Basis Radial Power.....   | 18          |
| 3.3           | Design Basis Local Power Distribution - ANF XN-2 9x9 Fuel.....  | 19          |
| 3.4           | Design Basis Local Power Distribution - ANF XN-1 9x9 Fuel.....  | 20          |
| 3.5           | Design Basis Local Power Distribution - GE 8x8R (Central)<br>Fuel.....  | 21          |
| 3.6           | Design Basis Local Power Distribution - GE (Peripheral)<br>8x8R Fuel.....                                     | 22          |
| 4.1           | Susquehanna Unit 2 Cycle 3 Enrichment Distribution For<br>ANF92-344L-9G4 XN-2 Fuel Lattice.....               | 24          |
| 4.2           | Susquehanna Unit 2 Cycle 3 Enrichment Distribution For<br>ANF92-344L-10G5 XN-2 Fuel Lattice.....              | 25          |
| 4.3           | Susquehanna Unit 2 Cycle 3 Reference Core Loading Plan.....   | 26          |
| 4.4           | Susquehanna Unit 2 Cycle 3 - Core Power vs. Core Flow.....  | 27          |
| 5.1           | Susquehanna Unit 2 Cycle 3 Control Rod Withdrawal Error<br>Analysis Limiting Initial Control Rod Pattern..... | 28          |
| 5.2           | Susquehanna Unit 2 Cycle 3 Flow MCPR Operating Limit.....   | 29          |

11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28  
29  
30  
31  
32  
33  
34  
35  
36  
37  
38  
39  
40  
41  
42  
43  
44  
45  
46  
47  
48  
49  
50  
51  
52  
53  
54  
55  
56  
57  
58  
59  
60  
61  
62  
63  
64  
65  
66  
67  
68  
69  
70  
71  
72  
73  
74  
75  
76  
77  
78  
79  
80  
81  
82  
83  
84  
85  
86  
87  
88  
89  
90  
91  
92  
93  
94  
95  
96  
97  
98  
99  
100

## 1.0 INTRODUCTION

This report provides the results of the analyses performed by Advanced Nuclear Fuels Corporation (ANF)\* in support of the Cycle 3 reload for Susquehanna Unit 2, which is scheduled to commence operation in the spring of 1988. This report is intended to be used in conjunction with ANF topical report XN-NF-80-19(P)(A), Volume 4, Revision 1, "Application of the Exxon Nuclear Company Methodology to BWR Reloads," which describes the analyses performed in support of this reload, identifies the methodology used for those analyses, and provides a generic reference list. However, LHGR mechanical design limits (Reference 9.1) and plant transient simulation model developments (Reference 9.2) have been revised by ANF subsequent to NRC approval of XN-NF-80-19(P)(A), Volume 4, Revision 1. Both References 9.1 and 9.2 have been approved by the NRC for use in referencing in license applications. Section numbers in this report are the same as corresponding section numbers in XN-NF-80-19(P)(A), Volume 4, Revision 1.

The Susquehanna Unit 2 Cycle 3 core will comprise a total of 764 fuel assemblies, including 236 unirradiated ANF XN-2 9x9 assemblies, 324 irradiated ANF XN-1 9x9 assemblies, 112 irradiated General Electric 8x8R fuel assemblies (central region), and 92 irradiated GE 8x8R assemblies in the peripheral region. The reference core configuration is described in Section 4.2.

The design and safety analyses reported in this document were based on the design and operational assumptions in effect for Susquehanna Unit 2 during the previous operating cycle. Additional information and the results of design studies covering the development of 9x9 fuel assemblies for BWR reloads are contained in Reference 9.3.

---

\*Formerly Exxon Nuclear Company (ENC).





002  
227

2.0 FUEL MECHANICAL DESIGN ANALYSIS

Applicable ANF Fuel Design Report:

Reference 9.1

To assure that the expected power history for the fuels to be irradiated during Cycle 3 of Susquehanna Unit 2 is bounded by the assumed power history in the fuel mechanical design analysis, LHGR operating limits (Figure 3.3 of Reference 9.1) have been specified. In addition, an LHGR transient operating limit for Anticipated Operating Occurrences (Figure 3.4 of Reference 9.1) has been specified for ANF 9x9 fuel. Additional information on rod bow, as requested in the NRC's safety evaluation report for Reference 9.1, has been transmitted in Reference 9.4.

3.0 THERMAL HYDRAULIC DESIGN ANALYSIS3.2 Hydraulic Characterization3.2.1 Hydraulic Compatibility

Component hydraulic resistances for the constituent fuel types in the Susquehanna Unit 2 Cycle 3 core have been determined in single phase flow tests of full scale assemblies. Figure 3.1 shows the hydraulic demand curves for ANF 9x9 fuel and GE 8x8R fuel in the Susquehanna Unit 2 core. The similar hydraulic performance indicates compatibility for co-residence in the Susquehanna Unit 2 core.

3.2.3 Fuel Centerline Temperature

Applicable Generic Report

Reference 9.1

3.2.5 Bypass Flow

Calculated Bypass Flow Fraction  
at 104% Power/100% Flow

10.1%

3.3 MCPR Fuel Cladding Integrity Safety Limit

Safety Limit MCPR = 1.06

3.3.1 Coolant Thermodynamic Condition

|                                |              |
|--------------------------------|--------------|
| Rated Thermal Power            | 3293 MWt     |
| Feedwater Flowrate (at SLMCPR) | 16.1 Mlbm/hr |
| Core Pressure (at SLMCPR)      | 1042.9 psia  |
| Feedwater Temperature          | 383°F        |

3.3.2 Design Basis Radial Power Distribution

See Figure 3.2

3.3.3 Design Basis Local Power Distribution

See Figures 3.3 through 3.6

4.0 NUCLEAR DESIGN ANALYSIS4.1 Fuel Bundle Nuclear Design Analysis

|                                |  |
|--------------------------------|--|
| Assembly Average Enrichment    | 3.33%  |
| Radial Enrichment Distribution | Figure 4.1 and 4.2   |
| Axial Enrichment Distribution  | Uniform 3.44%<br>with 6" natural<br>uranium top<br>blanket |

## Burnable Poisons

Figure 4.1 and 4.2

Note: Burnable poisons are distributed uniformly over the enriched length of the designated rods. The natural uranium axial blanket sections do not contain burnable absorber material.

## Non-Fueled Rods

Figure 4.1 and 4.2

## Neutronic Design Parameters

Table 4.1

4.2 Core Nuclear Design Analysis4.2.1 Core Configuration

Figure 4.3

|  |         |
|--|---------|
| Core Exposure at EOC2, Mwd/MTU                       | 18350.7 |
| Core Exposure at BOC3, Mwd/MTU                       | 10911.2 |
| Core Exposure at EOC3, Mwd/MTU                       | 21740.8 |
| Maximum Cycle 3 Licensing Exposure<br>Limit, Mwd/MTU | 22076   |

4.2.2 Core Reactivity Characteristics

|   |           |
|---|-----------|
| BOC Cold K-effective, All Rods Out                                    | 1.11353   |
| BOC Cold K-effective, Strongest Rod Out                               | 0.98524   |
| Reactivity Defect (R-Value)   | 0.00% rho |
| Standby Liquid Control System Reactivity,<br>Cold Conditions, 660 ppm | 0.98348   |

4.2.4 Core Hydrodynamic Stability

Power/Flow Map Figure 4.4

| <u>Power/Flow State Points</u> | <u>Decay Ratio (COTRAN)</u> |
|--------------------------------|-----------------------------|
| 64/42*                         | 0.82                        |
| 69/47**                        | 0.75                        |
| 66/45**                        | 0.75                        |

---

\*Two pump minimum flow - APRM Rod Block intercept point. Extended operation at lower flow is not allowed by Technical Specifications.

\*\*Operation at less than 45% flow requires APRM/LPRM surveillance. In addition, operation at power/flow combinations above and to the left of the line connecting these two points requires APRM/LPRM surveillance. See Figure 4.4.

5.0 ANTICIPATED OPERATIONAL OCCURRENCES

Applicable Generic Transient  
Analysis Methodology Report

References 9.5 &amp; 9.7

5.1 Analysis Of Plant Transients At  
Rated Conditions

Reference 9.6

Limiting Transient(s): Load Rejection Without Bypass (LRWB)  
Feedwater Controller Failure (FWCF)  
Loss of Feedwater Heating (LFWH)

| <u>Event</u> | <u>Power*</u> | <u>Flow</u> | <u>% Rated<br/>Maximum<br/>Heat Flux</u> | <u>% Rated<br/>Maximum<br/>Power</u> | <u>Maximum<br/>Pressure<br/>(psia)</u> | <u>Delta<br/>CPR**</u> | <u>Model</u>          |
|--------------|---------------|-------------|--|--------------------------------------|--|------------------------|-----------------------|
| LRWB         | 100%          | 100%        | 116.2%                                   | 267%                                 | 1194                                   | 0.24                   | COTRANSA/<br>XCOBRA-T |
| FWCF         | 100%          | 100%        | 116.8%                                   | 233%                                 | 1179                                   | 0.23                   | COTRANSA/<br>XCOBRA-T |
| LFWH         | 100%          | 100%        | 121.3%                                   | 123%                                 | 1078                                   | 0.16                   | PTSBWR3/<br>XCOBRA    |

Single Loop Operation:

Appendix A

5.2 Analyses For Reduced Flow Operation

Reference 9.6

Limiting Transient(s): Recirculation Flow Increase Transient (RFIT)

---

\*104% power used in analysis as design bases.

\*\*Delta-CPR results for most limiting fuel type.

5.3 Analyses For Reduced Power Operation

Reference 9.6

Limiting Transient(s): Feedwater Controller Failure (FWCF)

| <u>% Power</u> | <u>Transient</u> | <u>Delta CPR</u> |                |
|----------------|------------------|------------------|----------------|
|                |                  | <u>ANF 9x9</u>   | <u>GE 8x8R</u> |
| 104            | FWCF             | 0.23             | 0.20           |
| 80             | FWCF             | 0.25             | 0.23           |
| 65             | FWCF             | 0.28             | 0.26           |
| 40             | FWCF             | 0.31             | 0.28           |

5.4 ASME Overpressurization Analysis

Reference 9.6

Limiting Event

Full MSIV

Isolation

Worst Single Failure

Direct Scram

Maximum Pressure

1297 psig

Maximum Steam Dome Pressure

1281 psig

5.5 Control Rod Withdrawal Error (CRWE)

Starting Control Rod Pattern for Analysis

Figure 5.1

| <u>Rod Block Setting</u> | <u>100% Flow</u>               |                  |
|--------------------------|--------------------------------|------------------|
|                          | <u>Distance Withdrawn (ft)</u> | <u>Delta CPR</u> |
| 105                      | 4.0                            | 0.22             |
| 106*                     | 4.5                            | 0.24             |
| 107                      | 5.0                            | 0.26             |
| 108*                     | 5.0                            | 0.26             |

\*Rod Block Monitor settings recommended for Cycle 3 operation.



5.6 Fuel Loading Error

Maximum Delta CPR 0.16

5.7 Determination Of Thermal Margins

## Summary of Thermal Margin Requirements

| <u>Event</u> | <u>Power</u> | <u>Flow</u> | <u>Delta CPR*</u>                    | <u>MCPR Limit</u> |
|--------------|--------------|-------------|--------------------------------------|-------------------|
| LRWB         | 100%**       | 100%        | 0.24                                 | 1.30              |
| FWCF         | 100%**       | 100%        | 0.23                                 | 1.29              |
| LFWH         | 100%**       | 100%        | 0.16                                 | 1.22              |
| CRWE         | 100%         | 100%        | 0.24 at 106% RBM<br>0.26 at 108% RBM | 1.30<br>1.32      |

## MCPR Operating Limits at Rated Conditions

MCPR Operating Limit1.30 at 106% RBM  
1.32 at 108% RBM

## Reduced Flow MCPR Limits

Figure 5.2

## Power Dependent MCPR Operating Limit Results for Cycle 3:

| <u>% Power/% Flow</u> | <u>Limiting<br/>Transient</u> | <u>ANF 9x9</u> | <u>GE 8x8R</u> |
|-----------------------|-------------------------------|----------------|----------------|
| 100**/100             | LRWB                          | 1.30           | 1.27           |
| 80/100                | FWCF                          | 1.31           | 1.29           |
| 65/100                | FWCF                          | 1.34           | 1.32           |
| 40/100                | FWCF                          | 1.37           | 1.34           |

\*Delta CPR results for most limiting fuel type.

\*\*104% power used in analysis as design bases.



6.0 POSTULATED ACCIDENTS6.1 Loss-Of-Coolant Accident

Seismic-LOCA:

Appendix B

6.1.1 Break Location Spectrum

Reference 9.8

6.1.2 Break Size Spectrum

Reference 9.8

6.1.3 MAPLHGR Analyses

ANF 9x9 Fuel

Reference 9.9

Limiting Break: Double-ended guillotine pipe break  
Recirculation pump discharge line  
0.4 Discharge Coefficient

| <u>Bundle Average<br/>Exposure<br/>(GWD/MTU)</u> | <u>MAPLHGR<br/>(kw/ft)</u> | <u>Peak Clad<br/>Temperature*<br/>(Degree F)</u> | <u>Peak Local<br/>MWR**<br/>(Percent)</u> |
|--|----------------------------|--|---|
| 0  | 10.2                       | 2060   | 3.9                                       |
| 5  | 10.2                       | 2069   | 3.7                                       |
| 10   | 10.2                       | 2121   | 3.7                                       |
| 15   | 10.2                       | 2140   | 4.8                                       |
| 20   | 10.2                       | 2147   | 5.2                                       |
| 25   | 9.6                        | 2016   | 2.7                                       |
| 30   | 8.9                        | 1839   | 1.0                                       |
| 35   | 8.2                        | 1752   | 0.7                                       |
| 40   | 7.5                        | 1676   | 0.5                                       |

\*Peak clad temperatures for XN-1 and XN-2 fuel are bounded by these results.

\*\*Metal Water Reaction.

6.2 Control Rod Drop Accident

Section 8.0

|   |                          |
|---|--------------------------|
| Dropped Control Rod Worth, mk               | 13.5                     |
| Doppler Coefficient, $1/k dk/dT$            | $-10.6 \times (10)^{-6}$ |
| Effective Delayed Neutron Fraction          | 0.0058                   |
| Four-Bundle Local Peaking Factor            | 1.34                     |
| Maximum Deposited Fuel Rod Enthalpy, cal/gm | 205                      |
| Number of Rods Exceeding 170 cal/gm         | <250                     |

7.0 TECHNICAL SPECIFICATIONS

7.1 Limiting Safety System Settings

7.1.1 MCPR Fuel Cladding Integrity Safety Limit

MCPR Safety Limit 1.06

7.1.2 Steam Dome Pressure Safety Limit

Pressure Safety Limit (as measured in steam dome) 1325 psig

Analysis shows that a steam dome pressure safety limit of 1358 psig is allowed but the 1325 psig value used in Cycle 2 is to be conservatively retained.

7.2 Limiting Conditions For Operation

7.2.1 Average Planar Linear Heat Generation Rate Limits

| <u>Bundle Average Exposure (GWD/MT)</u> | <u>MAPLHGR Limits (kw/ft) ANF 9x9 Fuel</u> |
|---|--|
| 0                                       | 10.2                                       |
| 5                                       | 10.2                                       |
| 10                                      | 10.2                                       |
| 15                                      | 10.2                                       |
| 20                                      | 10.2                                       |
| 25                                      | 9.6  |
| 30                                      | 8.9  |
| 35                                      | 8.2  |
| 40                                      | 7.5  |

7.2.2 Minimum Critical Power Ratio

MCPR Operating Limits at Rated Conditions:

MCPR Operating Limit

1.30 at 106% RBM

1.32 at 108% RBM

MCPR Operating Limits at Off-Rated Conditions:

At Reduced Flow

Figure 5.2

Total Core  
Recirculation Flow  
(% Rated)Reduced Flow  
MCPR  
Operating Limit

100

1.12

96

1.14

92

1.16

83

1.20

76

1.23

60

1.31

50

1.44

40

1.61

At Reduced Power

Power Level  
(% Rated)Reduced Power  
MCPR  
Operating Limit

100\*

1.30

80

1.31

65

1.34

40

1.37

\*104% power used in analysis as design bases.

### 7.2.3 LHGR Limits

LHGR Limits

Figures 3.3 and 3.4 of  
Reference 9.1

## 7.3 Surveillance Requirements

### 7.3.1 Scram Insertion Time Surveillance

Thermal limits established in Section 5.0 are based on minimum acceptable scram insertion performance as defined in the Technical Specifications. No additional surveillance for scram insertion is required for validation of thermal limits.

### 7.3.2 Stability Surveillance

Power/Flow Map

Figure 4.4

The Unit 2 Cycle 2 Technical Specifications require APRM/LPRM surveillance to the left of the 45% Constant Flow line and above the 80% Rod Block line. Based on core hydrodynamic stability analyses, operation at power/flow combinations above and to the left of the line connecting the 66% Power/45% Flow and 69% Power/47% Flow points but below the APRM Rod Block line needs to be added to the APRM/LPRM surveillance requirement (see Section 4.2.4).

8.0 METHODOLOGY REFERENCES

See XN-NF-80-19(P)(A), Volume 4, Revision 1 for complete bibliography.





11

12

## 9.0 ADDITIONAL REFERENCES

- 9.1 "Generic Mechanical Design for Exxon Nuclear Jet Pump BWR Reload Fuel," XN-NF-85-67(P)(A), Rev. 1, Advanced Nuclear Fuels Corporation\*, Richland, Washington, September 4, 1986.
- 9.2 "Exxon Nuclear Methodology for Boiling Water Reactors, THERMEX: Thermal Limits Methodology Summary Description," XN-NF-80-19(P)(A), Volume 3, Revision 2, Advanced Nuclear Fuels Corporation, Richland, Washington, January, 1987.
- 9.3 "Demonstration of 9x9 Assemblies for BWRs," EPRI NP-3468, Electric Power Research Institute, Palo Alto, California, May 1, 1984.
- 9.4 Letter, G. N. Ward (ANF) to G. C. Lainas (NRC), "Additional Information on Rod Bow," serial no. GNW:021:87, dated March 11, 1987.
- 9.5 "Exxon Nuclear Plant Transient Methodology for Boiling Water Reactors," XN-NF-79-71(P), Revision 2, Advanced Nuclear Fuels Corporation, Richland, Washington, November 16, 1981.
- 9.6 "Susquehanna Unit 2 Cycle 3 Plant Transient Analysis," ANF-87-125, Rev. 2, Advanced Nuclear Fuels Corporation, Richland, Washington, November 1987.
- 9.7 "XCOBRA-T: A Computer Code for BWR Transient Thermal-Hydraulic Core Analysis," XN-NF-84-105(P)(A), Volume 1 and Volume 1, Supplements 1 and 2, Advanced Nuclear Fuels Corporation, Richland, Washington, February 1987.
- 9.8 "Generic LOCA Break Spectrum Analysis BWR 3 & 4 with Modified Low Pressure Coolant Injection Logic Using the EXEM Evaluation Model," XN-NF-84-117(P), Advanced Nuclear Fuels Corporation, Richland, Washington, December 1984.
- 9.9 "Susquehanna LOCA-ECCS Analysis MAPLHGR Results for ENC 9x9 Fuel," XN-NF-86-65, Advanced Nuclear Fuels Corporation, Richland, Washington, May 1986.
- 9.10 "Principal Reload Fuel Design Parameters, Fuel Design, Susquehanna Unit 2 Reload XN-2," XN-NF-1058, Advanced Nuclear Fuels Corporation, Richland, Washington, March 1987.

---

\*Formerly Exxon Nuclear Company.




Figure 3.1 Susquehanna Unit 2 Cycle 3 Hydraulic Demand Curve  
Power vs. Flow




Figure 3.2 Susquehanna 2 Cycle 3 Design Basis Radial Power

```

* * * * *
*
* : 0.88 : 0.91 : 0.96 : 1.04 : 1.02 : 1.04 : 0.96 : 1.00 : 0.96 :
* :      :      :      :      :      :      :      :      :      :
* : 0.91 : 0.93 : 0.98 : 1.07 : 0.91 : 1.07 : 0.97 : 1.04 : 1.01 :
* :      :      :      :      :      :      :      :      :      :
* : 0.96 : 0.98 : 0.90 : 1.04 : 1.03 : 1.04 : 1.04 : 0.99 : 0.96 :
* :      :      :      :      :      :      :      :      :      :
* : 1.04 : 1.07 : 1.04 : 1.00 : 0.99 : 1.00 : 1.05 : 0.94 : 1.04 :
* :      :      :      :      :      :      :      :      :      :
* : 1.02 : 0.91 : 1.03 : 0.99 : 0.00 : 0.98 : 1.05 : 1.07 : 1.04 :
* :      :      :      :      :      :      :      :      :      :
* : 1.04 : 1.07 : 1.04 : 1.00 : 0.98 : 0.00 : 1.03 : 0.94 : 1.05 :
* :      :      :      :      :      :      :      :      :      :
* : 0.96 : 0.97 : 1.04 : 1.05 : 1.05 : 1.03 : 1.06 : 1.00 : 0.97 :
* :      :      :      :      :      :      :      :      :      :
* : 1.00 : 1.04 : 0.99 : 0.94 : 1.07 : 0.94 : 1.00 : 0.94 : 1.01 :
* :      :      :      :      :      :      :      :      :      :
* : 0.96 : 1.01 : 0.96 : 1.04 : 1.04 : 1.05 : 0.97 : 1.01 : 0.97 :
* :      :      :      :      :      :      :      :      :      :
    
```

Figure 3.3  
Design Basis Local Power Distribution  
Advanced Nuclear Fuels XN-2 9X9 Fuel

```

* * * * *
* :-----:
* : 0.91 : 0.92 : 0.95 : 1.01 : 1.01 : 1.01 : 0.96 : 0.98 : 0.95 :
* :-----:
* : 0.92 : 0.94 : 0.98 : 0.97 : 1.05 : 0.95 : 0.99 : 0.95 : 0.98 :
* :-----:
* : 0.95 : 0.98 : 0.93 : 1.06 : 1.05 : 1.06 : 1.05 : 0.97 : 0.96 :
* :-----:
* : 1.01 : 0.97 : 1.06 : 1.03 : 1.03 : 1.04 : 1.07 : 1.06 : 1.02 :
* :-----:
* : 1.01 : 1.05 : 1.05 : 1.03 : 0.00 : 1.01 : 1.07 : 1.06 : 1.01 :
* :-----:
* : 1.01 : 0.95 : 1.06 : 1.04 : 1.01 : 0.00 : 1.04 : 0.96 : 1.02 :
* :-----:
* : 0.96 : 0.99 : 1.05 : 1.07 : 1.07 : 1.04 : 1.06 : 1.00 : 0.96 :
* :-----:
* : 0.98 : 0.95 : 0.97 : 1.06 : 1.06 : 0.96 : 1.00 : 0.95 : 0.98 :
* :-----:
* : 0.95 : 0.98 : 0.96 : 1.02 : 1.01 : 1.02 : 0.96 : 0.98 : 0.96 :
* :-----:

```

Figure 3.4  
Design Basis Local Power Distribution  
Advanced Nuclear Fuels XN-1 9X9 Fuel

```

* * * * *
* -----
* : 1.03 : 1.00 : 1.00 : 1.00 : 1.00 : 1.00 : 1.01 : 1.03 :
* :      :      :      :      :      :      :      :      :
* -----
* : 1.00 : 0.98 : 1.00 : 1.02 : 1.02 : 1.03 : 1.00 : 1.01 :
* :      :      :      :      :      :      :      :      :
* -----
* : 1.00 : 1.00 : 1.01 : 1.01 : 1.01 : 0.90 : 1.03 : 1.00 :
* :      :      :      :      :      :      :      :      :
* -----
* : 1.00 : 1.02 : 1.01 : 0.89 : 0.00 : 1.01 : 1.02 : 1.00 :
* :      :      :      :      :      :      :      :      :
* -----
* : 1.00 : 1.02 : 1.01 : 0.00 : 0.89 : 1.01 : 0.99 : 1.00 :
* :      :      :      :      :      :      :      :      :
* -----
* : 1.00 : 1.03 : 0.90 : 1.01 : 1.01 : 0.98 : 1.00 : 1.00 :
* :      :      :      :      :      :      :      :      :
* -----
* : 1.01 : 1.00 : 1.03 : 1.02 : 0.99 : 1.00 : 0.98 : 1.00 :
* :      :      :      :      :      :      :      :      :
* -----
* : 1.03 : 1.01 : 1.00 : 1.00 : 1.00 : 1.00 : 1.00 : 1.03 :
* :      :      :      :      :      :      :      :      :
* -----

```

Figure 3.5  
Design Basis Local Power Distribution  
General Electric (Central) 8X8R Fuel





TABLE 4.1 NEUTRONIC DESIGN VALUES

|   |                  |
|---|------------------|
| <u>Fuel Pellet</u>                          | Reference 9.10   |
| <u>Fuel Rod</u>                             | Reference 9.10   |
| <u>Fuel Assembly</u>                        | Reference 9.10   |
| <u>Core Data</u>                            |                  |
| Number of fuel assemblies                   | 764              |
| Rated thermal power, MW                     | 3293             |
| Rated core flow, Mlbm/hr                    | 100              |
| Core inlet subcooling, Btu/lbm              | 24.0             |
| Moderator temperature, F                    | 548.8            |
| Channel thickness, inch                     | .080             |
| Fuel assembly pitch, inch                   | 6.00             |
| Wide water gap thickness, inch              | 0.562            |
| Narrow water gap thickness, inch            | 0.562            |
| <u>Control Rod Data</u>                     |                  |
| Absorber material                           | B <sub>4</sub> C |
| Total blade span, inch                      | 9.75             |
| Total blade support span, inch              | 1.58             |
| Blade thickness, inch                       | 0.260            |
| Blade face-to-face internal dimension, inch | 0.200            |
| Absorber rods per blade                     | 76               |
| Absorber rod outside diameter, inch         | 0.188            |
| Absorber rod inside diameter, inch          | 0.138            |
| Absorber density, % of theoretical          | 70.0             |



\*\*\*\*\*

|   |   |    |   |    |   |    |   |    |   |    |   |    |   |    |   |    |   |    |   |
|---|---|----|---|----|---|----|---|----|---|----|---|----|---|----|---|----|---|----|---|
| * | : | LL | : | L  | : | ML | : | M  | : | M  | : | M  | : | ML | : | ML | : | L  | : |
| * | : | L  | : | ML | : | M* | : | MH | : | M* | : | MH | : | M* | : | M  | : | ML | : |
| * | : | ML | : | M* | : | M  | : | H  | : | H  | : | H  | : | MH | : | M  | : | ML | : |
| * | : | M  | : | MH | : | H  | : | H  | : | H  | : | H  | : | H  | : | M* | : | M  | : |
| * | : | M  | : | M* | : | H  | : | H  | : | W  | : | MH | : | H  | : | MH | : | M  | : |
| * | : | M  | : | MH | : | H  | : | H  | : | MH | : | W  | : | MH | : | M* | : | M  | : |
| * | : | ML | : | M* | : | MH | : | H  | : | H  | : | MH | : | MH | : | M  | : | ML | : |
| * | : | ML | : | M  | : | M  | : | M* | : | MH | : | M* | : | M  | : | ML | : | ML | : |
| * | : | L  | : | ML | : | ML | : | M  | : | M  | : | M  | : | ML | : | ML | : | L  | : |

- LL RODS ( 1) --- 1.45 W/O U235
- L RODS ( 5) --- 1.95 W/O U235
- ML RODS (16) --- 2.55 W/O U235
- M RODS (19) --- 3.27 W/O U235
- MH RODS (13) --- 4.23 W/O U235
- H RODS (15) --- 4.66 W/O U235
- M\* RODS (10) --- 3.27 W/O U235 + 5.00 W/O GD203
- W RODS ( 2) --- INERT WATER ROD

Figure 4.2 Susquehanna Unit 2 Cycle 3 Enrichment Distribution for the ANF92-344L-10G5 XN-2 Fuel Lattice

|    |    |    |    |    |    |    |    |    |    |    |    |    |    |    |
|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|
| A2 | C1 | A2 | C1 | A2 | C1 | A2 | C1 | D0 | C1 | A2 | C1 | E0 | C1 | A2 |
| C1 | D0 | C1 | D0 | C1 | A2 | C1 | D0 | C1 | A2 | C1 | E0 | C1 | C1 | A2 |
| A2 | C1 | D0 | A2 | D0 | C1 | D0 | A2 | D0 | C1 | D0 | C1 | E0 | C1 | A2 |
| C1 | D0 | A2 | D0 | C1 | D0 | C1 | D0 | A2 | D0 | C1 | E0 | C1 | C1 | A2 |
| A2 | C1 | D0 | C1 | A2 | C1 | D0 | C1 | D0 | A2 | D0 | C1 | E0 | C1 | A2 |
| C1 | A2 | C1 | D0 | C1 | C1 | A2 | D0 | A2 | E0 | C1 | E0 | C1 | C1 | A2 |
| A2 | C1 | D0 | C1 | D0 | A2 | C1 | C1 | D0 | C1 | E0 | C1 | E0 | C1 | A2 |
| C1 | D0 | A2 | D0 | C1 | D0 | C1 | E0 | C1 | E0 | C1 | D0 | C1 | A2 |    |
| D0 | C1 | D0 | A2 | D0 | A2 | D0 | C1 | E0 | C1 | E0 | A2 | B2 |    |    |
| C1 | A2 | C1 | D0 | A2 | E0 | C1 | E0 | C1 | C1 | C1 | A2 | A2 |    |    |
| A2 | C1 | D0 | C1 | D0 | C1 | E0 | C1 | E0 | C1 | A2 |    |    |    |    |
| C1 | E0 | C1 | E0 | C1 | E0 | C1 | D0 | A2 | A2 |    |    |    |    |    |
| E0 | C1 | E0 | C1 | E0 | C1 | E0 | C1 | B2 | A2 |    |    |    |    |    |
| C1 | C1 | C1 | C1 | C1 | C1 | C1 | A2 |    |    |    |    |    |    |    |
| A2 | A2 | A2 | A2 | A2 | A2 | A2 |    |    |    |    |    |    |    |    |

XY = Fuel Type X  
Burned Y Cycles

| <u>Fuel Type</u> | <u>No. of Bundles</u> | <u>Description</u>             |
|------------------|-----------------------|--------------------------------|
| A                | 196                   | GE 8X8 Type III 2.19 w/o U-235 |
| B                | 8                     | GE 8X8 Type II 1.76 w/o U-235  |
| C                | 324                   | XN-1 ENC92-331B-7G4            |
| D                | 140                   | XN-2 ANF92-333B-9G4            |
| E                | 96                    | XN-2 ANF92-333B-10G5           |

Figure 4.3 Susquehanna Unit 2 Cycle 3 Reference Core Loading




Figure 4.4 Susquehanna Unit 2 Cycle 3 - Core Power vs. Core Flow

|    | 2  | 6  | 10 | 14 | 18 | 22 | 26 | 30  | 34 | 38 | 42 | 46 | 50 | 54 | 58 |    |
|----|----|----|----|----|----|----|----|-----|----|----|----|----|----|----|----|----|
| 59 |    |    |    |    | -- | -- | -- | --  | -- | -- | -- |    |    |    |    | 59 |
| 55 |    |    |    | -- | -- | 12 | -- | 00  | -- | 12 | -- | -- |    |    |    | 55 |
| 51 |    |    | -- | -- | 20 | -- | 26 | --  | 26 | -- | 20 | -- | -- |    |    | 51 |
| 47 |    | -- | -- | 00 | -- | 12 | -- | 08  | -- | 12 | -- | 00 | -- | -- |    | 47 |
| 43 | -- | -- | 20 | -- | 20 | -- | -- | --  | -- | -- | 20 | -- | 20 | -- | -- | 43 |
| 39 | -- | 12 | -- | 08 | -- | 08 | -- | 00  | -- | 08 | -- | 08 | -- | 12 | -- | 39 |
| 35 | -- | -- | 26 | -- | -- | -- | 44 | --  | 44 | -- | -- | -- | 26 | -- | -- | 35 |
| 31 | -- | 00 | -- | 04 | -- | 00 | -- | 00  | -- | 00 | -- | 04 | -- | 00 | -- | 31 |
| 27 | -- | -- | 26 | -- | -- | -- | 44 | --  | 44 | -- | -- | -- | 26 | -- | -- | 27 |
| 23 | -- | 12 | -- | 08 | -- | 08 | -- | 00* | -- | 08 | -- | 08 | -- | 12 | -- | 23 |
| 19 | -- | -- | 20 | -- | 20 | -- | -- | --  | -- | -- | 20 | -- | 20 | -- | -- | 19 |
| 15 |    | -- | -- | 00 | -- | 12 | -- | 08  | -- | 12 | -- | 00 | -- | -- |    | 15 |
| 11 |    |    | -- | -- | 20 | -- | 26 | --  | 26 | -- | 20 | -- | -- |    |    | 11 |
| 7  |    |    |    | -- | -- | 12 | -- | 00  | -- | 12 | -- | -- |    |    |    | 7  |
| 3  |    |    |    |    | -- | -- | -- | --  | -- | -- | -- |    |    |    |    | 3  |
|    | 2  | 6  | 10 | 14 | 18 | 22 | 26 | 30  | 34 | 38 | 42 | 46 | 50 | 54 | 58 |    |

Cycle Exposure                      0.0 MWD/MTU  
Control Rod Density                23.3 %

Control Rod Being Withdrawn = 00\*  
Rod Fully Inserted = 00  
Rod Fully Withdrawn = --

Figure 5.1      Susquehanna Unit 2 Cycle 3 Control Rod Withdrawal Error  
Analysis Limiting Initial Control Rod Pattern




Figure 5.2 Susquehanna Unit 2 Cycle 3 Flow MCPR Operating Limit

1  
2  
3  
4  
5  
6



## APPENDIX A

SINGLE LOOP OPERATION

This Appendix provides limits and justification of those limits for Single Loop Operation (SLO).

A.1 ANTICIPATED OPERATIONAL OCCURRENCES

Reference A.1

The NSSS supplier has provided analyses which demonstrate the safety of plant operation with a single recirculation loop out of service for an extended period of time. These analyses restrict the overall operation of the plant to lower bundle power levels and lower nodal power levels than are allowed when both recirculation systems are in operation. The physical interdependence between core power and recirculation flow rate inherently limits the core to less than rated power. ANF fuel was designed to be compatible with the co-resident fuel in thermal hydraulic, nuclear, and mechanical design performance. The ANF methodology has given results which are consistent with those of previous analyses for normal two-loop operation. Many analyses performed by the NSSS supplier for single loop operation are also applicable to single loop operation with fuel and analyses provided by ANF.

For single loop operation, the NSSS vendor found that an increase of 0.01 in the MCPR safety limit was needed to account for the increased flow measurement uncertainties and increased tip uncertainties associated with single pump operation. ANF has evaluated the effects of the increased flow measurement uncertainties on the safety limit MCPR and found that the NSSS vendor determined increase in the allowed safety limit MCPR is also applicable to ANF fuel during single loop operation. Thus, increasing the safety limit MCPR by 0.01 for single loop operation (1.07) with ANF fuel is sufficiently conservative to also bound the increased flow measurement uncertainties for single loop operation.

The limiting MCPR operating limit for single loop operation is conservatively set using the limiting pump seizure accident delta CPR plus the single loop operation MCPR safety limit. This limit together with the  $MCPR_f$  curve for two loop operation plus .01 and the  $MCPR_p$  curve for two loop operation plus .01 conservatively bound all transients.

The Technical Specifications require APRM/LPRM surveillance to the left of the 45% Constant Flow line and above the 80% Rod Block line. Based on core hydrodynamic stability analyses for Cycle 3, operation at power/flow combinations above and to the left of the line connecting the 66% Power/45% Flow and 69% Power/47% Flow points needs to be added to the APRM/LPRM surveillance requirements. Figure 4.4 shows the core power versus core flow established for Cycle 3.

A.2 POSTULATED ACCIDENTS

Reference A.2

ANF performed LOCA analyses for single loop conditions and has determined that the MAPLHGR limit curve (Section 7.2) for two-loop operation is also applicable to single loop operation for ANF 9x9 fuels.

REFERENCES

- A.1 "Susquehanna Unit 2 Cycle 2 Single Loop Operation Analysis," XN-NF-86-146, Advanced Nuclear Fuels Corporation, Richland, WA 99352, November 1986.
- A.2 "Susquehanna LOCA Analysis for Single Loop Operation," XN-NF-86-125, Advanced Nuclear Fuels Corporation, Richland, WA 99352, November 1986.

## APPENDIX B

SEISMIC-LOCA EVALUATION

The structural response of Advanced Nuclear Fuels Corporation's (ANF's) 9x9 fuel is similar to the structural response of the GE 8x8R fuel it replaces in the Susquehanna Unit 2 core. Therefore, the seismic-LOCA structural response evaluation performed in support of the initial core remains applicable and continues to provide assurance that control blade insertion will not be inhibited following the occurrence of the design basis seismic-LOCA event.

The physical and structural properties of the 9x9 and the 8x8 fuel types which are important to the dynamic response of the fuel are summarized in Table B.1.

The close agreement between the important parameters for the ANF 9x9 and GE 8x8R fuel types indicates that the structural response would be very similar for both fuel types.

Similarity in the natural frequencies of the two fuel types mentioned above is further assured by the stiffness of the fuel assembly channel box. Both fuel types use the same fuel assembly channel box, and the channel box dominates the overall dynamic response of the incore fuel. ANF calculations show that approximately 97% of the stiffness of a fuel assembly is attributable to the stiffness of the channel box. For this reason, the dynamic structural response of the reload core is essentially that of the initial core, and the original seismic-LOCA analysis remains applicable. Deformation of the channel to the point that control blade insertion is inhibited is not predicted to occur.

TABLE B.1 COMPARISON OF PHYSICAL AND STRUCTURAL CHARACTERISTICS  
FOR 8X8 AND 9X9 FUEL ASSEMBLIES

| <u>Property</u>             | <u>Fuel Types</u> |                |
|-----------------------------|-------------------|----------------|
|                             | <u>ANF 9x9</u>    | <u>GE 8x8R</u> |
| Assembly Weight, lbs        | 580               | 600            |
| Number of Spacers           | 7                 | 7              |
| Overall Assembly Length, in | 171.29            | 171.40         |
| Assembly Frequencies, cps   |                   |                |
| Mode                        | 1                 | *              |
|                             | 2                 |                |
|                             | 3                 |                |
|                             | 4                 |                |
|                             | 5                 |                |
|                             | 6                 |                |
|                             | 7                 |                |
|                             | 1.9               |                |
|                             | 3.7               |                |
|                             | 6.5               |                |
|                             | 10.4              |                |
|                             | 15.5              |                |
|                             | 21.9              |                |
|                             | 29.1              |                |

---

\*GE proprietary

ANF-87-126  
Revision 1  
Issue Date: 11/25/87

SUSQUEHANNA UNIT 2 CYCLE 3 RELOAD ANALYSIS

Design and Safety Analyses

Distribution:

D. A. Adkisson  
D. J. Braun  
R. E. Collingham  
L. J. Federico  
S. F. Gaines  
R. G. Grummer  
K. D. Hartley  
M. J. Hibbard  
S. E. Jensen  
T. H. Keheley  
J. N. Morgan  
L. A. Nielsen  
D. F. Richey  
G. L. Ritter  
C. J. Volmer  
J. A. White  
H. E. Williamson

H. G. Shaw/PP&L (20)  
Document Control (5)