

CATEGORY 2

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9910050303 DOC.DATE: 99/09/30 NOTARIZED: NO DOCKET #
 FACIL: 50-387 Susquehanna Steam Electric Station, Unit 1, Pennsylva 05000387
 50-388 Susquehanna Steam Electric Station, Unit 2, Pennsylva 05000388
 AUTH.NAME AUTHOR AFFILIATION
 COWGILL, C.J. Region 1 (Post 820201)
 RECIP.NAME RECIPIENT AFFILIATION
 BYRAM, R.G. Pennsylvania Power & Light Co.

SUBJECT: Forwards insp repts 50-387/99-07 & 50-388/99-07 on
 990720-0828. NRC determined that two severity level IV
 violations of NRC requirements occurred. Violations being
 treated as non-cited violations.

DISTRIBUTION CODE: IE01F COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 3+13
 TITLE: General (50 Dkt)-Insp Rept/Notice of Violation Response

NOTES:

05000387

	RECIPIENT ID CODE/NAME	COPIES LTR	ENCL	RECIPIENT ID CODE/NAME	COPIES LTR	ENCL
	LPD1-1	1	1	NERSES, V	1	1
INTERNAL:	ACRS	2	2	AEOD/TTC	1	1
	DEDRO	1	1	FILE CENTER	1	1
	NRR/DIPM/IIPB	1	1	NRR/DIPM/OLHP	1	1
	NRR/DRIP/REXB	1	1	NUDOCS-ABSTRACT	1	1
	OE	1	1	OGC/RP	1	1
	RGN1 FILE 01	1	1			
EXTERNAL:	LMITCO MARSHALL	1	1	NOAC	1	1
	NRC PDR	1	1	NUDOCS FULLTEXT	1	1

NOTES:

1 1

LOADED FROM
 ELECTRONIC FILE

NOTE TO ALL "RIDS" RECIPIENTS:
 PLEASE HELP US TO REDUCE WASTE. TO HAVE YOUR NAME OR ORGANIZATION REMOVED FROM DISTRIBUTION LIST
 OR REDUCE THE NUMBER OF COPIES RECEIVED BY YOU OR YOUR ORGANIZATION, CONTACT THE DOCUMENT CONTROL
 DESK (DCD) ON EXTENSION 415-2083

TOTAL NUMBER OF COPIES REQUIRED: LTR 19 ENCL 19

September 30, 1999

Mr. Robert G. Byram
Senior Vice President - Nuclear
Pennsylvania Power & Light Company
2 North Ninth Street
Allentown, Pennsylvania 18101

SUBJECT: NRC INTEGRATED INSPECTION REPORT 50-387/99-07 and 50-388/99-07

Dear Mr. Byram:

On August 28, 1999, the NRC completed an inspection at your Susquehanna Steam Electric Station (SSES) Unit 1& 2 reactor facilities. The enclosed report presents the results of these inspections. The inspectors discussed the findings of these inspections with Mr. R. Saunders, Vice President Nuclear Operations, and others of your staff, at an exit meeting at the completion of the inspection period.

Overall, your staff safely operated the facility during this period. However, the NRC has determined that two Severity Level IV violations of NRC requirements occurred. These violations are being treated as Non-Cited Violations (NCVs), consistent with Appendix C of the Enforcement Policy. These NCVs are described in the subject inspection report and involve your procedure for performing a safety function determination for out of service primary containment isolation instrumentation and a shipment of dewatered condensate demineralizer resin waste. If you contest the violations or severity level of these NCVs, you should provide a response within 30 days of the date of this inspection report, with the basis for your denial, to the Nuclear Regulatory Commission, ATTN: Document Control Desk, Washington DC 20555-0001, with copies to the Regional Administrator, Region I, the Director, Office of Enforcement, United States Nuclear Regulatory Commission, Washington, DC 20555-0001, and the NRC resident inspector at the Susquehanna Steam Electric Station.

In accordance with 10 CFR 2.790 of the NRC's "Rules of Practice," a copy of this letter, its enclosure(s), and your response will be placed in the NRC Public Document Room.

Sincerely,

Original Signed By:

Curtis J. Cowgill, Chief
Projects Branch 4
Division of Reactor Projects

053632

Docket Nos: 50-387;50-388
License Nos: NPF-14, NPF-22

Enclosure: Inspection Report 50-387/99-07, 50-388/99-07

9910050303 990930
PDR ADOCK 05000387
G PDR

1E:01

MR. Robert G. Byram

2

cc w/encl:

R. F. Saunders, Vice President - Site Operations
B. Shriver, General Manger Susquehanna Steam Electric Station
G. T. Jones, Vice President - Engineering and Support
T. Harpster, Supervisor, Nuclear Licensing
G. D. Miller, General Manager - Nuclear Assurance
R. R. Wehry, Nuclear Licensing
P. Nderostek, Nuclear Services Manager, General Electric
W. H. Lowthert, Manager - Nuclear Plant Services
A. Male, Manager, Nuclear Assessment Services
H. D. Woodeshick, Special Assistant to the President
R. W. Osburne, Vice President, Supply & Engineering
Commonwealth of Pennsylvania

MR. Robert G. Byram

3

Distribution w/encl:
 Region I Docket Room (with concurrences)
 Nuclear Safety Information Center (NSIC)
 NRC Resident Inspector
 PUBLIC
 H. Miller, RA/J. Wiggins, DRA
 C. Cowgill, DRP
 D. Florek, DRP
 D. Cullison, DRP
 C. O'Daniell, DRP

Distribution w/encl: (Via E-Mail)
 M. Tschiltz, OEDO
 E. Adensam, PDI, NRR
 S. Bajwa, NRR
 V. Nerses, NRR
 R. Correia, NRR
 DOCDESK
 Inspection Program Branch, NRR (IPAS)

DOCUMENT NAME: G:\BRANCH4\SUS9907.WPD

To receive a copy of this document, indicate in the box: "C" = Copy without attachment/enclosure "E" = Copy with attachment/enclosure "N" = No copy

OFFICE	RI/DRP	RI/DRP					
NAME	Dflorek	CCowgill					
DATE	09/1/99	09/1/99	09/ /99	09/ /99	09/ /99	09/ /99	

OFFICIAL RECORD COPY

