

MAR 2 1971

Docket No. 50-249

Distribution:
 AEC PDR (50-249)
 Docket File (50-249)
 DR Reading
 DRL Reading
 BWR-2 File (50-249)
 R. S. Boyd
 R. L. Tedesco
 M. Wetterhahn
 H. Steele (2)
 S. H. Hanauer, DR

Mr. Leroy Stratton
 Bureau of Radiological Health
 Illinois Department of Public Health
 Springfield, Illinois 62706

Dear Mr. Stratton:

Pursuant to a Commission Order, the Atomic Energy Commission has issued Amendment No. 1 to Commonwealth Edison Company's Facility Operating License No. DPR-25. The license as previously issued authorized initial fuel loading and low-power startup testing of the Dresden Nuclear Power Station Unit 3 at power levels not in excess of one megawatt (thermal), and without the reactor vessel head in place.

Amendment No. 1 authorizes the licensee to operate the Dresden Unit 3 reactor at steady state power levels not in excess of 2527 megawatts (thermal), in accordance with the provisions of the license and the Technical Specifications, as modified, except that the licensee shall not operate the reactor at power levels in excess of five (5) megawatts (thermal) until satisfactory completion of modifications and final testing of the station output transformer, the auto-depressurization interlock, and the feedwater system, described in Commonwealth Edison Company's telegrams dated February 26, 1971, have been verified in writing by the Commission.

I am enclosing one copy each of the Commission's Order, the facility license amendment, Change No. 1 to the Technical Specifications, and a related notice which has been forwarded to the Office of the Federal Register for filing and publication.

Sincerely yours,

Original Signed by
 Frank Schroeder

for
 Peter A. Morris, Director
 Division of Reactor Licensing

Enclosures:

1. Commission Order
2. Amend. No. 1 to Lic. DPR-25
3. Change No. 1 to Tech. Spec.
4. Fed. Reg. Notice

state

OFFICE ▶	DRL: BWR-2 <i>HSB</i>	DRL: BWR-2 <i>R</i>	DRL: BWR <i>RSB</i>	DRL: DIR <i>AM</i>		
SURNAME ▶	HSteele:pcb	RLTedesco	RSBoyd	PAMorris		
DATE ▶	3/1/71	3/2/71	3/2/71	3/2/71		