

Docket No. 50-249

MAR 2 1971

Distribution:
 AEC PDR
 Docket File
 DRI Reading
 BWR-2 File
 R. S. Boyd
 R. L. Tedesco
 M. Wetterhahn
 H. Steele (2)
 S. Hanauer, DR

Mr. Sidney C. Carr
 Chairman, Board of Supervisors
 of Grundy County
 Grundy County Court House
 Morris, Illinois 60450

Dear Mr. Carr:

Pursuant to a Commission Order, the Atomic Energy Commission has issued Amendment No. 1 to Commonwealth Edison Company's Facility Operating License No. DPR-25. The license as previously issued authorized initial fuel loading and low-power startup testing of the Dresden Nuclear Power Station Unit 3 at power levels not in excess of one megawatt (thermal), and without the reactor vessel head in place.

Amendment No. 1 authorizes the licensee to operate the Dresden Unit 3 reactor at steady state power levels not in excess of 2527 megawatts (thermal), in accordance with the provisions of the license and the Technical Specifications, as modified, except that the licensee shall not operate the reactor at power levels in excess of five (5) megawatts (thermal) until satisfactory completion of modifications and final testing of the station output transformer, the auto-depressurization interlock, and the feedwater system, described in Commonwealth Edison Company's telegrams dated February 26, 1971, have been verified in writing by the Commission.

I am enclosing one copy each of the Commission's Order, the facility license amendment, Change No. 1 to the Technical Specifications, and a related notice which has been forwarded to the Office of the Federal Register for filing and publication.

Sincerely yours,

Original Signed by
 R. E. Ireland

R. S. Boyd
 Roger S. Boyd, Assistant Director
 for Boiling Water Reactors
 Division of Reactor Licensing

Enclosures:

1. Commission Order
2. Amend. No. 1 to Lic. DPR-25
3. Change No. 1 to Tech Specs
4. Fed. Reg. Notice

OFFICE ▶	DRL: BWR-2	DRL: BWR-2	DRL: BWR			
SURNAME ▶	H Steele: pcb	RL Tedesco	R Boyd			
DATE ▶	3/1/71	3/2/71	3/2/71			

State