

REGULATOR INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR:8506130304 DOC.DATE: 85/06/10 NOTARIZED: NO DOCKET #  
 FACIL:50-387 Susquehanna Steam Electric Station, Unit 1, Pennsylv 05000387  
 50-388 Susquehanna Steam Electric Station, Unit 2, Pennsylv 05000388  
 AUTH.NAME AUTHOR AFFILIATION  
 CURTIS,N.W. Pennsylvania Power & Light Co.  
 RECIP.NAME: RECIPIENT AFFILIATION  
 BUTLER,W.R. Licensing Branch 2

SUBJECT: Advises of completion of design mods to emergency svc water sys discribed in util 830516 ltr.Mods eliminate single failure in subj sys,thereby eliminating need for uncooled RHR pump.

DISTRIBUTION CODE: A001D COPIES RECEIVED:LTR 1 ENCL 0 SIZE: 1  
 TITLE: OR Submittal: General Distribution

NOTES:1cy NMSS/FCAF/PM. LPDR 2cys Transcripts. 05000387  
 OL:07/17/82  
 1cy NMSS/FCAF/PM. LPDR 2cys Transcripts. 05000388  
 OL:03/23/84

	RECIPIENT ID CODE/NAME		COPIES LTTR ENCL		RECIPIENT ID CODE/NAME		COPIES LTTR ENCL
	NRR LB2 BC	01	7	7			
INTERNAL:	ACRS	09	6	6	ADM/LFMB		1 0
	ELD/HDS4		1	1	NRR/DE/MTEB		1 1
	NRR/DL DIR		1	1	NRR/DL/ORAB		1 0
	NRR/DL/TSRG		1	1	NRR/DSI/METB		1 1
	NRR/DSI/RAB		1	1	REG FILE	04	1 1
	RGN1		1	1			
EXTERNAL:	24X		1	1	EG&G BRUSKE,S		1 1
	LPDR	03	2	2	NRC PDR	02	1 1
	NSIC	05	1	1			
NOTES:			3	3			

TOTAL NUMBER OF COPIES REQUIRED: LTTR 32 ENCL 0

THE UNIVERSITY OF CHICAGO LIBRARY

1968

1969

1970

1971

1972

1973

1974



**Pennsylvania Power & Light Company**

Two North Ninth Street • Allentown, PA 18101 • 215 / 770-5151

Norman W. Curtis  
Vice President-Engineering & Construction-Nuclear  
215/770-7501

**JUN 10 1985**

Director of Nuclear Reactor Regulation  
Attention: Mr. W. R. Butler, Chief  
Licensing Branch No. 2  
Division of Licensing  
U.S. Nuclear Regulatory Commission  
Washington, DC 20555

SUSQUEHANNA STEAM ELECTRIC STATION  
LICENSE CONDITIONS 2.C.(32) OF OPERATING  
LICENSE NO. NPF-14 AND 2.C.(13) OF OPERATING  
LICENSE NO. NPF-22  
ER 100450 FILE 841-1  
PLA-2484

Docket Nos. 50-387  
50-388

Dear Mr. Butler:

In accordance with License Conditions 2.C.(32) of Operating License No. NPF-14 and 2.C.(13) of Operating License No. NPF-22, Pennsylvania Power & Light Company has completed design modifications to the Emergency Service Water (ESW) System, approved by the staff, to eliminate single failure in the ESW System which leads to the need for an uncooled residual heat removal (RHR) pump. These design modifications were described in a letter dated May 16, 1983.

This completes PP&L's action on these license conditions.

Very truly yours,

N. W. Curtis  
Vice President-Engineering & Construction-Nuclear

cc: M. J. Campagnone USNRC  
R. H. Jacobs USNRC

*A001  
1/10*

8506130304 850610  
PDR ADDCK 05000387  
P PDR

Faint, illegible text located in the lower-left quadrant of the page.

A small, faint mark or text fragment located in the lower-right quadrant.