

# ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

## REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8803210467      DOC. DATE: 88/03/15      NOTARIZED: NO      DOCKET #  
 FACIL: 50-387 Susquehanna Steam Electric Station, Unit 1, Pennsylv      05000387  
       50-388 Susquehanna Steam Electric Station, Unit 2, Pennsylv      05000388  
 AUTH. NAME                      AUTHOR AFFILIATION  
 KEISER, H.W.                    Pennsylvania Power & Light Co.  
 RECIP. NAME                    RECIPIENT AFFILIATION

SUBJECT: "RMS Annual Statistical Summary Rept (20.47)." W/880315 ltr. R

DISTRIBUTION CODE: IE56D      COPIES RECEIVED: LTR 1 ENCL 1      SIZE: 2 I  
 TITLE: 20.407 Annual Personnel Monitoring Rpt/Annual Rad Exposure Rpt by Fun D

NOTES: 1cy NMSS/FCAF/PM.      LPDR 2cys Transcripts. 05000387  
       1cy NMSS/FCAF/PM.      LPDR 2cys Transcripts. 05000388 S

	RECIPIENT ID CODE/NAME	COPIES	LTR	ENCL	RECIPIENT ID CODE/NAME	COPIES	LTR	ENCL	/
	PD1-2 LA	1		0	PD1-2 PD	5		5	A
	THADANI, M	1		0					D
INTERNAL:	ACRS                      11	10		10	AEOD/DOA	1		1	D
	AEOD/DSP/TPAB	1		1	NMSS/IMSB      6H3	1		1	D
	NRR/DOEA/EAB11E	1		1	NRR/DREP/RPB10A	2		2	S
	NRR/PMAS/ILRB12	1		1	<del>REG-FILE</del> 02	1		1	
	RES BROOKS, B	2		2	RGNI              01	1		1	
EXTERNAL:	LPDR	2		2	NRC PDR	1		1	
	NSIC	1		1					
NOTES:		3		3					

R  
I  
D  
S  
/  
A  
D  
D  
S

TOTAL NUMBER OF COPIES REQUIRED: LTR 35 ENCL 33

## PERSONNEL WHOLE BODY EXPOSURES FOR THE CALENDAR YEAR 1987

ESTIMATED WHOLE BODY EXPOSURE RANGE (REM)	# OF INDIVIDUALS IN EACH RANGE	TOTAL DOSE RECEIVED (REMS)
< 0.010	1501	0.000
0.010 -- 0.100	1161	40.449
0.100 -- 0.250	505	85.400
0.250 -- 0.500	451	163.115
0.500 -- 0.750	243	148.846
0.750 -- 1.000	127	110.859
1.000 -- 2.000	61	72.671
2.000 -- 3.000	0	0.000
3.000 -- 4.000	0	0.000
4.000 -- 5.000	0	0.000
5.000 -- 6.000	0	0.000
6.000 -- 7.000	0	0.000
7.000 -- 8.000	0	0.000
8.000 -- 9.000	0	0.000
9.000 -- 10.000	0	0.000
10.000 -- 11.000	0	0.000
11.000 -- 12.000	0	0.000
> 12.000	0	0.000
TOTALS:	4049	621.340

NOTE: INDIVIDUAL VALUES EXACTLY EQUAL TO THE VALUES SEPARATING  
EXPOSURE RANGES ARE REPORTED IN THE HIGHER RANGE.

IE56  
1/1

R  
8803210467  
PDR ADDOCK 05000387  
880315  
DCD



Pennsylvania Power & Light Company

Two North Ninth Street • Allentown, PA 18101 • 215/770-5151

MAR 15 1988

Harold W. Keiser  
Vice President-Nuclear Operations  
215/770-7502

Ms. Barbara G. Brooks  
Occupational Radiation Protection Branch  
Mail Stop 007NL  
Office of Nuclear Regulatory Research  
U.S. Nuclear Regulatory Commission  
Washington, D.C. 20555

SUSQUEHANNA STEAM ELECTRIC STATION  
ANNUAL PERSONNEL MONITORING REPORT  
PLA-2999 FILE R41-2A

Docket Nos. 50-387/NPF-14  
and 50-388/NPF-22

Dear Ms. Brooks:

In accordance with 10CFR20.407, the attached annual personnel monitoring report is provided for Susquehanna SES Units 1 and 2 covering the calendar year 1987. This information is provided for the total number of individuals for whom personnel monitoring was provided during the calendar year. If you have any questions, please call Mr. R. M. Harris at (215) 770-7918.

Very truly yours,

H. W. Keiser  
Vice President-Nuclear Operations

Attachment

cc: NRC Document Control Desk (original)  
NRC Region I  
Mr. F. I. Young - NRS Resident Inspector  
Mr. M. C. Thadani - NRC Project Manager

IES6  
1/1