

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8807250355 DOC. DATE: 88/06/30 ^{7/14} NOTARIZED: NO DOCKET #
 FACIL: 50-387 Susquehanna Steam Electric Station, Unit 1, Pennsylvania 05000387
 50-388 Susquehanna Steam Electric Station, Unit 2, Pennsylvania 05000388
 AUTH. NAME AUTHOR AFFILIATION
 SAXTON, C.H. Pennsylvania Power & Light Co. *ELI*
 RECIP. NAME RECIPIENT AFFILIATION

SUBJECT: "Drinking Water Rept," for June 1988.W/880714 ltr.

DISTRIBUTION CODE: C001D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 2
 TITLE: Licensing Submittal: Environmental Rept Amdt & Related Correspondence

NOTES: LPDR 2 cys Transcripts. 05000387
 LPDR 2 cys Transcripts. 05000388

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PD1-2 LA THADANI, M	1 1 1 1	PD1-2 PD	1 1
INTERNAL:	ACRS	6 6	AEOD/DOA	1 1
	AEOD/DSP/TPAB	1 1	ARM/DAF/LFMB	1 0
	NRR/DEST/ADE 8H	1 1	NRR/DEST/SGB 8D	1 1
	NRR/DREP/RPB 10	4 4	NIDOCs-ABSTRACT	1 1
	OGC 15-B-18	1 0	<u>REG FILE</u> 01	1 1
EXTERNAL:	LPDR	2 2	NRC PDR	1 1
	NSIC	1 1		
NOTES:		2 2		

TOTAL NUMBER OF COPIES REQUIRED: LTTR 27 ENCL 25

R I D S / A D S / R I D S / A D S

PP&E MUSQUEHANNA S.E.S. DRINKING WATER REPORT

PWS PERMIT NUMBER 4085504 MONTH: June, 1988

PREPARED BY: Deane B. Davis

DATE: 7-11-88

APPROVED BY: [Signature]

DATE: 7-11-88

DATE	DAILY FLOWS in gpd	FILTRATION RATES		TURBIDITIES IN NTU			
		DAILY AVERAGE gpm/ft ²	DAILY MAXIMUM gpm/ft ²	RAW WATER		FILTERED WATER	
				DAILY AVERAGE	DAILY MAXIMUM	DAILY AVERAGE	DAILY MAXIMUM
1	165400	0.73	0.76	7.3	25.0	0.17	0.22
2	185100	0.82	1.59	9.0	32.0	0.18	0.46
3	211900	0.94	1.50	8.3	20.0	0.17	0.30
4	182300	0.81	1.40	8.7	12.0	0.16	0.30
5	164300	0.73	0.80	7.5	9.0	0.17	0.25
6	165200	0.73	1.37	8.3	12.0	0.18	0.28
7	164100	0.73	1.43	6.3	11.0	0.19	0.32
8	164400	0.73	1.34	6.7	10.0	0.18	0.37
9	164900	0.73	1.40	7.3	20.0	0.17	0.35
10	186700	0.83	1.40	7.3	9.0	0.16	0.20
11	198500	0.88	2.32	6.8	25.0	0.15	0.61
12	216900	0.96	0.96	6.5	7.0	0.16	0.50
13	197300	0.87	1.53	7.0	10.0	0.19	0.25
14	226500	1.00	1.59	6.0	15.0	0.20	0.35
15	221200	0.98	1.59	5.0	6.0	0.20	0.22
16	220300	0.89	1.56	5.0	9.0	0.18	0.35
17	181700	0.80	1.15	5.0	9.0	0.16	0.18
18	202800	0.90	2.26	5.3	7.0	0.17	0.24
19	209000	0.92	1.40	6.0	7.0	0.20	0.24
20	189100	0.84	1.50	5.7	8.0	0.25	0.28
21	194400	0.86	0.96	5.0	10.0	0.23	0.32
22	151300	0.67	1.34	4.7	7.0	0.24	0.60
23	177200	0.78	1.34	4.3	6.0	0.29	0.41
24	175200	0.77	0.77	5.7	15.0	0.22	0.30
25	129900	0.57	0.57	7.0	12.0	0.22	0.35
26	127800	0.57	0.57	5.0	7.0	0.22	0.27
27	138100	0.61	0.70	7.7	12.0	0.20	0.22
28	190500	0.84	0.84	7.7	11.0	0.18	0.24
29	167000	0.74	0.74	8.5	13.0	0.17	0.18
30	151200	0.67	1.40	8.0	14.0	0.17	0.22
31	X	X	X	X	X	X	X



Handwritten scribbles or marks in the top right corner.



Pennsylvania Power & Light Company

Two North Ninth Street • Allentown, PA 18101 • 215 / 770-5151

July 14, 1988

Mr. Russell Sager
Sanitarian
Bureau of Community Environmental Control
Pennsylvania Department of Environmental Resources
290 South Pennsylvania Boulevard
Wilkes-Barre, PA 18701

SUSQUEHANNA STEAM ELECTRIC STATION
DRINKING WATER OPERATIONAL REPORT - JUNE 1988
PWS 2400998, OPERATING PERMIT #4085504
CCN 741326 FILE R9-8B
PLE- 10684

Dear Mr. Sager:

Pursuant to Special Condition 2 of Public Water Supply Permit No. 4085504, enclosed please find the Susquehanna Steam Electric Station drinking water operational report for June 1988.

If you have any questions, please contact me at (215) 770-7891.

Respectfully yours,

Curtis H. Saxton
Environmental Specialist-Nuclear

chs1te7002o(25)

Enclosure

cc: Mr. J. P. LaBuz Pa DER
~~Dr. W. R. Butler~~ US NRC

COOL
|||