

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATOR INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8808010038 DOC. DATE: 88/07/21 NOTARIZED: NO DOCKET #
 FACIL: 50-387 Susquehanna Steam Electric Station, Unit 1, Pennsylv 05000387
 50-388 Susquehanna Steam Electric Station, Unit 2, Pennsylv 05000388
 AUTH. NAME AUTHOR AFFILIATION
 KEISER, H.W. Pennsylvania Power & Light Co.
 RECIP. NAME RECIPIENT AFFILIATION
 BUTLER, W.R. Project Directorate I-2

SUBJECT: Submits response to NRC request for addl info re Generic Ltr 83-28. R

DISTRIBUTION CODE: A055D COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 2 I
 TITLE: OR/Licensing Submittal: Salem ATWS Events GL-83-28 D

NOTES: LPDR 2 cys Transcripts. 05000387S
 LPDR 2 cys Transcripts. 05000388

	RECIPIENT		COPIES		RECIPIENT		COPIES		
	ID CODE/NAME		LTR	ENCL	ID CODE/NAME		LTR	ENCL	
	PDI-2 LA		1	0	PDI-2 PD		3	0	D
	THADANI, M		1	1					D
INTERNAL:	ACRS		6	0	ARM/DAF/LFMB		1	0	S
	NRR LASHER, D		1	1	NRR/DEST/ESB 8D		1	1	
	NRR/DEST/ICSB 7		1	1	NRR/DEST/PSB 8D		1	0	
	NRR/DEST/RSB 8E		1	1	NRR/DLPQ/QAB 10		1	0	
	NRR/DOEA/GCB 11		1	0	NUDOCS-ABSTRACT		1	1	
	OGC 15-B-18		1	0	<u>REG-ELLE</u> 01		1	1	
	RES/DSIR/EIB		1	1					
EXTERNAL:	LPDR		2	2	NRC PDR		1	1	
	NSIC		1	1					
NOTES:			2	2					

R
I
D
S
/
A
D
D
S



Pennsylvania Power & Light Company

Two North Ninth Street • Allentown, PA 18101 • 215/770-5151

JUL 21 1988

Harold W. Keiser
Senior Vice President-Nuclear
215/770-4194

Director of Nuclear Reactor Regulation
Attn.: Dr. W. R. Butler
Project Directorate I-2
Division of Reactor Projects
U.S. Nuclear Regulatory Commission
Mail Station P1-137
Washington, D.C. 20555

SUSQUEHANNA STEAM ELECTRIC STATION
RESPONSE TO ADDITIONAL INFORMATION REQUEST
ON GENERIC LETTER 83-28
PLA-2928 FILE R41-2

Dear Dr. Butler:

The following is provided in response to a request made by your staff.

GE Service Information Letter (SILs) and Rapid Information Communication Services Information Letters (RICSILs) are processed in Pennsylvania Power & Light Company's Industry Event Review Program (IERP). The IERP assures that each SIL/RICSIL is evaluated for applicability to Susquehanna and that an appropriate resolution is determined. If that resolution includes recommendations for action to be accomplished, the IERP provides a means to track the recommended actions until they are complete and to verify that the completed action meets the intent of the recommended action. Feedback is given to GE on the PP&L resolution of SIL/RICSIL recommendation. The IERP is also used to evaluate all industry events not just those related to GE plants.

As we have stated in our previous submittals, the back-up scram valves are not tested under the Surveillance Program. These valves have been part of our Preventative Maintenance Program with no set testing schedule. We have recently changed the Preventative Maintenance Program to test these valves every 18 months.

In addition to the scram pilot valves and the back-up scram valves, we have installed additional DC powered solenoid valves as part of our ARI system in accordance with 10CFR50.62. These ARI valves are tested at least every 18 months.

If you have any additional questions, please contact us.

Very truly yours,

H. W. Keiser

8808010038 880721
PDR ADDCK 05000387
P PNU

A055
110

cc: ~~NRC Document Control Desk (original)~~
NRC Region I
Mr. L. R. Plisco, NRC Resident Inspector
Mr. M. C. Thadani, NRC Project Manager

THE UNIVERSITY OF CHICAGO
DEPARTMENT OF CHEMISTRY
540 SOUTH EAST ASIAN AVENUE
CHICAGO, ILLINOIS 60607

RECEIVED

1964

UNIVERSITY MICROFILMS
SERIALS ACQUISITION
300 NORTH ZEEB RD
ANN ARBOR MI 48106