

26 AUG 1988

Docket Nos. 50-387  
50-388

Pennsylvania Power & Light Company  
ATTN: Mr. Harold W. Keiser  
Senior Vice President - Nuclear  
2 North Ninth Street  
Allentown, Pennsylvania 18101

Gentlemen:

Subject: Enforcement Discretion Regarding the Mislocated Reactor Water  
Cleanup Room High Temperature Sensor

This letter confirms the telephone conversation of August 24, 1988, between Messrs. Eugene Heckman and Dale Roth and others of your staff and Messrs. Lowell Tripp and Gene Kelly and others of my staff granting your request for one-time enforcement discretion to allow for relocation of the subject instrument to its proper location. Specifically, for the reasons discussed in that telephone conversation and subsequently described in your letter to me dated August 25, 1988, this action grants relief from Susquehanna Unit 1 Technical Specification 3.3.2 (C) which specifies placing one reactor water cleanup isolation trip system in the trip condition. All other Technical Specifications remain in effect.

This discretion will remain in effect until 11:00 a.m. on Monday, August 29, 1988, unless you contact this office before that time and present justification for an extension.

~~Original~~ Signed By:

William T. Russell  
Regional Administrator

cc w/encl:

A. R. Sabol, Manager, Nuclear Quality Assurance  
E. A. Heckman, Licensing Group Supervisor  
R. G. Bryam, Superintendent of Plant-SSES  
H. W. Hirst, Manager, Joint Generation Projects Department  
R. J. Benich, Services Project Manager, General Electric Company  
B. A. Snapp, Esquire, Assistant Corporate Counsel  
H. D. Woodshick, Special Office of the President  
J. C. Tilton, III, Allegheny Electric Cooperative, Inc.  
Public Document Room (PDR)  
Local Public Document Room (LPDR)  
Nuclear Safety Information Center (NSIC)  
NRC Resident Inspector  
Commonwealth of Pennsylvania

*Incid.  
Action*

OFFICIAL RECORD COPY

HAVERKAMP 3378/26/88 - 0001.0.0  
08/26/88

8809070356 880826  
PDR ADOCK 05000387  
P PDC

*IE 01 1/p*

26 AUG 1988

bcc w/encl:  
 Region I Docket Room (with concurrences)  
 Management Assistant, DRMA (w/o encl)  
 DRP Section Chief  
 R. Bores, DRSS  
 M. Kohl, DRP  
 M. Thadani, NRR  
 PAO 10 (SALP) Reports Only

RI:/DRP Barkley 8/21/88	<del>DRP</del> Blough 8/26/88	<del>DRP</del> Wiggins 8/26/88	RI:DRP Collins 8/ /88	<sup>260</sup> RI:DRP Kane 8/26/88	RI:EO Holody 8/26/88
-------------------------------	-------------------------------------	--------------------------------------	-----------------------------	---	----------------------------

OFFICIAL RECORD COPY

HAVERKAMP 3378/26/88 - 0002.0.0  
08/26/88