

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8810250508 DOC. DATE: 88/10/19 NOTARIZED: NO DOCKET
 FACIL: 50-387 Susquehanna Steam Electric Station, Unit 1, Pennsylv 05000387
 AUTH. NAME AUTHOR AFFILIATION
 BYRAM, R. G. Pennsylvania Power & Light Co.
 RECIP. NAME RECIPIENT AFFILIATION
 RUSSELL, W. Region 1, Ofc of the Director

SUBJECT: Special rept: on 881003, meteorological monitoring instruments listed in Tech Spec Table 3.3.7-1 removed from svc.

DISTRIBUTION CODE: IE22D COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 1
 TITLE: 50.73 Licensee Event Report (LER), Incident Rpt, etc.


NOTES: LPDR 2 cys Transcripts.

05000387

	RECIPIENT		COPIES			RECIPIENT		COPIES	
	ID CODE/NAME		L	T		ID CODE/NAME		L	T
	PD1-2 LA		1	1		PD1-2 PD		1	1
	THADANI, M		1	1					
INTERNAL:	ACRS MICHELSON		1	1		ACRS MOELLER		2	2
	ACRS WYLIE		1	1		AEOD/DOA		1	1
	AEOD/DSP/TPAB		1	1		ARM/DCTS/DAB		1	1
	DEDRO		1	1		NRR/DEST/ADS 7E		1	1
	NRR/DEST/CEB 8H		1	1		NRR/DEST/ESB 8D		1	1
	NRR/DEST/ICSB 7		1	1		NRR/DEST/MEB 9H		1	1
	NRR/DEST/MTB 9H		1	1		NRR/DEST/PSB 8D		1	1
	NRR/DEST/RSB 8E		1	1		NRR/DEST/SGB 8D		1	1
	NRR/DLPQ/HFB 10		1	1		NRR/DLPQ/QAB 10		1	1
	NRR/DOEA/EAB 11		1	1		NRR/DREP/RAB 10		1	1
	NRR/DREP/RPB 10		2	2		NRR/DRTS/SIB 9A		1	1
	NUDOCS-ABSTRACT		1	1		REG FILE 02		1	1
	RES/DSIR/EIB		1	1		RES/DSR DEPY		1	1
	RES/DSR/PRAB		1	1		RGN1 FILE 01		1	1
EXTERNAL:	EG&G WILLIAMS, S		4	4		FORD BLDG HOY, A		1	1
	H ST LOBBY WARD		1	1		LPDR		2	2
	NRC PDR		1	1		NSIC HARRIS, J		1	1
	NSIC MAYS, G		1	1					
NOTES:			2	2					

TOTAL NUMBER OF COPIES REQUIRED: LTR 46 ENCL 0

[Handwritten signature]
I/A 2



Pennsylvania Power & Light Company

October 19, 1988

Two North Ninth Street • Allentown, PA 18101 • 215/770-5151

Mr. William Russell
Regional Administrator, Region I
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406


SUSQUEHANNA STEAM ELECTRIC STATION
SPECIAL REPORT - METEOROLOGICAL
MONITORING INSTRUMENTATION
ER 100450 FILE R41-2
PLAS- 341

Docket No. 50-387
License No. NPF-14

Dear Mr. Russell:

This special report, required by Technical Specification 3.3.7.3.a, documents the inoperability of all meteorological monitoring instrumentation channels for more than seven days, the reason for the inoperability, and the plans for restoring the instrumentation to operable status.

On October 3, 1988, all meteorological monitoring instruments listed in Technical Specification Table 3.3.7.3-1 were removed from service and declared inoperable in order to permit the implementation of plant modification PMR-87-7005. This modification replaced all meteorological monitoring instrumentation including sensing, signal conditioning, recording and telemetering components with instrumentation of a new design and supplier. PMR-87-7005 was implemented in accordance with PP&L's response to NRC Region I Combined Inspection Reports 50-387/86-10 and 50-388/86-10 as described in PLA-2715 dated September 12, 1986. Plans are to restore the meteorological monitoring instrumentation to operable status by October 21, 1988.


R.G. Byram
Superintendent of Plant - Susquehanna

RGS/mjm

cc: Mr. Frank Young
Sr. Resident Inspector
U.S. Nuclear Regulatory Commission
P.O. Box 52
Shickshinny, PA 18655

U.S. Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555

8810250508 881019
PDR ADUCK 05000387
S PDC

IE 22
1/0