



NOTES
 1) PROTECTED SAFE SHUTDOWN PATH (I.E. DIVISION) IS DEFINED AS THOSE SAFE SHUTDOWN CABLES AND COMPONENTS WHICH MUST BE PROTECTED FROM FIRE DAMAGE WITHIN THE DESIGNATED FIRE ZONE. WHERE BOTH DIVISIONS ARE SHOWN, BOTH DIVISIONS MUST BE PROTECTED.

DEVIATION REQUEST NO. 14
 FIRE ZONES WITHOUT FIRE DETECTION

FLOOR PLAN @ EL. 818'-1'

REFERENCE DRAWINGS	
A-17	E-184302, SHT. 7
C-1739	E-105004, SHT. 7
C-1738	E-205968
C-1737	E-205967
C-1736	E-205966
C-1735	E-205965

NO.	DESCRIPTION	DATE	BY	CHK	APPROVED
1	PER ENGINEERING INFO.	12/16/77	746		
0	INITIAL ISSUE				

SUSQUEHANNA S.E.S.
 UNIT 1
 REACTOR BUILDING
 FIRE ZONE PLAN OF
 ELEVATION 818'-1'

AREA 27.8, 29 ELEV. 818'-1' SCALE 1/8" = 1'-0"

PENNSYLVANIA POWER & LIGHT COMPANY
 ALLENTOWN PA.

DATE: 12/16/77 SHEET NO. 1 OF 1
 DRAWING NO. E-205956
 REVISION NO. C-1727

LEGEND

- I DIVISION I PROTECTED SAFE SHUTDOWN PATH
- II DIVISION II PROTECTED SAFE SHUTDOWN PATH
- ▨ 3/4" FIRE RATED WALLS
- ▭ FIRE ZONE BOUNDARY
- ◇ FIRE EXIST. NUMBER

30X I CERTIFY THAT THE IMAGE CONTAINED ON THIS FRAME WAS MADE IN THE NORMAL AND REGULAR COURSE OF BUSINESS ON THE DATE STATED BELOW AND THAT IT IS AN ACCURATE REPRODUCTION OF THE DOCUMENT SUBMITTED TO SRMS CORRESPONDENCE AND DRAWING FILES
 DATE: 12/16/77

8812200330

SI APERTURE CARD