



FLOOR PLAN @ EL. 645'-0"

DEVIATION REQUEST NO. 14  
FIRE ZONES WITHOUT FIRE DETECTION

NOTES  
1) PROTECTED SAFE SHUTDOWN PATH (I.E. DIVISION) IS DEFINED AS THOSE SAFE SHUTDOWN CADLES AND COMPONENTS WHICH MUST BE PROTECTED FROM FIRE DAMAGE WITHIN THE DESIGNATED FIRE ZONE. WHERE BOTH DIVISIONS ARE SHOWN, BOTH DIVISIONS MUST BE PROTECTED.

LEGEND

	FIRE ZONES		INERTED CONTAINMENT BOUNDARY
	DIVISION I PROTECTED SAFE SHUTDOWN PATH		3 IN. FIRE RATED WALLS
	DIVISION II PROTECTED SAFE SHUTDOWN PATH		FIRE DOOR NUMBER

A-11	E-184302, SHT. 1
C-1738	E-104004, SHT. 1
C-1738	E-205368
C-1738	E-205367
C-1737	E-205366
C-1736	E-205365
AC EXAMING NO.	SPL. DRAWING NO.
SUSQUEHANNA S.E.S. UNIT 2 REACTOR BUILDING FIRE ZONE PLAN OF ELEVATION 645'-0"	
AREA 30, D. 33, 34 ELEV. 645'-0" SCALE 1/8" = 1'-0"	
PENNSYLVANIA POWER & LIGHT COMPANY ALLENTOWN, PA.	
DWG. NO. E-205957	SHEET NO. 1
EXAMING NO. C-1728	SHEET NO. 1

30X I CERTIFY THAT THE IMAGE CONTAINED ON THIS FRAME WAS MADE IN THE NORMAL AND REGULAR COURSE OF BUSINESS ON THE DATE STATED BELOW, AND THAT IT IS AN ACCURATE REPRODUCTION OF THE DOCUMENT SUBMITTED TO SHOW CORRESPONDENCE AND DRAWING FILES.  
DATE: 12/14/80

SI APERTURE CARD 8812200331