

TABLE 3.6.3-1 (Continued)
PRIMARY CONTAINMENT ISOLATION VALVES

<u>VALVE FUNCTION AND NUMBER</u>	<u>MAXIMUM ISOLATION TIME (Seconds)</u>	<u>ISOLATION SIGNAL(s)^(a)</u>
<u>Automatic Isolation Valves (Continued)</u>		
<u>Containment Atmosphere Sample</u>		
SV-15734 A,B	N/A	B,Y
SV-15736 A	N/A	B,Y
SV-15736 B	N/A	B,Y
SV-15740 A,B	N/A	B,Y
SV-15742 A,B	N/A	B,Y
SV-15750 A,B	N/A	B,Y
SV-15752 A,B	N/A	B,Y
SV-15774 A,B	N/A	B,Y
SV-15776 A	N/A	B,Y
SV-15776 B	N/A	B,Y
SV-15780 A,B	N/A	B,Y
SV-15782 A,B	N/A	B,Y
<u>Nitrogen Makeup</u>		
SV-15737	N/A	B,Y,R
SV-15738	N/A	B,Y,R
SV-15767	N/A	B,Y,R
SV-15789	N/A	B,Y,R
<u>Reactor Coolant Sample</u>		
HV-143F019	2	B,C
HV-143F020	2	B,C
<u>Liquid Radwaste</u>		
HV-16108 A1,A2	15	B,Z
HV-16116 A1,A2	15	B,Z
<u>RHR - Suppression Pool</u>		
<u>Cooling/Spray^(c)</u>		
HV-151F011 A,B	23	X,Z
HV-151F028 A,B	90	X,Z
<u>CS Test^{(b)(c)}</u>		
HV-152F015 A,B	60	X,Z
<u>HPCI Suction^{(b)(c)}</u>		
HV-155F042	90	L,LB

SUSQUEHANNA - UNIT 1

3/4 6-21

Amendment No. 50

8903090047 890224
PDR ADCK 05000387
P PIC

TABLE 3.6.3-1 (Continued)

PRIMARY CONTAINMENT ISOLATION VALVES

VALVE FUNCTION AND NUMBER

Manual Isolation Valves (Continued)

SLCS^(b)

HV-148F006

Demineralized Water

1-41-017

1-41-018

ILRT

1-57-193

1-57-194

HPCI Turbine Exhaust^(b)

HV-155F066

RHR - Shutdown Cooling Return/
LPCI Injection - Pressure Equalizing Valve

HV-151F122 A,B

c. Other Valves

Feedwater

141F010 A,B

RHR - Shutdown Cooling Suction

PSV-151F126

RHR - Shutdown Cooling Return/
LPCI Injection

HV-151F050 A,B

RHR-Suppression Pool
Cooling/Spray^(c)

HV-151F011 A,B

12

1941
A. B. ...

TABLE 3.8.4.2.1-1 (Continued)

MOTOR OPERATED VALVES THERMAL OVERLOAD PROTECTION CONTINUOUS

<u>VALVE NUMBER</u>	<u>SYSTEM(S) AFFECTED</u>
HV-E11-1F040	RHR
HV-G33-1F001	RWCU
HV-E11-1F103A	RHR
HV-E11-1F075A	RHR
HV-E11-1F048A	RHR
HV-E11-1F006C	RHR
HV-E11-1F004C	RHR
HV-E11-1F015A	RHR
HV-E11-1F024A	RHR
HV-E21-1F015A	RHR
HV-E41-1F002	CS
HV-B21-1F016	HPCI
HV-E11-1F022	NSSS
HV-E11-1F010A	RHR
HV-E11-1F011A	RHR
HV-E11-1F004A	RHR
HV-E11-1F006A	RHR
HV-E11-1F027A	RHR
HV-E11-1F007A	RHR
HV-E11-1F104A	RHR
HV-E11-1F026A	RHR
HV-E11-1F028A	RHR
HV-E11-1F047A	RHR
HV-E11-1F073A	RHR
HV-E11-1F003A	RHR
HV-E11-1F017A	RHR
HV-E21-1F001A	RHR
HV-E21-1F031A	CS
HV-E21-1F004A	CS
HV-E21-1F005A	CS
HV-E11-1F021A	CS
HV-E11-1F016A	RHR
HV-15112	RHR
HV-E51-1F007	RHR
HV-E51-1F084	RCIC
HV-E11-1F027B	RHR
HV-E11-1F048B	RHR
HV-E11-1F015B	RHR
HV-E11-1F006B	RHR
HV-E11-1F021B	RHR
HV-E11-1F010B	RHR
HV-E11-1F011B	RHR
HV-E11-1F004B	RHR
HV-E11-1F007B	RHR
HV-E11-1F104B	RHR
HV-E11-1F026B	RHR

