

8707050503 870814

ADDCK 05000387

PNU

PDR

UNITED STATES NUCLEAR REGULATORY COMMISSION WASHINGTON, D. C. 20555

PENNSYLVANIA POWER & LIGHT COMPANY

ALLEGHENY ELECTRIC COOPERATIVE, INC.

DOCKET NO. 50-387

SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 92 License No. NPF-14

- 1. The Nuclear Regulatory Commission (the Commission or the NRC) having found that:
 - A. The application for the amendment filed by the Pennsylvania Power & Light Company, dated April 14, 1989 complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the regulations of the Commission;
 - C. There is reasonable assurance: (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations set forth in 10 CFR Chapter I;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
- Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment and paragraph 2.C.(2) of the Facility Operating License No. NPF-14 is hereby amended to read as follows:
 - (2) Technical Specifications and Environmental.Protection.Plan

The Technical Specifications contained in Appendix A, as revised through Amendment No. 92 and the Environmental Protection Plan contained in Appendix B, are hereby incorporated in the license. PP&L shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

FOR THE NUCLEAR REGULATORY COMMISSION

/S/

Walter R. Butler, Director Project Directorate I-2 Division of Reactor Projects I/II

Attachment: Changes to the Technical Specifications

Date of Issuance: August 16, 1989



/PM MThadani:mj /// /89



ł

and the set of the set

North March Martin Martin Contraction Contraction

, ,

મ ક્રમ વાંચ વ્યક્તિ કેંદ્ર દેવાં વિદ્વાર્થ ના ગાળવા કેંદ્ર કેંદ્ર સ્વતુ વધુ છે. છે જ સ્વાર્થ

· ·

•••

FOR THE NUCLEAR REGULATORY COMMISSION

Tutter

Walter R. Butler, Director Project Directorate I-2 Division of Reactor Projects I/II

.

Attachment: Changes to the Technical Specifications

Date of Issuance: August 16, 1989

ATTACHMENT TO LICENSE AMENDMENT NO. 92

FACILITY OPERATING LICENSE NO. NPF-14

DOCKET NO. 50-387

Replace the following pages of the Appendix A Technical Specifications with enclosed pages. The revised pages are identified by Amendment number and contain vertical lines indicating the area of change. The overleaf page(s) are provided to maintain document completeness.*

REMOVE	INSERT
3/4 8-13	3/4 8-13
3/4 8-14	3/4 8-14*
3/4 8-29	3/4 8-29
3/4 8-30	3/4 8-30*
3/4 8-32a	3/4 8-32a*
3/4 8-32b	3/4 8-32b

SURVEILLANCE REQUIREMENTS (Continued)

- 5) Channel "A" battery 20612:
 - 323 amperes for 60 seconds
- 96 amperes for the remainder of the 4 hour test. 6) Channel "B" battery 2D622:
 - 324 amperes for 60 seconds
 - 96 amperes for the remainder of the 4 hour test.
- 7) Channel "C" battery 2D632:
 - 297 amperes for 60 seconds
- 80 amperes for the remainder of the 4 hour test. 8) Channel "D" battery 2D642:
 - 300 amperes for 60 seconds
 - 83 amperes for the remainder of the 4 hour test.
- 9) Channel "H" battery OD595: 253 amperes for the first 60 seconds 75 amperes for the remainder of the 4 hour test.
- c) For 250-volt batteries:
 - 1) Battery bank 1D650: 1120 amperes for 60.0 seconds 599 amperes for 29.0 minutes 99 amperes for 120.0 minutes 27 amperes for 90.0 minutes
 - 2) Battery bank 10660: 887 amperes for 60.0 seconds 396 amperes for 9.0 minutes 20.0 minutes 366 amperes for 325 amperes for 90.0 minutes 187 amperes for 119.0 minutes 229 amperes for . 60.0 seconds
- e. At least once per 60 months by verifying that the battery capacity is at least 80% of the manufacturer's rating when subjected to a performance discharge test. Once per 60 month interval, this performance discharge test may be performed in lieu of the battery service test.
- f. Annual performance discharge tests of battery capacity shall be given to any battery that shows signs of degradation or has reached 85% of the service life expected for the application. Degradation is indicated when the battery capacity drops more than 10% of rated capacity from its average on previous performance tests, or is below 90% of the manufacturer's rating.

TABLE 4.8.2.1-1

BATTERY SURVEILLANCE REQUIREMENTS

	CATEGORY A(1)	CATEGORY	(2) B ⁽²⁾
Parameter	Limits for each designated pilot cell	Limits for each connected cell	Allowable ⁽³⁾ value for each connected cell
Electrolyte Level	>Hinimum level indication mark, and < '#" above maximum level indication mark	>Hinimum level indication mark, and < %" above maximum level indication mark	Above top of plates, and not overflowing
Float Voltage	> 2.13 volts	\geq 2.13 volts(c)	> 2.07 volts
		≥ 1.195 ^(b) .	Not mere than .020 below the average of all connected cells
Specifica) Gravity(a)	≥ 1.200 ¹⁰⁷	Average of all . connected cells > 1.205	Average of all connected calls ≥ 1.195 ^(D)

- (a) Corrected for electrolyte temperature and level.
- (b) Or battery charging current is less than 0.01, 0.1 and 0.25 amperes for the ± 24 , 125 and 250 welt batteries, respectively, when on float charge.
- (c) May be corrected for average electrolyte temperature.
- (1) For any Category A parameter(s) outside the limit(s) shown, the battery may be considered OPERABLE provided that within 24 hours all the Category B measurements are taken and found to be within their allowable values, and provided all Category A and B parameter(s) are restored to within limits within the maxt 6 days.
- (2) For any Category S parameter(s) outside the limit(s) shown, the battery may be considered OPERABLE provided that the Category S parameters are within their allowable values and provided the Category S parameter(s) are restored to within limits within 7 days.
- (3) Any Category 8 perameter not within its alloweble value indicates an inoperable battery.

TABLE 3.8.4.2.1-1

MOTOR OPERATED VALVES THERMAL OVERLOAD PROTECTION - CONTINUOUS

42

VALVE NUMBER	SYSTEM(S) AFFECTED
HV-01222A	RHRSW
HV-01222B	RHRSW
HV-01224A1	RHRSW
HV-01224B1	RHRSW
HV-01224A2	RHRSW
HV-01224B2	RHRSW
HV-08693A	ESW
HV-08693B	ESW
HV-01201A1	RHRSW
HV-01201A2	RHRSW
HV-01201B1	· RHRSW
HV-01201B2	RHRSW
HV-11210A	RHRSW
HV-11210B	RHRSW
HV-11215A	RHRSW
HV-11215B	RHRSW
HV-15766	Cont. Isol
HV-15768	Cont. Isol
HV-12603	Cont. Isol
HV-11345 .	Cont. Isol
HV-11313	Cont. Isol
HV-11346	Cont. Isol
HV-11314	Cont. Isol
HV-FTT-TE008	RHR

TABLE 3.8.4.2.1-1 (Continued)

MOTOR OPERATED VALVES THERMAL OVERLOAD PROTECTION CONTINUOUS

ī

. •

(1) (7) 7 7040	
HV-E11-1F040	SHD
HV-G33-1F001	RWCII
HV-E11-1F103A	0HD
HV-E11-1F075A	DHDCM
HV-E11-1F048A	000
HV-E11-1F006C	OUD
HV-E11-1F004C	OUD
HV-E11-1F015A	0U0
HV-E11-1F024A	DUD
HV-E21-1F015A	ΛΠΛ Γς
HV-E41-1F002	HPCT
HV-B21-1F016	NSSS
HV-E11-1F022	RHR
HV-E11-1F010A	QUD
HV-E11-1F004A	QHD
HV-E11-1F006A	DHD
HV-E11-1F027A	RHP
HV-E11-1F007A	PHD
HV-E11-1F104A	DHD
HV-E11-1F028A	RHR
HV-E11-1F047A	RHD
HV-E11-1F073A	RHRCW
HV-E11-1F003A	
HV-E11-1F017A	RHR
HV-E21-1F001A	nnn CC
HV-E21-1F031A	~~ ^<
HV-E21-1F004A	~~ ~~
HV-E21-1F005A	20
HV-E11-1F021A ·	2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2
HV-E11-1F016A	SHB .
HV-15112	RHR
HV-E51-1F007	21.75
HV-E51-1F084	
HV-E11-1F027B	RHR
HV-E11-1F048B	RHR
HV-E11-1F015B	2HR
HV-E11-1F006B	RHR
HV-E11-1F021B	RHR
HV-E11-1F0108	RHR
HV-E11-1F004B	RHR
HV-E11-1F007B	RHR
HV-E11-1F104B	RHR

SUSQUEHANNA - UNIT 1

٢.

ł

L

I

MOTOR OPERATED VALVES THERMAL OVERLOAD PROTECTION - AUTOMATIC

LIMITING CONDITION FOR OPERATION

3.8.4.2.2 The thermal overload protection of each valve shown in Table 3.8.4.2.2-1 shall be bypassed automatically by an OPERABLE bypass device integral with the motor starter.

<u>APPLICABILITY</u>: When diesel generator E is not aligned to the Class 1E distribution system.

ACTION:

a. With thermal overload protection automatic bypass inoperable for one or more valves listed above, take administrative action to continuously bypass the thermal overload within 8 hours, or verify that all diesel generator E ESW valves are closed and diesel generator E is not running within 8 hours.

SURVEILLANCE REQUIREMENTS

4.8.4.2.2.1 The automatic bypass of thermal overload protection for those valves listed above shall be demonstrated OPERABLE at least once per 18 months.

TABLE 3.8.4.2.2-1

MOTOR OPERATED VALVES THERMAL OVERLOAD PROTECTION - AUTOMATIC

VALVE NUMBER	SYSTEM(S) AFFECTED
HV-01110E	ESW
HV-01120E	ESW
HV-01112E	ESW
HV-01122E	ESW

SUSQUEHANNA - UNIT 1

Amendment No. 92



UNITED STATES NUCLEAR REGULATORY COMMISSION WASHINGTON, D. C. 20555

PENNSYLVANIA POWER & LIGHT COMPANY

ALLEGHENY ELECTRIC COOPERATIVE, INC.

DOCKET NO. 50-388

SUSQUEHANNA STEAM ELECTRIC STATION, UNIT 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 56 License No. NPF-22

- 1. The Nuclear Regulatory Commission (the Commission or the NRC) having found that:
 - A. The application for the amendment filed by the Pennsylvania Power & Light Company, dated April 14, 1989 complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the regulations of the Commission;
 - C. There is reasonable assurance: (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations set forth in 10 CFR Chapter I;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
- Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment and paragraph 2.C.(2) of the Facility Operating License No. NPF-22 is hereby amended to read as follows:
 - (2) Technical Specifications and Environmental Protection Plan

The Technical Specifications contained in Appendix A, as revised through Amendment No. 56 and the Environmental Protection Plan contained in Appendix B, are hereby incorporated in the license. PP&L shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

r

, £

•

•

•

¥ · · · · · ٢

• . •

. . . , *i* ,

FOR THE NUCLEAR REGULATORY COMMISSION

/S/

Walter R. Butler, Director Project Directorate I-2 Division of Reactor Projects I/II

1

Attachment: Changes to the Technical Specifications

Date of Issuance: August 16, 1989







a second and the second and the second

มินชี⁷¹คื เ ถิ่นู่ได้ เ ันโหเหเอ มีนั่งเกิ ถิชี*า เ วิ ผมกั หู่หัวงเกิ

·

ી હતુ દુધ તે જે જે અને મહેનો આ તે જે જે જે અને મહેનો આ તે જે જે અને સ્ટાર્ગ જે જે અને સ્ટાર્ગ આ તે જે જે અને સ્ટાર્ગ જે સ

FOR THE NUCLEAR REGULATORY COMMISSION

t.

Walter R. Butler, Director Project Directorate I-2 Division of Reactor Projects I/II

Attachment: Changes to the Technical Specifications

Date of Issuance: August 16, 1989

ATTACHMENT TO LICENSE AMENDMENT NO. 56

FACILITY OPERATING LICENSE NO. NPF-14

DOCKET NO. 50-387

Replace the following pages of the Appendix A Technical Specifications with enclosed pages. The revised pages are identified by Amendment number and contain vertical lines indicating the area of change. The overleaf pages are provided to maintain document completeness.*

REMOVE	INSERT
3/4 8-13	3/4 8-13*
3/4 8-13a	3/4 8-13a
3/4 8-31	3/4 8-31
3/4 8-32	3/4 8-32*
3/4 8-34a	3/4 8-34a*
3/4 8-34b	3/4 8-34b

SURVEILLANCE REQUIREMENTS (Continued)

- c. At least once per 18 months by verifying that:
 - 1. The cells, cell plates, and battery racks show no visual indication of physical damage or abnormal deterioration.
 - 2. The cell-to-cell and terminal connections are clean, tight, free of corrosion, and coated with anticorrosion material,
 - 3. The resistance of each cell-to-cell and terminal connection of each 125-volt and 250-volt battery is less than or equal to 150 \times 10-5 ohm, and
 - 4. The battery charger, for at least 4 hours, will supply at least:
 - a) For the ± 24-volt batteries, 25 amperes at a minimum of 25.7 volts.
 - b) For the 125-volt batteries, 100 amperes at a minimum of 127.8 volts.
 - c) For the 250-volt batteries, 300 amperes at a minimum of 255.6 volts.
 - d) For the 125 volt generator E batteries, 200 amperes at a minimum of 127.8 volts
- d. At least once per 18 months by verifying that either:
 - 1. The battery capacity is adequate to supply and maintain in OPERABLE status all of the actual emergency loads for the design duty cycle when the battery is subjected to a battery service test, or
 - 2. The battery capacity is adequate to supply a dummy load of the following profile, which is verified to be greater than the actual emergency loads, while maintaining the battery terminal voltage greater than or equal to \pm 21, 105 or 210 volts, as applicable.
 - a) For \pm 24-volt battery banks 2D670, 2D670-1, 2D680, and 2D680-1, 9.37 amperes for the entire 4-hour test.
 - b) For 125-volt batteries:
 - 1) Channel "A" battery 10612: 325 amperes for 60 seconds 95 amperes for the remainder of the 4 hour test
 - 2) Channel "B" battery 1D622: 325 amperes for 60 seconds 95 amperes for the remainder of the 4 hour test
 - 3) Channel "C" battery 1D632: 294 amperes for 60 seconds 73 amperes for the remainder of the 4 hour test
 - 4) Channel "D" battery 1D642: 297 amperes for 60 seconds 76 amperes for the remainder of the 4 hour test.
 - 5) Channel "A" battery 2D612: 323 amperes for 60 seconds 96 amperes for the remainder of the 4 hour test
 - 6) Channel "B" battery 20622: 324 amperes for 60 seconds 96 amperes for the remainder of the 4 hour test

SUSQUEHANNA - UNIT 2

Amendment No. 55

SURVEILLANCE REQUIREMENTS (Continued)

- 7) Channel "C" battery 2D632: 297 amperes for 60 seconds 80 amperes for the remainder of the 4 hour test
- 8) Channel "D" battery 2D642: 300 amperes for 60 seconds 83 amperes for the remainder of the 4 hour test
- 9) Channel "H" battery OD595: 253 amperes for the first 60 seconds, 75 amperes for the remainder of the 4 hour test.
- c) For 250-volt batteries:
 - 1) Battery bank 2D650: 458 amperes for 60 seconds 251 amperes for 239 minutes
 - 2) Battery bank 2D660: 1119 amperes for 60 seconds 244 amperes for 239 minutes
- e. At least once per 60 months by verifying that the battery capacity is at least 80% of the manufacturer's rating when subjected to a performance discharge test. Once per 60-month interval, this performance discharge test may be performed in lieu of the battery service test.
- f. Annual performance discharge tests of battery capacity shall be given to any battery that shows signs of degradation or has reached 85% of the service life expected for the application. Degradation is indicated when the battery capacity drops more than 10% of rated capacity from its average on previous performance tests, or is below 90% of the manufacturer's rating.

TABLE 3.8.4.2.1-1

، • الم .,.

13.48

MOTOR-OPERATED VALVES THERMAL OVERLOAD PROTECTION CONTINUOUS

•	SYSTEM(S)
VALVE NUMBER	AFFECTÈD
HV-01222A	RHRSW
HV-01222B	RHRSW
HV - 0122401	DHDCW
UV-01224R1	DUDCH
	RIKOW
	KHRSW
HV-01224B2	RHRSW
HV-21144A	ESW
HV-21144B	ESW
HV-08693A	ESW
HV-08693B	ESW
HV-01201A1	RHRSW
HV = 0120102	RHRSW
UV_01201R2	DLDCM
	RUNCH OUDCH
	KHKSW
HV-21210A	RHRSW
HV-21210B	RHRSW
HV-21215A	RHRSW
HV-21215B	. RHRSW
HV-25766	Cont. Isol.
HV-25768	Cont. Isol
HV-22603	Cont Isol
	CONC. 1301.

ł

<u>TABLE 3.8.4.2.1-1</u> (Continued)

MOTOR-OPERATED VALVES THERMAL OVERLOAD PROTECTION CONTINUOUS

VALVE NUMBER	SYSTEM(S) AFFECTED
HV-21345	Cont. Isol.
HV-21313	Cont. Isol.
HV-21346	Cont. Isol.
HV-21314	Cont. Isol.
HV-E11-2F009	RHR
HV-E11-2F040	RHR
HV-G33-2F001	RWCU
HV-E11-2F103A	RHR
HV-E11-2F075A	RHRSW
HV-E11-2F048A	RHR
HV-E11-2F006C	RHR
HV-E11-2F004C	RHR
HV-E11-2F015A	RHR
HV-E11-2F024A	RHR
HV-E21-2F015A	· CS
HV-E41-2F002	HPCI
HV-B21-2F016	NSSS
HV-E11-2F022	RHR
HV-E11-2F010A	- RHR
HV-E11-2F011A	RHR
HV-E11-2F004A	RHR
HV-E11-2F006A	RHR
HV-E11-2F027A	RHR
HV-E11-2F007A	RHR
HV-E11-2F104A	RHR
HV-E11-2F026A	RHR
HV-E11-2F028A	RHR
HV-E11-2F047A	RHRSW
HV-E11-2F073A	RHR
HV-E11-2F003A	BHP
HV-E11-2F017A HV-E21-2F001A HV-E21-2F031A	CS CS
HV-E21-2F004A HV-E21-2F005A HV-E11-2F021A HV-E11-2F021A	CS RHR RHR
HV-25112 HV-251-2F007 HV-E51-2F007 HV-E51-2F084	RHR RCIC RCIC
HV-E11-2F027B	RHR
HV-E11-2F048B	RHR
HV-E11-2F048B	RHR
HV-E11-2F006B	RHR

.

.

Amendment No. 32

MOTOR OPERATED VALVES THERMAL OVERLOAD PROTECTION - AUTOMATIC

LIMITING CONDITION FOR OPERATION

3.8.4.2.2 The thermal overload protection of each valve shown in Table 3.8.4.2.2-1 shall be bypassed automatically by an OPERABLE bypass device integral with the motor starter.

<u>APPLICABILITY</u>: When diesel generator E is not aligned to the Class 1E distribution system.

ACTION:

a. With thermal overload protection automatic bypass inoperable for one or more valves listed above, take administrative action to continuously bypass the thermal overload within 8 hours, or verify that all diesel generator E ESW valves are closed and diesel generator E is not running within 8 hours.

SURVEILLANCE REQUIREMENTS

4.8.4.2.2.1 The automatic bypass of thermal overload protection for those valves listed above shall be demonstrated OPERABLE at least once per 18 months.

TABLE 3.8.4.2.2-1

MOTOR OPERATED VALVES THERMAL OVERLOAD PROTECTION - AUTOMATIC

Valve Number	System(s) <u>Affected</u>
HV-01110E	ESW
HV-01120E	ESW
HV-01112E	ESW
HV-01122E	ESW

20

SUSQUEHANNA - UNIT 2