

8910060173 891002
PDR ADDCK 05000387
PIC

SUSQUEHANNA - UNIT 1

TABLE 3.3.4.1-1

ATWS RECIRCULATION PUMP TRIP SYSTEM INSTRUMENTATION

<u>TRIP FUNCTION</u>	<u>MINIMUM OPERABLE CHANNELS PER TRIP SYSTEM^(a)</u>
1. Reactor Vessel Water Level - Low Low, Level 2	2
2. Reactor Vessel Steam Dome Pressure - High	2

3/4 3-37

(a) One channel ^{or trip system} may be placed in an inoperable status for up to 2 hours for required surveillance provided the other channel is OPERABLE. Upon determination that a trip setpoint cannot be restored to within ^{trip system} its specified value during performance of the CHANNEL CALIBRATION, the appropriate ACTION shall be followed.



TABLE 3.3.4.1-1

ATWS RECIRCULATION PUMP TRIP SYSTEM INSTRUMENTATION

<u>TRIP FUNCTION</u>	<u>MINIMUM OPERABLE CHANNELS PER TRIP SYSTEM^(a)</u>
1. Reactor Vessel Water Level - Low Low, Level 2	2
2. Reactor Vessel Steam Dome Pressure - High	2

or trip system

(a) One channel may be placed in an inoperable status for up to 2 hours for required surveillance provided the other channel is OPERABLE. Upon determination that a trip setpoint cannot be restored to *trip system*

within its specified value during performance of the CHANNEL CALIBRATION, the appropriate ACTION shall be followed.