

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8910110192 DOC. DATE: 89/10/02 NOTARIZED: YES DOCKET #
 FACIL: 50-387 Susquehanna Steam Electric Station, Unit 1, Pennsylv 05000387
 50-388 Susquehanna Steam Electric Station, Unit 2, Pennsylv 05000388
 AUTH. NAME AUTHOR AFFILIATION
 KEISER, H.W. Pennsylvania Power & Light Co.
 RECIP. NAME RECIPIENT AFFILIATION
 BUTLER, W.R. Project Directorate I-2

SUBJECT: Forwards Proposed Amend 125 & 76 to Licenses NPF-14 & NPF-22, revising requirements of Tech Spec 4.0.2.

DISTRIBUTION CODE: A001D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 448
 TITLE: OR Submittal: General Distribution

NOTES: LPDR 1 cy Transcripts. 05000387
 LPDR 1 cy Transcripts. 05000388

	RECIPIENT		COPIES			RECIPIENT		COPIES	
	ID CODE/NAME		LTR	ENCL		ID CODE/NAME		LTR	ENCL
	PD1-2 LA		1	1		PD1-2 PD		1	1
	THADANI, M		5	5					
INTERNAL:	ACRS		6	6		NRR/DEST/ADS 7E		1	1
	NRR/DEST/ESB 8D		1	1		NRR/DEST/ICSB		1	1
	NRR/DEST/MTB 9H		1	1		NRR/DEST/RSB 8E		1	1
	NRR/DOEA/TSB 11		1	1		NUDOCS-ABSTRACT		1	1
	OC/LMB		1	0		OGC/HDS2		1	0
	<u>REG FILE</u> 01		1	1		RES/DSIR/EIB		1	1
EXTERNAL:	LPDR		1	1		NRC PDR		1	1
	NSIC		1	1					
NOTES:			2	2					

total

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK, ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTR 29 ENCL 27

R
I
D
S
/
A
D
S

R
I
D
S
/
A
D
S



Pennsylvania Power & Light Company

Two North Ninth Street • Allentown, PA 18101 • 215/770-5151

Harold W. Keiser
Senior Vice President-Nuclear
215/770-4194

OCT 02 1989

Director of Nuclear Reactor Regulation
Attention: Dr. W. R. Butler, Project Director
Project Directorate I-2
Division of Reactor Projects
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

SUSQUEHANNA STEAM ELECTRIC STATION
PROPOSED AMENDMENT 125 TO LICENSE NPF-14
AND AMENDMENT 76 TO LICENSE NPF-22
PLA-3267 FILES A17-2/R41-2

Docket Nos. 50-387
and 50-388

Dear Dr. Butler:

The purpose of this letter is to propose amendments to Facility Operating Licenses NPF-14 and NPF-22. The proposed amendments seek to change the requirements of Technical Specification 4.0.2. Currently, Technical Specification 4.0.2 allows surveillance intervals to be extended up to 25 percent of the time interval specified but limits the combined time interval for any three consecutive surveillance intervals to no more than 3.25 times the specified surveillance interval. The proposed change seeks removal of the 3.25 limit. The proposed change is consistent with the guidance provided in Generic Letter 89-14, "Line-Item Improvements in Technical Specifications- Removal of the 3.25 Limit on Extending Surveillance Intervals."

Background

Experience indicates that the currently required surveillance intervals, with the provision to extend them by 25 percent, are generally sufficient to accommodate normal operational variations. However, we have had to request and were granted a one-time exception to the 3.25 limit on extending refueling surveillances for the Susquehanna SES, Unit 2, Third Refueling and Inspection Outage.

Commonwealth Edison Company submitted a lead-plant proposal for the LaSalle Technical Specifications to remove the 3.25 limitation for all surveillances. The proposal was approved.

Based on the above and the guidance provided in Generic Letter 89-14, we are submitting this proposed change to remove the 3.25 limitation for all surveillances for the Susquehanna SES Units 1 and 2 Technical Specifications.

8910110192 891002
PDR ADOCK 05000387
P PDC

Pool 11

200 5 10 10

The following information is for your information only. It is not intended to be used as a basis for any action. The information is based on the best available information at the time of this report.

It is noted that the information is based on the best available information at the time of this report. It is not intended to be used as a basis for any action.

100 10 10

The information is based on the best available information at the time of this report. It is not intended to be used as a basis for any action. The information is based on the best available information at the time of this report.

200 5 10 10

The information is based on the best available information at the time of this report. It is not intended to be used as a basis for any action. The information is based on the best available information at the time of this report.

The information is based on the best available information at the time of this report. It is not intended to be used as a basis for any action. The information is based on the best available information at the time of this report.

The information is based on the best available information at the time of this report. It is not intended to be used as a basis for any action. The information is based on the best available information at the time of this report.

100 10 10

Description of the Change

The proposed change deletes the current requirements of Technical Specification 4.0.2 and replaces them with the following:

- 4.0.2 Each Surveillance Requirement shall be performed within the specified surveillance interval with a maximum allowable extension not to exceed 25 percent of the specified surveillance interval.

Additionally, the Bases Section of Technical Specification 4.0.2 must be changed. The proposed change to the Bases Section is in accordance with the guidance of Generic Letter 87-09. The changed section should read as follows:

Specification 4.0.2 established the limit for which the specified time interval for Surveillance Requirements may be extended. It permits an allowable extension of the normal surveillance interval to facilitate surveillance scheduling and consideration of plant operating conditions that may not be suitable for conducting the surveillance; e.g., transient conditions or other ongoing surveillance or maintenance activities. It also provides flexibility to accommodate the length of a fuel cycle for surveillances that are performed at each refueling outage and are specified with an 18-month surveillance interval. It is not intended that this provision be used repeatedly as a convenience to extend surveillance intervals beyond that specified for surveillances that are not performed during refueling outages. The limitation of Specification 4.0.2 is based on engineering judgement and the recognition that the most probable result of any particular surveillance being performed is the verification of conformance with the Surveillance Requirements. This provision is sufficient to ensure that the reliability ensured through surveillance activities is not significantly degraded beyond that obtained from the specified surveillance interval.

Safety Analysis

Technical Specification 4.0.2 accepts currently established surveillance intervals and the use of a 25 percent extension as providing a sufficient level of protection. The intent of the 3.25 limit is to preclude routine use of the provision for extending a surveillance interval by 25 percent. The Commission in its review of Commonwealth Edison Company's lead-plant proposal to remove the 3.25 limitation on extending surveillance intervals stated the following:

"The use of the allowance to extend surveillance intervals by 25 percent can also result in a significant safety benefit for surveillances that are performed on a routine basis during plant operation. This safety benefit is incurred when a surveillance interval is extended at a time that conditions are not suitable for performing the surveillance. Examples of this include transient plant operating conditions or conditions in which safety systems are out of service because of ongoing surveillance or maintenance activities. In such cases, the safety benefit of allowing the use of the 25 percent allowance to extend a surveillance interval would



11
12
13
14
15

[The main body of the page contains extremely faint and illegible text, likely bleed-through from the reverse side of the paper. The text is scattered across the page and does not form any recognizable words or sentences.]

outweigh any benefit derived by limiting three consecutive surveillance intervals to the 3.25 limit. Also, there is the administrative burden associated with tracking the use of the 25 percent allowance to ensure compliance with the 3.25 limit. On the basis of these considerations, the staff concluded that removal of the 3.25 limit will have an overall positive impact on safety."

Based on the above, the proposed change to Technical Specification 4.0.2 will remove unnecessary restriction on extending surveillance requirements and will result in a benefit to safety when plant conditions are not conducive to the safe conduct of surveillance requirements. The removal of the 3.25 limit will provide greater flexibility in the use of the provision for extending surveillance intervals, reduce the administrative burden associated with its use, and have a positive effect on safety.

No Significant Hazards Considerations

- I. The proposed change does not involve a significant increase in the probability or consequences of an accident previously evaluated.

The 3.25 surveillance interval extension criteria of Technical Specification 4.0.2 was not taken credit for in the evaluation of the probability or severity of events analyzed in the plant accident analysis (FSAR Chapter 15).

Additionally, the 18 month refuel interval was originally chosen to correspond to the expected operating cycle length such that these surveillances would be performed during the shutdown period (Reference Generic Letter 83-27). Since no technical basis is specified for the 18 month interval other than conformance with expected operating cycle length, deleting the 3.25 requirement for 18 month surveillances does not involve a significant decrease in the effectiveness of the monitoring provision.

- II. The proposed change does not create the possibility of a new or different kind of accident from any accident previously evaluated since the surveillance interval will still be constrained by the maximum 1.25 interval extension criteria of Technical Specification 4.0.2.
- III. The proposed change does not involve a significant reduction in the margin of safety. The Commission in its review of Commonwealth Edison Company's lead-plant proposal to remove the 3.25 limitation on extending surveillance intervals stated the following:

"The use of the allowance to extend surveillance intervals by 25 percent can also result in a significant safety benefit for surveillances that are performed on a routine basis during plant operation. This safety benefit is incurred when a surveillance interval is extended at a time that conditions are not suitable for performing the surveillance. Examples of this include transient



Small, faint markings or characters in the top right corner.

23 + 1000 2117 800 1000

1000 1000 1000 1000 1000 1000

2

1000

plant operating conditions or conditions in which safety systems are out of service because of ongoing surveillance or maintenance activities. In such cases, the safety benefit of allowing the use of the 25 percent allowance to extend a surveillance interval would outweigh any benefit derived by limiting three consecutive surveillance intervals to the 3.25 limit. Also, there is the administrative burden associated with tracking the use of the 25 percent allowance to ensure compliance with the 3.25 limit. On the basis of these considerations, the staff concluded that removal of the 3.25 limit will have an overall positive impact on safety."

Guidance has been provided in 51 FR 7744 for the application of standards to license change requests for determination of the existence of significant hazards considerations. This document provides examples of amendments which are and are not considered likely to involve significant hazards considerations. This proposed amendment does not involve a significant relaxation of the criteria used to establish safety limits, a significant relaxation of the bases for the limiting safety system settings or a significant relaxation of the bases for the limiting conditions for operations. Therefore, based on the guidance provided in the Federal Register and the criteria established in 10 CFR 50.92(e), the proposed change does not constitute a significant hazards consideration.

Implementation

Expeditious review of this proposed change is requested. The proposed amendment is consistent with guidance provided in Generic Letter 89-14, dated August 21, 1989.

Any questions on this submittal should be directed to Mr. W.W. Williams at (215) 770-7910.

Very truly yours,



H. W. Keiser

Attachment

cc: NRC Document Control Desk (original)
NRC Region I
Mr. G. S. Barber, NRC Resident Inspector - SSES
Mr. M. C. Thadani, NRC Project Manager
Mr. T. M. Gerusky, Pennsylvania DER



11
12
13
14
15

16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100
101
102
103
104
105
106
107
108
109
110
111
112
113
114
115
116
117
118
119
120
121
122
123
124
125
126
127
128
129
130
131
132
133
134
135
136
137
138
139
140
141
142
143
144
145
146
147
148
149
150
151
152
153
154
155
156
157
158
159
160
161
162
163
164
165
166
167
168
169
170
171
172
173
174
175
176
177
178
179
180
181
182
183
184
185
186
187
188
189
190
191
192
193
194
195
196
197
198
199
200
201
202
203
204
205
206
207
208
209
210
211
212
213
214
215
216
217
218
219
220
221
222
223
224
225
226
227
228
229
230
231
232
233
234
235
236
237
238
239
240
241
242
243
244
245
246
247
248
249
250
251
252
253
254
255
256
257
258
259
260
261
262
263
264
265
266
267
268
269
270
271
272
273
274
275
276
277
278
279
280
281
282
283
284
285
286
287
288
289
290
291
292
293
294
295
296
297
298
299
300
301
302
303
304
305
306
307
308
309
310
311
312
313
314
315
316
317
318
319
320
321
322
323
324
325
326
327
328
329
330
331
332
333
334
335
336
337
338
339
340
341
342
343
344
345
346
347
348
349
350
351
352
353
354
355
356
357
358
359
360
361
362
363
364
365
366
367
368
369
370
371
372
373
374
375
376
377
378
379
380
381
382
383
384
385
386
387
388
389
390
391
392
393
394
395
396
397
398
399
400
401
402
403
404
405
406
407
408
409
410
411
412
413
414
415
416
417
418
419
420
421
422
423
424
425
426
427
428
429
430
431
432
433
434
435
436
437
438
439
440
441
442
443
444
445
446
447
448
449
450
451
452
453
454
455
456
457
458
459
460
461
462
463
464
465
466
467
468
469
470
471
472
473
474
475
476
477
478
479
480
481
482
483
484
485
486
487
488
489
490
491
492
493
494
495
496
497
498
499
500
501
502
503
504
505
506
507
508
509
510
511
512
513
514
515
516
517
518
519
520
521
522
523
524
525
526
527
528
529
530
531
532
533
534
535
536
537
538
539
540
541
542
543
544
545
546
547
548
549
550
551
552
553
554
555
556
557
558
559
560
561
562
563
564
565
566
567
568
569
570
571
572
573
574
575
576
577
578
579
580
581
582
583
584
585
586
587
588
589
590
591
592
593
594
595
596
597
598
599
600
601
602
603
604
605
606
607
608
609
610
611
612
613
614
615
616
617
618
619
620
621
622
623
624
625
626
627
628
629
630
631
632
633
634
635
636
637
638
639
640
641
642
643
644
645
646
647
648
649
650
651
652
653
654
655
656
657
658
659
660
661
662
663
664
665
666
667
668
669
670
671
672
673
674
675
676
677
678
679
680
681
682
683
684
685
686
687
688
689
690
691
692
693
694
695
696
697
698
699
700
701
702
703
704
705
706
707
708
709
710
711
712
713
714
715
716
717
718
719
720
721
722
723
724
725
726
727
728
729
730
731
732
733
734
735
736
737
738
739
740
741
742
743
744
745
746
747
748
749
750
751
752
753
754
755
756
757
758
759
760
761
762
763
764
765
766
767
768
769
770
771
772
773
774
775
776
777
778
779
780
781
782
783
784
785
786
787
788
789
790
791
792
793
794
795
796
797
798
799
800
801
802
803
804
805
806
807
808
809
810
811
812
813
814
815
816
817
818
819
820
821
822
823
824
825
826
827
828
829
830
831
832
833
834
835
836
837
838
839
840
841
842
843
844
845
846
847
848
849
850
851
852
853
854
855
856
857
858
859
860
861
862
863
864
865
866
867
868
869
870
871
872
873
874
875
876
877
878
879
880
881
882
883
884
885
886
887
888
889
890
891
892
893
894
895
896
897
898
899
900
901
902
903
904
905
906
907
908
909
910
911
912
913
914
915
916
917
918
919
920
921
922
923
924
925
926
927
928
929
930
931
932
933
934
935
936
937
938
939
940
941
942
943
944
945
946
947
948
949
950
951
952
953
954
955
956
957
958
959
960
961
962
963
964
965
966
967
968
969
970
971
972
973
974
975
976
977
978
979
980
981
982
983
984
985
986
987
988
989
990
991
992
993
994
995
996
997
998
999
1000