

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9003120072 DOC. DATE: 90/02/28 NOTARIZED: NO DOCKET #
 FACIL: 50-388 Susquehanna Steam Electric Station, Unit 2, Pennsylvania 05000388
 AUTH. NAME AUTHOR AFFILIATION
 KEISER, H.W. Pennsylvania Power & Light Co.
 RECIPIENT NAME RECIPIENT AFFILIATION
 BUTLER, W.R. Project Directorate I-2

SUBJECT: Discusses util cycle 4 stability data consisting of full core of ANF 9x9 fuel.

DISTRIBUTION CODE: A001D COPIES RECEIVED: LTR ENCL SIZE: 8
 TITLE: OR Submittal: General Distribution

NOTES: LPDR 1 cy Transcripts. 05000388

	RECIPIENT ID CODE/NAME	COPIES LTTR	ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR	ENCL
	PD1-2 LA THADANI, M	1 5	1 5	PD1-2 PD	1 1	1 1
INTERNAL:	ACRS	6	6	NRR/DET/ECMB 9H	1	1
	NRR/DOEA/OTSB11	1	1	NRR/DST 8E2	1	1
	NRR/DST/SELB 8D	1	1	NRR/DST/SICB 7E	1	1
	NRR/DST/SRXB 8E	1	1	NUDOCS-ABSTRACT	1	1
	OC/LEMB	1	0	OGC/HDS2	1	0
	<u>REG FILE</u> 01	1	1	RES/DSIR/EIB	1	1
EXTERNAL:	LPDR	1	1	NRC PDR	1	1
	NSIC	1	1			
NOTES:		2	2			

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,
 ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION
 LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 29 ENCL 27

M-A-4



SECRET

SECRET



Pennsylvania Power & Light Company

Two North Ninth Street • Allentown, PA 18101 • 215 / 770-5151

Harold W. Keiser
Senior Vice President-Nuclear
215/770-4194

FEB 28 1990

Director of Nuclear Reactor Regulation
Attention: Dr. W. R. Butler, Project Director
Project Directorate I-2
Division of Reactor Projects
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

SUSQUEHANNA STEAM ELECTRIC STATION
UNIT 2/CYCLE 4 STABILITY DATA
PLA-3344 FILES R41-2, A7-8C

Docket No. 50-388

Reference: Letter from M.C. Thadani (NRC) to H.W. Keiser (PP&L), "Technical Specification Changes To Support Cycle 4 Operation (TAC No. 73588)", dated November 3, 1989.

Dear Dr. Butler:

The NRC Safety Evaluation for Susquehanna SES Cycle 4 stated that stability measurements should be made during initial startup and when reasonably possible during the cycle and the data should be presented to the NRC. The Susquehanna SES Unit 2 Cycle 4 consists of a full core of ANF 9x9 fuel.

A tape containing one file of GETARS data that was recorded during the Unit 2 Cycle 4 beginning of cycle stability testing is being sent under separate cover to our NRC Project Manager. This file contains the following data points stored in engineering units at every 0.033 seconds: Time, APRM A, APRM B, APRM C, APRM D, APRM E, APRM F, Total Core Flow, and Narrow Range Pressure. The tape contains IBM standard labels and a density of 6250 BPI. In addition, a POWERPLEX edit which was taken at the beginning of the test and a sample JCL listing that may be used to read the tape are enclosed.

PP&L also plans to obtain neutron flux noise data near the end of the cycle. In addition, if during the cycle a plant evolution or maintenance activity requires the plant to operate near the instability region for a few hours, noise data will be obtained. All stability data obtained during the Unit 2 Cycle 4 operation will be provided to the NRC.

9003120072 900228
PDR ADOCK 05000388
P PDC

A001
1/1



1942

1943

1944

1945

1946

1947

1948

1949

1950

1951

1952

1953

1954

1955

1956

1957

1958

1959

1960

1961

If you need additional data or information regarding the test, please contact Mr. R.R. Sgarro (215-770-7916). Also we request a copy of any analysis performed by you or your contractors as a result of using this data.

Very truly yours,



H. W. Keiser

Enclosures

cc: NRC Document Control Desk (original)
NRC Region I
Mr. G. S. Barber, NRC Sr. Resident Inspector
Mr. M. C. Thadani, NRC Project Manager



11

12

13

14

15

16

17

18

19

20

21

22

VOLUME SERIAL: 012394
IBM STANDARD LABEL
6250 BPI
1 FILE

CONTENTS OF TAPE 012394

<u>FILE</u>	<u>DATA SET NAME</u>	<u>LRECL</u>	<u>BLKSIZE</u>	<u>RECFM</u>
1	TEST.GETARS.DATA	8504	17012	VB

SAMPLE JCL TO UNLOAD TAPE 012394

```
//      JOBCARD
//S1 EXEC PGM=IEBGENER,REGION=500K,TIME=10,PARM='IBM'
//SYSIN DD DUMMY
//SYSPRINT DD SYSOUT=*
//SYSUT1 DD DSN=TEST.GETARS.DATA,DISP=(OLD,KEEP),
// DCB=(BLKSIZE=17012,LRECL=8504,RECFM=VB),UNIT=3420,
// VOL=(,RETAIN, , ,SER=012394),
// LABEL=(1,SL)
//SYSUT2 DD DSN=PPL.GETARS.DATA,UNIT=SYSDA,
// DISP=(NEW,CATLG),DCB=(BLKSIZE=17012,LRECL=8504,RECFM=VB),
// SPACE=(17012,(1500,1500),RLSE)
```



11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100

101
102
103
104
105
106
107
108
109
110
111
112
113
114
115
116
117
118
119
120
121
122
123
124
125
126
127
128
129
130
131
132
133
134
135
136
137
138
139
140
141
142
143
144
145
146
147
148
149
150
151
152
153
154
155
156
157
158
159
160
161
162
163
164
165
166
167
168
169
170
171
172
173
174
175
176
177
178
179
180
181
182
183
184
185
186
187
188
189
190
191
192
193
194
195
196
197
198
199
200

201
202
203
204
205
206
207
208
209
210
211
212
213
214
215
216
217
218
219
220
221
222
223
224
225
226
227
228
229
230
231
232
233
234
235
236
237
238
239
240
241
242
243
244
245
246
247
248
249
250
251
252
253
254
255
256
257
258
259
260
261
262
263
264
265
266
267
268
269
270
271
272
273
274
275
276
277
278
279
280
281
282
283
284
285
286
287
288
289
290
291
292
293
294
295
296
297
298
299
300


```

*****
*                               DATA FOR SUSQUEHANNA 2                               *
*                               OPERATING STATE FILE EDIT                             *
*-----*
* P D/T - BEGIN                               H D/T - BEGIN                       *
*      89DEC08-23.00.06                       89DEC08-21.54.18                   *
*                               CORE EXPOSURE = 300.77                            *
*                               CYCLE MWDE   = 13005.46                            *
*                               CYCLE MWDT   = 39794.46                            *
* NUMBER OF SCANS IN OPSTATE   = 5          TRIGGER EVENT † FOR OPSTATE          *
*                               0000000000 1000000000 0000000000                  *
* P D/T - END-OPS                               H D/T - END-OPS                       *
*      89DEC08-23.04.06                       89DEC08-23.04.06                   *
*-----*
*****

```

† CONTROL ROD NOTCH POSITIONS FOR SUSQUEHANNA 2 †
† (PROCESS COMPUTER COORDINATES) †


	02	06	10	14	18	22	26	30	34	38	42	46	50	54	58	
59					--	--	--	--	--	--	--					59
55					--	--	--	--	--	--	--					55
51			--	--	42	--	14	--	14	--	42	--	--			51
47		--	--	--	--	--	--	--	--	--	--	--	--	--		47
43	--	--	42	--	20	--	40	--	40	--	20	--	42	--	--	43
39	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	39
35	--	--	14	--	40	--	10	--	10	--	40	--	14	--	--	35
31	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	31
27	--	--	14	--	40	--	10	--	10	--	40	--	14	--	--	27
23	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	23
19	--	--	42	--	20	--	40	--	40	--	20	--	42	--	--	19
15		--	--	--	--	--	--	--	--	--	--	--	--	--		15
11			--	--	42	--	14	--	14	--	42	--	--			11
07																07
03					--	--	--	--	--	--	--					03

*** CONTROL ROD SEQUENCE : A-1 ***

C

+ LPRM READINGS - UNCALIBRATED FOR SUSQUEHANNA 2 +
 + (PROCESS COMPUTER COORDINATES) +

	(1657)	(2457)	(3257)	(4057)		
	12.1	15.3	16.2	14.5		
	18.0	22.3	22.6	22.3		
	23.0	26.2	28.1	27.5		
	25.8	38.1	36.6	34.7		
(0849)	(1649)	(2449)	(3249)	(4049)	(4849)	
13.8	23.3	22.6	23.4	21.3	16.1	
20.5	29.8	28.8	-0.1	29.1	25.4	
24.4	33.1	30.5	29.0	31.7	30.5	
25.9	35.3	30.7	33.6	33.5	34.2	
(0841)	(1641)	(2441)	(3241)	(4041)	(4841)	(5641)
16.3	22.7	21.6	18.1	20.7	21.8	14.5
25.8	31.4	34.2	31.3	34.8	31.0	22.7
29.0	29.5	35.0	32.8	32.5	33.3	27.1
35.4	33.0	35.4	35.3	33.6	35.8	39.0
(0833)	(1633)	(2433)	(3233)	(4033)	(4833)	(5633)
21.6	23.9	26.7	28.2	22.3	21.8	16.3
26.0	31.9	29.8	30.6	32.5	-0.2	22.6
28.6	38.3	-0.4	30.2	34.5	29.7	27.1
34.2	34.3	35.2	39.8	36.8	33.3	36.5
(0825)	(1625)	(2425)	(3225)	(4025)	(4825)	(5625)
18.0	23.5	26.9	26.1	24.2	19.7	13.2
24.0	33.6	31.9	31.0	33.7	27.6	20.3
26.4	36.2	33.3	30.0	35.6	28.7	24.6
32.0	35.4	36.1	35.0	-0.1	32.7	34.6
(0817)	(1617)	(2417)	(3217)	(4017)	(4817)	(5617)
16.3	21.0	22.6	24.4	22.0	19.1	11.7
26.8	30.6	33.2	34.0	31.8	29.9	18.0
31.4	27.6	27.1	36.0	30.6	34.6	22.8
32.8	28.8	34.9	33.0	35.3	33.2	23.4
	(1609)	(2409)	(3209)	(4009)	(4809)	
	17.4	19.1	21.4	17.8	12.2	
	25.8	23.8	25.9	27.9	20.0	
	31.9	26.3	28.3	30.1	22.6	
	36.3	31.2	33.1	37.7	24.2	



+
+ XTG INPUTS AND SCAN DATA EDIT FOR SUSQUEHANNA-2 +
+

NAME OR POINT ID	DESCRIPTION (ALL FLOWS IN MLB/HR ALL TEMPERATURES IN DEG F)	VALUE
*WT	TOTAL CORE FLOW USED IN H.B.	45.972
*WL	ACTIVE/TOTAL CORE FLOW FRAC	0.90000
NFP51	REACTOR PRESSURE (PSIA)	968.55
*MWT	CORE THERMAL POWER (MWT)	2050.7
*DHS	CORE INLET SUBCOOLING (BTU/LB)	-36.993
*ENDEL	CORE ENERGY INCREMENT (MWHT)	31.603
NM551	APRM READING(A)-CHAN 01 (ZPWR)	63.637
NM553	APRM READING(C)-CHAN 02 (ZPWR)	63.000
NM555	APRM READING(E)-CHAN 03 (ZPWR)	62.962
NM552	APRM READING(B)-CHAN 04 (ZPWR)	63.187
NM554	APRM READING(D)-CHAN 05 (ZPWR)	62.637
NM556	APRM READING(F)-CHAN 06 (ZPWR)	62.675
*HBFLAG	CTP CALC. (0-HT BAL, 1-APRM)	0.00000
NJP51	REACTOR CORE PRES. DROP (PSID)	2.5725
NEF51*K1	CRD FLOW (MLB/HR)	0.31500E-01
NLF51*K2	CLEANUP LOOP FLOW (MLB/HR)	0.10494
NLT52	CLEANUP LOOP INLET TEMP (DEGF)	526.50
NLT51	CLEANUP LOOP EXIT TEMP (DEGF)	439.05
NFL01(DCS)	REACTOR WATER LEVEL (INCHES)	35.537
NFF51	REACTOR STEAM FLOW	8.1067
GNJ02	GROSS GENERATOR POWER (MWE)	650.70
DFWFA	FW FLOW A, WGHTD AVE (MLB/HR)	2.6055
DFWFB	FW FLOW B, WGHTD AVE (MLB/HR)	2.7242
DFWFC	FW FLOW C, WGHTD AVE (MLB/HR)	2.6243
NRJ51	RECIRC PUMP A POWER (MW)	0.33618
NRJ52	RECIRC PUMP B POWER (MW)	0.13842
NFF52	FEEDWATER FLOW, A (MLB/HR)	2.5999
NFF53	FEEDWATER FLOW, B (MLB/HR)	2.7364
NFF54	FEEDWATER FLOW, C (MLB/HR)	2.6190
NBT51	FW TEMP 1, BRANCH A (DEGF)	346.96
NBT52	FW TEMP 2, BRANCH A (DEGF)	346.71
NBT53	FW TEMP 1, BRANCH B (DEGF)	344.64
NBT54	FW TEMP 2, BRANCH B (DEGF)	344.28
NBT55	FW TEMP 1, BRANCH C (DEGF)	344.67
NBT56	FW TEMP 2, BRANCH C (DEGF)	344.08
NRF51*K3	RECIRC FLOW, A1 (MLB/HR)	6.4595
NRF53*K3	RECIRC FLOW, A2 (MLB/HR)	6.4208
NRF52*K3	RECIRC FLOW, B1 (MLB/HR)	5.2973
NRF54*K3	RECIRC FLOW, B2 (MLB/HR)	5.0999
NRT51	RECIRC TEMP, A1 (DEGF)	511.36
NRT52	RECIRC TEMP, A2 (DEGF)	510.24
NRT53	RECIRC TEMP, B1 (DEGF)	508.62
NRT54	RECIRC TEMP, B2 (DEGF)	508.75
*GENDEL	GENERATOR ENERGY INCR. (MWE)	10.000

```

+-----+
+ XTG INPUTS AND SCAN DATA EDIT FOR SUSQUEHANNA-2 +
+-----+

```

NAME OR POINT ID	DESCRIPTION (ALL FLOWS IN MLB/HR ALL TEMPERATURES IN DEG F)	VALUE
*WTSUB	CORE FLOW FROM FUNCTION F4	50.787
NJF51	WT FROM J.P. OR INPUT (MLB/HR)	45.972
WD	TOTAL RECIRC FLOW	11.639
*WTFLAG	CORE FLOW FLAG	2.0000
*CRD	CONTROL ROD DENSITY	0.72973E-01
*CRDSYM	CONTROL ROD SYMMETRY FLAG	0.00000



11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100

*** FAILED SENSORS ***

CR102-35 MAN | L32-49-C LOW | L24-33-B LOW | L48-33-C LOW | L40-25-A LOW