

ADMINISTRATIVE CONTROLS

6.2.3 NUCLEAR SAFETY ASSESSMENT GROUP (NSAG)

FUNCTION

6.2.3.1 The NSAG shall function to examine unit operating characteristics, NRC issuances, industry advisories, Licensee Event Reports, and other sources of plant design and operating experience information, including plants of similar design, which may indicate areas for improving plant safety.

COMPOSITION

6.2.3.2 The NSAG shall be composed of at least five dedicated, full-time engineers with at least three located onsite, each with a bachelor's degree in engineering or related science and at least two years professional level experience in his field, at least one year of which experience shall be in the nuclear field.

RESPONSIBILITIES

6.2.3.3 The NSAG shall be responsible for maintaining surveillance of unit activities to provide independent verification* that these activities are performed correctly and that human errors are reduced as much as practical.

AUTHORITY

6.2.3.4 The NSAG shall make detailed recommendations for revised procedures, equipment modifications, maintenance activities, operations activities, or other means of improving unit safety to the Senior Vice President-Nuclear.

6.2.4 SHIFT TECHNICAL ADVISOR

6.2.4.1 The Shift Technical Advisor shall provide technical support to the Shift Supervisor in the areas of thermal hydraulics, reactor engineering, and plant analysis with regard to the safe operation of the unit.

6.3 UNIT STAFF QUALIFICATIONS

6.3.1 Each member of the unit staff shall meet or exceed the minimum qualifications of ANSI N18.1-1971 for comparable positions and the supplemental requirements specified in Section A and C of Enclosure 1 of the March 28, 1980 NRC letter to all licensees, except for the Radiological Protection Supervisor or Health Physics/Chemistry Supervisor who shall meet or exceed the qualifications of Regulatory Guide 1.8, September 1975, and the shift Technical Advisor who shall meet or exceed the qualifications referred to in Section 2.2.1.b of Enclosure 1 of the October 30, 1979 NRC letter to all operating nuclear power plants.

6.4 TRAINING

6.4.1 A retraining and replacement training program for the unit staff shall ^{and} be maintained under the direction of the Manager - Nuclear Training, shall meet or exceed the requirements and recommendations of Section 5.5 of ANSI N18.1-1971, and Appendix "A" of 10 CFR Part 55 and the supplemental requirements specified in Section A and C of Enclosure 1 of the March 28, 1980 NRC letter to all licensees, and shall include familiarization with relevant industry operational experience, ~~except that the licensed operator initial training and~~ ^{and} ~~regulification programs shall meet or exceed the requirements of 10 CFR 55~~

*Not responsible for sign-off function.


SUSQUEHANNA - UNIT 1

6-7

Amendment No. 47

and utilize the guidance contained in Regulatory Guide 1.8 Rev. 2.

9004160014 900402
PDR ADOCK 05000387
P PDC



ADMINISTRATIVE CONTROLS

6.2.3 NUCLEAR SAFETY ASSESSMENT GROUP (NSAG)

FUNCTION

6.2.3.1 The NSAG shall function to examine unit operating characteristics, NRC issuances, industry advisories, Licensee Event Reports, and other sources of plant design and operating experience information, including plants of similar design, which may indicate areas for improving plant safety.

COMPOSITION

6.2.3.2 The NSAG shall be composed of at least five dedicated, full-time engineers with at least three located onsite, each with a bachelor's degree in engineering or related science and at least two years professional level experience in his field, at least one year of which experience shall be in the nuclear field.

RESPONSIBILITIES

6.2.3.3 The NSAG shall be responsible for maintaining surveillance of unit activities to provide independent verification* that these activities are performed correctly and that human errors are reduced as much as practical.

AUTHORITY

6.2.3.4 The NSAG shall make detailed recommendations for revised procedures, equipment modifications, maintenance activities, operations activities, or other means of improving unit safety to the Senior Vice President-Nuclear.

6.2.4 SHIFT TECHNICAL ADVISOR

6.2.4.1 The Shift Technical Advisor shall provide technical support to the Shift Supervisor in the areas of thermal hydraulics, reactor engineering, and plant analysis with regard to the safe operation of the unit.

6.3 UNIT STAFF QUALIFICATIONS

6.3.1 Each member of the unit staff shall meet or exceed the minimum qualifications of ANSI N18.1-1971 for comparable positions and the supplemental requirements specified in Sections A and C of Enclosure 1 of the March 28, 1980 NRC letter to all licensees, except for the Radiological Protection Supervisor or Health Physics/Chemistry Supervisor who shall meet or exceed the qualifications of Regulatory Guide 1.8, September 1975, and the Shift Technical Advisor who shall meet or exceed the qualifications referred to in Section 2.2.1.b of Enclosure 1 of the October 30, 1979 NRC letter to all operating nuclear power plants.

6.4 TRAINING

6.4.1 A retraining and replacement training program for the unit staff shall ^{and} be maintained under the direction of the Manager - Nuclear Training, shall meet or exceed the requirements and recommendations of Section 5.5 of ANSI N18.1-1971 ~~and Appendix A of 10 CFR Part 55 and the supplemental requirements specified in Sections A and C of Enclosure 1 of the March 28, 1980 NRC letter to all licensees, and shall include familiarization with relevant industry operational experience.~~ *except that the licensed operator initial training and requalification programs shall meet or exceed the requirements of*

*Not responsible for sign-off function.