

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR:9004260329 DOC.DATE: 90/04/19 NOTARIZED: YES DOCKET #
 FACIL:50-387 Susquehanna Steam Electric Station, Unit 1, Pennsylv 05000387
 50-388 Susquehanna Steam Electric Station, Unit 2, Pennsylv 05000388
 AUTH.NAME AUTHOR AFFILIATION
 KEISER,H.W. Pennsylvania Power & Light Co.
 RECIP.NAME RECIPIENT AFFILIATION
 BUTLER,W.R. Project Directorate I-2

SUBJECT: Responds to NRC Bulletin 90-002, "Loss of Thermal Margin Caused by Channel Box Bow." Util has not used channel boxes for more than single bundle lifetime.

DISTRIBUTION CODE: IE38D COPIES RECEIVED:LTR / ENCL 0 SIZE: 2
 TITLE: NRC Bulletin 90-002, Loss of Thermal Margin Caused by Channel Box Bow

NOTES:LPDR 1 cy Transcripts. 05000387
 LPDR 1 cy Transcripts. 05000388

| | RECIPIENT | | COPIES | | | RECIPIENT | | COPIES | |
|-----------|-----------------|--|--------|------|--|------------------------|--|--------|------|
| | ID CODE/NAME | | LTR | ENCL | | ID CODE/NAME | | LTR | ENCL |
| | PD1-2 LA | | 1 | 0 | | PD1-2 PD | | 1 | 1 |
| INTERNAL: | AEOD/DOA | | 1 | 1 | | AEOD/DSP/TPAB | | 1 | 1 |
| | NRR FIENO,D | | 1 | 1 | | NRR LONG,W PD31 | | 1 | 1 |
| | NRR/DET/EMEB9H3 | | 1 | 1 | | NRR/DOEA/OEAB11 | | 1 | 1 |
| | NRR/DOEA/OGCB11 | | 1 | 1 | | NRR/DREP/PEPB9D | | 1 | 1 |
| | NRR/DST/ 8E2 | | 1 | 1 | | NRR/PMAS/ILRB12 | | 1 | 1 |
| | PM | | 1 | 1 | | REG FILE 02 | | 1 | 1 |
| | RES/DSIR/EIB | | 1 | 1 | | RGNI FILE 01 | | 1 | 1 |
| EXTERNAL: | LPDR | | 1 | 1 | | NRC PDR | | 1 | 1 |
| | NSIC | | 1 | 1 | | | | | |
| NOTES: | | | 2 | 2 | | | | | |

2nd distribution for notary

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK.
 ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION
 LISTS FOR DOCUMENTS YOU DON'T NEED!

*A10-1
 ent*

TOTAL NUMBER OF COPIES REQUIRED: LTR 21 ENCL 0



Pennsylvania Power & Light Company

Two North Ninth Street • Allentown, PA 18101 • 215 / 770-5151

Harold W. Keiser
Senior Vice President-Nuclear
215/770-4194

APR 19 1990

Director of Nuclear Reactor Regulation
Attention: Dr. W. R. Butler, Project Director
Project Directorate I-2
Division of Reactor Projects
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

SUSQUEHANNA STEAM ELECTRIC STATION
NRC BULLETIN NO. 90-02
PLA-3373 FILE R41-2

Docket Nos. 50-387
and 50-388

Dear Dr. Butler:

In response to NRC Bulletin No. 90-02, "Loss of Thermal Margin Caused by Channel Box Bow", Pennsylvania Power & Light Company has not used channel boxes for more than a single bundle lifetime.

Very truly yours,

H. W. Keiser

cc: NRC Document Control Desk (original)
NRC Region I
Mr. G. S. Barber, NRC Sr. Resident Inspector
Mr. M. C. Thadani, NRC Project Manager

9004260329 900419
FDR ADOCK 05000387
Q PDC

TE38
1/0

AFFIDAVIT

COMMONWEALTH OF PENNSYLVANIA)

: SS

COUNTY OF LEHIGH)

I, HAROLD W. KEISER, being duly sworn according to law, state that I am Sr. Vice President - Nuclear of Pennsylvania Power & Light Company and that the facts set forth on the attached response to NRC Bulletin 90-02 are true and correct to the best of my knowledge, information and belief.



Harold W. Keiser
Sr. Vice President - Nuclear

Sworn to and subscribed
before me this 19 day
of April, 1990.



Notary Public

Notarial Seal
Martha C. Sedora, Notary Public
Allentown, Lehigh County
My Commission Expires Jan. 15, 1994

Member, Pennsylvania Association of Notaries

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9004260329 DOC.DATE: 90/04/19 NOTARIZED: NO DOCKET #
 FACIL: 50-387 Susquehanna Steam Electric Station, Unit 1, Pennsylv 05000387
 50-388 Susquehanna Steam Electric Station, Unit 2, Pennsylv 05000388
 AUTH.NAME AUTHOR AFFILIATION
 KEISER, H.W. Pennsylvania Power & Light Co.
 RECIP.NAME RECIPIENT AFFILIATION
 BUTLER, W.R. Project Directorate I-2

SUBJECT: Responds to NRC Bulletin 90-002, "Loss of Thermal Margin Caused by Channel Box Bow."

DISTRIBUTION CODE: IE38D COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 2
 TITLE: NRC Bulletin 90-002, Loss of Thermal Margin Caused by Channel Box Bow

NOTES: LPDR 1 cy Transcripts. 05000387
 LPDR 1 cy Transcripts. 05000388

| | RECIPIENT | | COPIES | | | RECIPIENT | | COPIES | |
|-----------|--------------------|--|--------|------|--|------------------|--|--------|------|
| | ID CODE/NAME | | LTR | ENCL | | ID CODE/NAME | | LTR | ENCL |
| | PD1-2 LA | | 1 | 0 | | PD1-2 PD | | 1 | 1 |
| INTERNAL: | AEOD/DOA | | 1 | 1 | | AEOD/DSP/TPAB | | 1 | 1 |
| | NRR FIENO, D | | 1 | 1 | | NRR LONG, W PD31 | | 1 | 1 |
| | NRR/DET/EMEB9H3 | | 1 | 1 | | NRR/DOEA/OEAB11 | | 1 | 1 |
| | NRR/DOEA/OGCB11 | | 1 | 1 | | NRR/DREP/PEPB9D | | 1 | 1 |
| | NRR/DST/ 8E2 | | 1 | 1 | | NRR/PMAS/ILRB12 | | 1 | 1 |
| | NUDOCS-ABSTRACT | | 1 | 1 | | PM | | 1 | 1 |
| | <u>REG FILE</u> 02 | | 1 | 1 | | RES/DSIR/EIB | | 1 | 1 |
| | RGNI FILE 01 | | 1 | 1 | | | | | |
| EXTERNAL: | LPDR | | 1 | 1 | | NRC PDR | | 1 | 1 |
| | NSIC | | 1 | 1 | | | | | |
| NOTES: | | | 2 | 2 | | | | | |

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK, ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTR 22 ENCL 21

*A/0-1
ent*

R
I
D
S
/
A
D
E
S



Pennsylvania Power & Light Company

Two North Ninth Street • Allentown, PA 18101 • 215 / 770-5151

Harold W. Keiser
Senior Vice President-Nuclear
215/770-4194

APR 19 1990

Director of Nuclear Reactor Regulation
Attention: Dr. W. R. Butler, Project Director
Project Directorate I-2
Division of Reactor Projects
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

SUSQUEHANNA STEAM ELECTRIC STATION
NRC BULLETIN NO. 90-02
PLA-3373 FILE R41-2

Docket Nos. 50-387
and 50-388

Dear Dr. Butler:

In response to NRC Bulletin No. 90-02, "Loss of Thermal Margin Caused by Channel Box Bow", Pennsylvania Power & Light Company has not used channel boxes for more than a single bundle lifetime.

Very truly yours,

H. W. Keiser

cc: NRC Document Control Desk (original)
NRC Region I
Mr. G. S. Barber, NRC Sr. Resident Inspector
Mr. M. C. Thadani, NRC Project Manager

9004260329 900419
PDR ADUCK 05000387
R PDC

TEB8
110

