

LIMITING CONDITION FOR OPERATION (Continued)

2. For each of the four++ OPERABLE, aligned diesel generators:
 - a) Verify Surveillance Requirement 4.8.1.1.2.a.4 has been successfully performed within the last 24 hours, or
 - b) Perform Surveillance Requirement 4.8.1.1.2.a.4 sequentially on each diesel generator within 24 hours, and
 3. Restore both offsite circuits to OPERABLE status within 72 hours or be in at least HOT SHUTDOWN within the next 12 hours and in COLD SHUTDOWN within the following 24 hours.
- b. With one diesel generator of 3.8.1.1.b inoperable,
1. Perform Surveillance Requirement 4.8.1.1.1.a within one hour and at least once per 8 hours thereafter, and
 2. # For each of the remaining three OPERABLE, aligned diesel generators:
 - a) Verify Surveillance Requirement 4.8.1.1.2.a.4 has been successfully performed within the last 24 hours, or
 - ++++ b) Perform Surveillance Requirement 4.8.1.1.2.a.4 sequentially on each diesel generator within 24 hours, and
 3. Restore the diesel generator to OPERABLE status within 72 hours or be in at least HOT SHUTDOWN within the next 12 hours and in COLD SHUTDOWN within the following 24 hours. +++
- c. ## With one offsite circuit and one diesel generator of the above required A.C. electrical power sources inoperable,
1. Perform Surveillance Requirement 4.8.1.1.1.a on the remaining A.C. sources within one hour and at least once per 8 hours thereafter, and
 2. # Perform Surveillance Requirement 4.8.1.1.2.a.4 within 8 hours on the remaining three OPERABLE aligned diesel generators, and

++ If the cause of the inoperability of the offsite circuit is inoperability of an ESS transformer, only the two diesel generators associated with the inoperable ESS transformer are required to be tested.

This ACTION is not required to be performed if the diesel generator is inoperable solely due to preplanned preventative maintenance.

Performance of Surveillance Requirement 4.8.1.1.2.a.4 per Action Statement c, e, or f above meets the requirements of Action Statements a or b.

+++ On a one-time basis, this time may be extended to 15 days. This applies to the entry into this action which occurred on 8/30/90, and will expire when the LCO is restored, but no later than 1200 hours on 9/14/90.

++++ For the duration of the one-time extension specified in footnote +++, this action shall read, "Perform Surveillance Requirement 4.8.1.1.2.a.4 sequentially on each diesel generator within 24 hours and every 72 hours thereafter."

LIMITING CONDITION FOR OPERATION (Continued)

2. For each of the four++ OPERABLE, aligned diesel generators:
 - a) Verify Surveillance Requirement 4.8.1.1.2.a.4 has been successfully performed within the last 24 hours, or
 - b) Perform Surveillance Requirement 4.8.1.1.2.a.4 sequentially on each diesel generator within 24 hours, and
 3. Restore both offsite circuits to OPERABLE status within 72 hours or be in at least HOT SHUTDOWN within the next 12 hours and in COLD SHUTDOWN within the following 24 hours.
- b. With one diesel generator of 3.8.1.1.b inoperable,
1. Perform Surveillance Requirement 4.8.1.1.1.a within one hour and at least once per 8 hours thereafter, and
 2. # For each of the remaining three OPERABLE, aligned diesel generators:
 - a) Verify Surveillance Requirement 4.8.1.1.2.a.4 has been successfully performed within the last 24 hours, or
 - +++ b) Perform Surveillance Requirement 4.8.1.1.2.a.4 sequentially on each diesel generator within 24 hours, and
 3. Restore the diesel generator to OPERABLE status within 72 hours or be in at least HOT SHUTDOWN within the next 12 hours and in COLD SHUTDOWN within the following 24 hours. +++
- c. ## With one offsite circuit and one diesel generator of the above required A.C. electrical power sources inoperable,
1. Perform Surveillance Requirement 4.8.1.1.1.a on the remaining A.C. sources within one hour and at least once per 8 hours thereafter, and
 2. # Perform Surveillance Requirement 4.8.1.1.2.a.4 within 8 hours on the remaining three OPERABLE aligned diesel generators, and

++ If the cause of the inoperability of the offsite circuit is inoperability of an ESS transformer, only the two diesel generators associated with the inoperable ESS transformer are required to be tested.

This ACTION is not required to be performed if the diesel generator is inoperable solely due to preplanned preventative maintenance.

Performance of Surveillance Requirement 4.8.1.1.2.a.4 per Action Statement c, e, or f above meets the requirements of Action Statements a or b.

+++ On a one-time basis, this time may be extended to 15 days. This applies to the entry into this action which occurred on 8/30/90, and will expire when the LCO is restored, but no later than 1200 hours on 9/14/90.

++++ For the duration of the one-time extension specified in footnote +++, this action shall read, "Perform Surveillance Requirement 4.8.1.1.2.a.4 sequentially on each diesel generator within 24 hours and every 72 hours thereafter."