



UNITED STATES
NUCLEAR REGULATORY COMMISSION
REGION I
475 ALLENDALE ROAD
KING OF PRUSSIA, PENNSYLVANIA 19406

Docket Nos. 50-387 SEP 04 1990
50-388

Pennsylvania Power & Light Company
ATTN: Mr. Harold W. Keiser
Senior Vice President - Nuclear
2 North Ninth Street
Allentown, Pennsylvania 18101

Gentlemen:

Subject: Regional Waiver of Compliance Related to the Susquehanna
Steam Electric Station Units 1 and 2. Technical
Specifications Limiting Condition for Operation of
Emergency Diesel Generator

This responds to your September 1, 1990, letter requesting a
Regional Waiver of Compliance in order to allow you to prepare and
submit an emergency Technical Specification Amendment request for
an extension of the action statement time related to Emergency
Diesel Generator availability, and subsequent review and action by
the Office of Nuclear Reactor Regulation (NRR). A copy of your
request is enclosed for reference.

After careful consideration of your request, I have concluded that
(1) the four day extension of the Action Statement for A.C. Power
Source Operability (Technical Specification 3.8.1.1.b) is warranted
to process an emergency Technical Specification Amendment request
and (2) that the relief granted will not put the plant into an
unsafe condition.

A Regional Waiver of Compliance is hereby granted for a four day
extension of the Action Statement for A.C. Power Source Operability
of Technical Specification 3.8.1.1.b. The Regional Waiver of
Compliance grants relief from the requirements of Susquehanna Units
1 and 2 Technical Specifications 3.8.1.1 with the following
provisions.

1. The emergency Technical Specification Amendment request will
be submitted, reviewed, and acted upon by NRR within the four
day extension.
2. The compensatory actions specified in your waiver request will
be implemented throughout the duration of the waiver period.
3. The above provisions are effective at 12:00 noon on September
2, 1990, and expire at 12:00 noon on September 6, 1990.

00107

~~4-0100-1-267~~

(2pp)

H005
11

A/A-3
cur

This Waiver of Compliance and the provisions detailed above were discussed by Mr. P. Swetland and Mr. G. Stanley on September 1, 1990.

Sincerely,

Charles W. Hehl, Jr., for
Charles W. Hehl, Director
Division of Reactor Projects

Enclosure:
As Stated

cc w/encl:

A. R. Sabol, Manager, Nuclear Quality Assurance
J. M. Kenny, Licensing Group Supervisor
R. G. Bryam, Superintendent of Plant-SSES
S. B. Ungerer, Manager, Joint Generation Projects Department
J. D. Decker, Nuclear Services Manager, General Electric Co.
B. A. Snapp, Esquire, Assistant Corporate Counsel
H. D. Woodeshick, Special Office of the President
J. C. Tilton, III, Allegheny Electric Cooperative, Inc.
Public Document Room (PDR)
Local Public Document Room (LPDR)
Nuclear Safety Information Center (NSIC)
NRC Resident Inspector
Commonwealth of Pennsylvania